

1

A CATALOG OF CURRENT DER APPROACHES AND INCENTIVES

INTRODUCTION

This chapter catalogs various approaches that states and utilities have used to begin integrating distributed energy resources (DER) into evolving energy markets.⁶ Its intent is to offer insights about what has been tried to date, and starting points for designing win-win incentive approaches that can benefit multiple parties, and can be implemented through collaborative stakeholder efforts.

The discussion concentrates less on technical features than on market mechanisms, regulatory constructs, and relationships among participants in these programs. It describes each program approach, and provides examples (sometimes differing only slightly in design). Although specific attributes of the approaches may vary by location, regulatory jurisdiction, participants, target applications and other features, the examples illustrate basic concepts that can be combined, expanded, refined and applied to different circumstances.

Table 1 below provides an overview of the chapter. The table is organized roughly according to the primary interests on which each approach focuses – i.e., the interests of the distribution utility, the bulk power utility, the DER customer, or society at large. These interests are not mutually exclusive, and they overlap in many of the examples. Still, distinguishing them in broad terms provides some structure for thinking about which approaches might be most useful for what purposes.

For each of the primary interests identified, the table lists various approaches that legislators, regulators, and utilities have tried to facilitate DER or to take advantage of its attributes. For each of the approaches listed, the table shows –

- examples of states and utilities that have tried it
- the stakeholder(s) that have driven the approach
- the need(s) addressed by the approach
- any incentive(s) offered *by* the utility
- any incentive(s) offered *to* the utility, and

⁶ 'DER' as used here includes not only distributed generation ('DG'), but also demand reduction and demand-side management (collectively, 'DSM') resources. Where programs are directed primarily or exclusively to DG or to DSM, those acronyms may be used.

- **distinguishing features of the approach**

Following Table 1, the remainder of the chapter describes each approach in more detail.

TABLE 1. RECENT APPROACHES TO DER INTEGRATION

I. Distribution Utility Focus: enhancing distribution system reliability through cost-effective asset deployment						
APPROACH	Example	Driver	Need Addressed	DER Incentive from utility	DER Incentive for utility	Distinguishing Features
A: PUCs require evaluation and acquisition of DG as grid alternative	New York	Utility Commission	Grid reinforcement	\$/kW/yr \$/kWh/yr	Reduced costs between rate cases	<ul style="list-style-type: none"> Required by PSC RFQ/RFP process First solicitation had little success
	California	Legislature & Utility Commission	Grid reliability and environmental improvement	Deferral value	Reduced costs between rate cases, and ROI	<ul style="list-style-type: none"> Result of multi-year proceedings Reliance on model contracts Utility-specific evaluation methods and procurement approaches
B: Utilities offer targeted incentives	O&R	Utility Commission	Grid reinforcement	Area-specific payment and reduced inter-connect cost	Reduced costs between rate cases	<ul style="list-style-type: none"> Area-specific payments based on value to local grid Reduced interconnection costs
	Mass Elec.	Utility		\$/kWh/event		

APPROACH	Example	Driver	Need Addressed	DER Incentive from utility	DER Incentive for utility	Distinguishing Features
C: Utilities use customer equipment for grid reliability	PGE	Utility	Grid reinforcement and customer reliability	Generator maintenance, payment for interconnection hardware, fuel	Reduced costs between rate cases	<ul style="list-style-type: none"> Utility dispatches customer generators as a utility resource. Utility assumes O&M responsibility and non-performance risk for non-utility equipment.
	Madison G&E	Utility		Customer receives guaranteed back-up service at fixed cost.	Cost recovery thru lease payments	<ul style="list-style-type: none"> Utility designs, installs and owns backup generators at customer locations Customer charge is determined through ratemaking process Utility bills service on customer's regular bill Customer payment represents a value-added service revenue stream for the utility
	D: Customers schedule loads for grid reliability	Utility and Customer	Grid reinforcement	Avoid line extension cost/rate discount	Customer satisfaction, continued revenue	<ul style="list-style-type: none"> Strong customer interest supported a multi-party collaborative process Customer curtails to utility load, not site load Combined with broader utility program
II. Bulk Power Utility Focus: mitigating wholesale prices and transmission congestion						
APPROACH	Example	Driver	Need Addressed	DER Incentive from utility	DER Incentive for utility	Distinguishing Features
A: Utilities install DER for wholesale and transmission purposes	Met-Ed	Utility	Wholesale energy, grid reliability and congestion mgt.	Shared LMP savings	Reduced energy and transmission congestion costs	<ul style="list-style-type: none"> DER vendor owns and dispatches units based on locational marginal prices Equipment used for multiple purposes
	AMP-Ohio	Utility	Transmission cost savings	N/A	Reduced FTR payments	<ul style="list-style-type: none"> DG used to reduce peak transmission costs Provides alternative to firm peaking service
B: Utilities purchase DER from aggregator	Public Service New Mexico and Celerity	Utility and DER Provider	Increase wholesale energy sales	Celerity pays fuel and maintenance PNM pays Celerity for KW and kWh.	PNM resells power in wholesale market	<ul style="list-style-type: none"> Third-party aggregator develops customer contracts and assembles supply Aggregator works with local AQMDs to reduce environmental impacts 25 MW now, with potential for 75 MW
	Com-Ed	Utility and DER Provider	Reduce costs of purchasing peak power	\$/MW / year	Lowered capacity costs	<ul style="list-style-type: none"> Utility contracts with third-party aggregator for 50 MW demand reduction at market prices Large-scale demand resource is tradeable

C: Utilities pay for load curtailment	BPA	Utility	Reduce costs of constructing transmission capacity	\$/kW / event	Reduced peak power expenses	<ul style="list-style-type: none"> Wholesale utility enlisted retail customers to help solve standard operational issues Winter rather than summer load control Uses demand response to avoid transmission construction
	NYISO	Utility (ISO)	Reduce costs of wholesale energy and increased grid reliability	\$/kW / event	Reduced peak power expense	<ul style="list-style-type: none"> ISO program \$500 / MWh minimum payment, regardless of market price
	PSE&G	Utility			Reduced peak power expense Recovery of administrative expense	<ul style="list-style-type: none"> Utility dispatches aggregated load control as a system resource Targets residential loads Utility controls customer equipment
III. DER Customer Focus: Increasing the reliability of on-site energy supplies and expanding energy options						
APPROACH	Example	Driver	Need Addressed	DER Incentive from utility	DER Incentive for utility	Distinguishing Features
A: Utility offers time-of-use pricing	Gulf Power	Utility	Offer customers a way to control energy costs through real time pricing	Lower energy costs	Customer pays to access the technology service	<ul style="list-style-type: none"> Value-added service opportunity for utility Residential customers use TOU rates to schedule use and reduce bills
B: Customer installs on-site co-generation	New Yorker Hotel	Customer	Increase on-site reliability and reduce energy costs thru CHP	On-site reliability or reduced overall energy costs	Often seen as negative due to loss of revenue	<ul style="list-style-type: none"> CHP system installed in New York City, a difficult place to site local generation DER provider owns and operates CHP facility and guarantees host energy savings
C: Customer installs on-site generator to adopt hourly pricing	Pa. Mail	Customer	Customer reliability, lower energy costs	Wholesale mkt. sales	N/A	<ul style="list-style-type: none"> DG becomes a tool in the customer's energy procurement strategy DER value in wholesale market exceeds value of avoided hourly purchases under demand response strategy

IV. Regulatory and Societal Focus: Increasing energy efficiency and improving environmental quality						
APPROACH	Example	Driver	Need Addressed	DER Incentive from utility	DER Incentive for utility	Distinguishing Features
A: States offer efficiency and renewable incentives	New York					<ul style="list-style-type: none"> Independent state agency administers program Focus on CHP efficiency value
	California	Legislature and Utility Commission or State Energy Agency	Reduce peak demand, Increase efficiency through CHP, and improve air quality through renewables	Direct customer payments, interest buy downs, etc.	N/A	<ul style="list-style-type: none"> CEC rebate program has stimulated renewables market, especially small PV CPUC tied incentive program administered by investor-owned utilities rewards ultra-clean, high-efficiency technologies DER size limits for both programs have limited their system impacts
	Texas					<ul style="list-style-type: none"> Administratively-set DER deferral value and contract length provides transparency Distribution utilities excluded from demand response and renewable DG projects
B: State requires solar DER in state energy supply	New Jersey	Utility Commission	Improve air quality	Required solar RPS	N/A	<ul style="list-style-type: none"> Solar RPS establishes a market for Renewable Energy Credits (RECs) from distributed solar Solar RECs available for customer-sited projects, recognizing retail value as well as RPS value Increased size limits for net metered systems enables larger seasonal users (e.g. schools) to recognize retail PV value

DESCRIPTIONS OF RECENT APPROACHES TO DER MARKET INTEGRATION

1. Distribution Utility Focus: enhancing system reliability through cost-effective asset deployment

- 1.A: New York and California public utility commissions require utilities to evaluate DG as a distribution alternative, and seek to acquire it where it is cost-effective**
 - 1.B: Orange & Rockland and Massachusetts Electric target incentives to customers that curtail load or dispatch backup generators to enhance grid reliability.**
 - 1.C: Portland General Electric and Madison G&E contract with customers to use their backup generators to enhance grid reliability.**
 - 1.D: Green Mountain Power negotiated an agreement with a large customer that requires the customer to curtail load based on grid reliability criteria.**
-

1.A: New York and California public utility commissions require utilities to evaluate DG as a distribution alternative, and seek to acquire it where it is cost-effective

New York Program Description: Having already adopted standardized interconnection requirements for small generators, in October 2001 the New York State Public Service Commission (NYPSC), established a pilot program to develop policies and procedures to integrate DG into utility distribution planning.⁷ The program's objectives are:

- to determine whether distribution system needs can be satisfied on a least-cost basis by creative and competitive means;
- to develop case-specific information on DG costs, benefits, and impacts across a range of distribution system conditions;
- to refine methods for evaluating customer-owned DG proposals against traditional system improvement projects;
- to determine whether a competitive process using requests for proposals (RFPs) is a viable and optimal means of eliciting a market response to the utility's distribution system needs.⁸

The program requires New York utilities to develop and issue RFPs for customer-side DG to meet specific capacity needs on their systems. Each utility is responsible to identify system needs that DG projects might meet, and to issue two RFPs in each planning year to potential DG

⁷ State of New York Public Service Commission, Opinion No. 01-5, Case 00-E-0005, *Proceeding on Motion of the Commission to Examine Costs, Benefits and Rates Regarding Distributed Generation*, p. 8. The Opinion did not address interconnection costs or standby rates, which are the subject of separate cases or orders.

⁸ *Id.*, pp. 8-9.

customers or vendors.⁹ Utilities can meet up to 50% of the needs identified in their RFPs with utility-owned DG. The RFPs must:

- address system needs at least 18 months in the future
- consider only technically feasible DG that can meet those needs
- solicit DG to meet load growth, for substation construction or expansion, or for projects on a radial distribution feeder where load may be temporarily islanded
- consider DG only for utility needs exceeding the following cost thresholds:¹⁰

Table 2. New York Cost Thresholds for DG Distribution Deferrals

Utility	Distribution Project Cost Threshold
Consolidated Edison	\$750,000
Niagara Mohawk	\$750,000
New York State Gas & Electric	\$500,000
Central Hudson Rochester Gas & Electric Orange & Rockland Utilities	\$500,000 (or if not enough projects are identified, \$250,000)

Four utilities¹¹ issued their first RFPs in 2002-03 for projects scheduled to come online in early 2004 or later. RFPs were issued only to pre-qualified bidders meeting certain minimum qualifications, and their content has not yet been made public. However, technical and cost evaluation criteria for proposed DG projects can include:

- costs to modify the system (allocated on a first-served basis)
- the need for a dedicated transformer to avoid islanding
- proposed redundancy to ensure minimum reliability standards
- potential lost revenues resulting from DG installation.¹²

The four utilities that have issued RFPs are expected to submit summary reports to the Commission during the Fall/Winter of 2003. These reports should document DG costs, vendor response, and experience integrating DG into utility planning. To our knowledge, the RFPs issued to date have not yet resulted in actual DG projects. At the end of the three-year pilot program, all utilities must submit final reports on their RFP results and pilot program efforts, to be used to refine future DG policies and programs.

⁹ Except that Consolidated Edison must issue four in the program's third and final year.

¹⁰ Id., p. 10.

¹¹ Consolidated Edison, Orange & Rockland, Niagara Mohawk, and New York Gas & Electric. The PSC has allowed the remaining two utilities an additional year because it issued its original order in November of the first year.

¹² The Order did not require utilities to evaluate the environmental impacts of DG proposals, although final program reports are expected to address these. Id., p. 28.

California Program Descriptions: Since 2001, California statutes have required investor-owned electric utilities, as part of distribution planning, to consider non-utility owned distributed resources as alternatives to distribution system investments.¹³ A February 2003 decision by the California Public Utilities Commission (CPUC), which also permits utility-owned DG, adopted a similar requirement.¹⁴ Among other things, it ordered California IOUs to describe the methodology each would use to evaluate DG as a distribution alternative, and to develop model contracts to acquire DG for that purpose. The decision states that the methodology should:

- *establish performance criteria* that balance reliability, safety and cost to determine when DG is a viable distribution alternative;
- *inform DG providers* of these criteria in advance, and of specific locations where DG may be procured;
- *procure the DG solution* where the utility determines that it is a potential distribution alternative;
- *develop model contracts* as a starting point for negotiations with nonutility providers;¹⁵ and
- *pay DG providers* who defer distribution upgrades through a bill credit or direct payment.

These credits or payments are to be charged to utility distribution budgets, and cannot exceed the utility's short-term carrying cost of capital, multiplied by the cost of the planned distribution addition and the number of years of deferral.¹⁶ In allowing the utilities to own DG assets, the decision provides that these are to be treated as generation assets, with costs and revenues booked to generation accounts.¹⁷

California's three major electric IOUs have made very similar compliance filings describing their DG evaluation methodologies. Pacific Gas & Electric (PG&E) and Southern California Edison (SCE) described an initial screening of distribution projects and a comparison of wires solutions with an 'ideal' DG alternative. Where the DG alternative appears less costly, the utility will analyze it in more detail. If it appears to offer an appropriate distribution alternative, the utility will issue an RFP to acquire it.

Proposals submitted in response to the RFP, along with DG proposals developed internally (at least for SCE) will be screened for technical adequacy. For those that pass, their costs will be compared with the costs of the utility's wires solution, and the least-cost alternative will be pursued. If that is the DG alternative, the DG provider must execute the utility's model contract or one similar to it, and assure project completion by a drop-dead date that allows the utility to revert to its wires solution if necessary to meet its required in-service date.

¹³ California Public Utilities Code §353.5.

¹⁴ D. 03-02-068, issued February 27, 2003 in R. 99-10-025. This rulemaking chose to focus on distributed *generation*, rather than the broader category of distributed energy *resources* (which would include conservation, efficiency and load management), so this discussion of California initiatives sometimes refers to 'DG' rather than 'DER'

¹⁵ The CPUC does not intend to mandate or adopt specific contract terms. *Id.*, p.20.

¹⁶ *Id.*, Order, paragraphs 4 and 5.

¹⁷ *Id.*, p. 26 and Ordering paragraph 6.

San Diego Gas & Electric's (SDG&E) process is similar, but includes explicit evaluation guidelines to identify situations that may favor DG. More importantly, SDG&E would substitute its normal equipment procurement process for the RFP approach proposed by the other two utilities, potentially reducing transactions costs for all participants. This process would periodically identify potential DG vendors in advance, and would pre-qualify them based on relevant experience and credit-worthiness. Once potential DG projects are identified, only pre-qualified vendors would be solicited to bid on them.¹⁸

These utility DG methodologies to acquire DG as a distribution alternative were filed in May, 2003, and apparently had not resulted in actual DG procurements for that purpose by the end of the year.

Distinguishing Features of the New York and California Examples

1. New York

Requirement that utilities participate in a process to procure DER as an alternative to traditional utility approaches

Two-stage RFQ/RFP process designed to elicit customer and third-party DG solutions that utilities might not otherwise consider

Little success so far in stimulating new DER installations, because program design has not yet synchronized utility needs with DER provider needs.

2. California

California's DER planning and procurement approach was one of a number of directives to emerge from a multi-year Commission proceeding involving all major DER stakeholders.

The process contemplates that utilities and DER providers will negotiate bilateral contracts using model provisions submitted to the Commission as a starting point.

The methodology described by SDG&E offers more explicit evaluation guidelines and possibly a more streamlined DG procurement process than the other IOU approaches, but all have yet to be tested in practice.

¹⁸ Apart from procuring DG as a distribution alternative, California IOUs have resumed responsibility for procuring roughly 10% of their customers' bundled service power not supplied by the IOUs' retained nuclear and hydro resources, or under long-term contracts. CPUC rules governing this broader procurement responsibility direct the utilities to explicitly include DG and 'self-generation' resources such as CHP in their procurement plans, stressing that these technologies can provide important transmission and grid-support benefits as well as energy and capacity. The Commission also expressly includes customer-side renewable DG among the resources utilities should procure under California's recently adopted renewable portfolio standard.

1.B: Orange & Rockland and Massachusetts Electric target incentives to customers that curtail load or dispatch backup generators to enhance grid reliability.

Orange and Rockland Description: In 1997, New York's Orange and Rockland Utilities (ORU), a transmission and distribution (T&D) company, had in place programs to encourage primary and secondary customers to relieve load on its system. Its Curtailable Load (CL) program offered those customers financial incentives in the form of summer bill credits for curtailing their load within four hours of the utility's request, for up to 75 hours during the summer. Its Temporary Buyback (TBB) program encouraged customers with back-up generation to interconnect, and paid them to deliver 250 kW or more onto ORU's grid at its request.

ORU recognized that the costs of these programs were high, and assembled a team to explore ways to reduce costs and increase program efficiency. One way to do this was to target specific geographic locations on ORU's system where peak load relief would offer the most T&D value, so the team evaluated what ORU should be willing to pay and in what form for such benefits at these locations. Their analysis resulted in regionally-based incentives that recognized T&D benefits as a value separate from capacity in areas where the utility needed local relief. In those areas, ORU offered an *additional \$3/kW T&D component* to the payments it was already offering for load curtailment and for temporary buybacks from customer back-up generation, as illustrated in the following table:

Table 3. Orange & Rockland TBB Incentives Recognizing Regional T&D Benefits

REGION	Capacity Rate – TBB*	Additional T&D Rate	Total Rate
1	\$2/kW	\$0/kW	\$2/kW
2	\$2/kW	\$0/kW	\$2/kW
3	\$2/kW	\$3/kW	\$5/kW

* The CL rate was \$3/kW.

ORU's geographic T&D adder significantly increased the amount of contracted kW load relief maintained after the summer 1998 peak season: from 81% in ORU's service territory generally, to 94% in the high-value region where ORU offered geographically-based T&D payments. In other words, by differentiating price signals to its customers, ORU targeted system relief more effectively and paid for it more efficiently. Customers initially responded and continued participating in the load relief program. Over time, ORU's overall incentive payments declined too much relative to customer curtailment costs, participation rates dropped, and the program was ended.

However, the program's early success revealed that customers are willing to relieve utility load if the incentive price offsets their own costs of providing relief. High enough incentive payments, reflecting geographically delineated T&D benefits, can successfully target load relief programs to areas of the utility's greatest need.

Two aspects of ORU's program may be useful in designing future approaches to integrate DER as a utility resource. First, the program led to an important partnering opportunity. Cummins Metro Power owned and operated more than half of the potential on-site generation resources in the area. ORU was able to partner with Cummins to simplify the dispatch process and reduce the utility's overall program costs, initially making the TBB portion of the program viable and successful.

Secondly, the ORU team learned that significant benefits can flow from a temporary buyback program differentiated by location. About 50% of the total potential peak load reduction capacity in ORU's service territory resided in a single region. This region relied on load reduction to address limited area transmission capability, adding value not only locally but to the overall system. If this area were to become overloaded, catastrophic electrical failures could occur throughout the system, so ORU had more incentive to secure adequate load reduction contracts in this region than in the rest of its service territory.

Massachusetts Electric Program Description:¹⁹ Massachusetts Electric (National Grid) identified a need to invest \$1.2 million to increase capacity at its Belmont Street substation in Brockton, Massachusetts. The need resulted from high loading during relatively few hours of the year.

Mass Electric wanted to determine if it could contract with customers for enough curtailment of load served from the Belmont substation to defer this investment. The utility set up the pilot in summer 2002 learn whether this approach could work and could be expanded to other areas, and specifically to learn:

1. whether the utility could acquire enough curtailable load from the target area's larger customers, to minimize transaction costs by dealing with fewer customers
2. whether customers would agree to curtail in the event of a multi-day heat spell, and would offer enough capacity on the later days to meet system reliability requirements
3. what minimum incentive would be needed to acquire the necessary capacity, and whether it would exceed \$.50/kWh
4. what load management measures customers could implement
5. if the pilot succeeded, how the utility could integrate similar programs into its planning criteria for different locations.

The Brockton area substation had a design capacity of 45 megawatts. Mass Electric estimated that its peak load would need to be reduced by 950 kW by summer 2002. The quickest and most efficient way to do this was to work with larger customers, whose loads exceeded 200 KW. The substation served 25 such customers, of which 10 voluntarily agreed to participate in the program. They offered a potential load reduction estimated at 650-2,300 kW, based on their load profiles and controls expected to be in place by summer.

The utility conducted energy audits and enrolled participants in its existing DSM programs. Seven customers had energy management systems, and three of those were remotely controllable. The other participants relied on local personnel to control equipment manually. All ten were enrolled in the Northeast ISO Load Response Program and eligible for payments under that program in addition to the Mass Electric incentives.

¹⁹ Source: "Report on the Load Curtailment Pilot Program in Brockton" by Massachusetts Electric Company, October 31, 2002; as submitted to the Massachusetts Department of Telecommunications and Energy.

Mass Electric notified these customers of curtailment events by email, giving them 30 minutes to reduce their load to a pre-determined level, and Internet access to view their facility loads in real time during events. For load curtailed during each event, it paid customers a \$.50/kWh incentive.

The utility decided to call for curtailment when the area substation experienced a 43 MW load for more than 15 minutes, or grew quickly from 43 to 44 MW. It called four events totaling 17 hours during summer 2002, two in July and two in August. Eight customers participated on three days, and seven participated on the fourth day. Their average load reduction ranged from 675–862 KW/hour, and the maximum reductions for all customers ranged from 1,231–2,300 KW/hour.

Mass. Electric achieved its primary goal of keeping the substation load below 45 MW; paid participating customers a total of \$6,454; and considered the pilot a success. Lessons learned included the importance of:

1. planning for diversity of curtailable load, so every customer need not curtail for every day of longer-term events;
2. leveraging participation by allowing customers to take advantage of demand response programs offered by others (here, the New England ISO's program);
3. committing to multi-year customer load response programs, which take longer to implement than installation of utility equipment.

Distinguishing Features of the Orange & Rockland and Mass Electric Examples:

Orange & Rockland:

- Payments to DER providers were based on area-specific analysis of the value of load deferral or curtailment in a specific utility planning region.
- The utility reduced some utility-specific interconnection costs to induce DER providers to site projects where it needed grid support.

Mass Electric:

- This pilot approach was driven by the utility's desire to defer an identified construction project.
- The \$.50/kWh incentive was sufficient to attract customers and easy to understand (no hourly variations or dependence on wholesale market prices).

1.C: Portland General Electric and Madison G&E contract with customers to use their backup generators to enhance grid reliability.

Portland General Program Description: PGE contracts with customers with backup generators to allow the utility to operate the units for up to 400 hours annually. In exchange, PGE will:

upgrade switchgear to permit grid synchronization

install control and communication hardware

assume all maintenance, repair and operation costs (including fuel used during utility interruptions)

provide additional sound attenuation

add more fuel storage capabilities

test the system monthly under full load.

PGE networks the backup generators into its control center so utility operators can dispatch them as part of its system. The utility outsources maintenance and repair, and guarantees a 4-hour response when the generator is not functioning. Customers served by a competitive supplier can opt to participate in the program. In that case PG&E, the customer, and the supplier negotiate an agreement to provide accurate billing and accounting for power used during outages.

Since PGE owns the switchgear, the generator output is considered PGE power. This avoids customer tax liability and FERC jurisdiction over wholesale power sales. Customers must sign a Dispatchable Generation Agreement with early termination penalties.

PGE installs oxidation catalysts on all engine generators in the program to reduce carbon monoxide and hydrocarbon emissions. It is exploring the use of dual-fuel systems that burn natural gas in a diesel engine, displacing 80-90% of the diesel fuel with cleaner natural gas. PGE obtains air permits from the Oregon Department of Environmental Quality for all generators enrolled in the program.

Madison Gas and Electric Program Description: MG&E'S Backup Generation Program is a pilot limited initially to 50 MW of customer load. At a customer's request, MG&E will install and maintain a natural gas or diesel backup generator at the customer's facility. The utility reserves the right to operate the unit to enhance grid reliability or to meet other system requirements. The backup service must equal the facility's highest annual demand. Customers initially pay \$1.48/month/KW for new contracts involving diesels, and \$3.45/month/KW for new gas generators.

Each customer must sign an agreement with Madison G&E wherein they agree to accept service for a term of three years or pay an early termination penalty. The agreement is automatically renewed after the initial three year term, absent written notice from either party. The monthly charge is guaranteed for the initial three year term, after which it reverts to the tariff rate in effect at the time. The customer must provide a suitable location, a concrete mounting pad, all necessary easements and right of ways and necessary permits. Any non-standard features such as noise abatement or landscaping are billed to the customer as contributions in advance of construction.

Distinguishing Features of Portland General Electric and Madison G&E Examples:

PGE:

- The utility dispatches output from customer generators as a utility resource.
- The utility assumes O&M responsibility and non-performance risk for non-utility equipment.

Madison:

- The utility designs, installs and owns backup generators at customer locations.
- The customer charge is determined through the ratemaking process.
- The service is billed on the customer's normal utility bill.
- Customer payments represent value-added service revenues for the utility.

1.D: Green Mountain Power negotiated an agreement with a large customer that requires the customer to curtail load based on grid reliability criteria

Green Mountain Power Program Description:²⁰ Vermont's Sugarbush Resort wanted to increase snowmaking capacity at the ski area by 15 MW. Green Mountain Power (GMP) would have needed to charge Sugarbush \$5 million for the necessary line extension. The utility, the customer and Vermont's Public Advocate formed a collaborative team to explore alternatives, and state regulators later approved the approach they developed.

The collaborative solution had two components:

1. A customer-managed interruptible contract under which Sugarbush ensured that the load would not exceed the distribution line's 30 MW carrying limit, and installed real-time metering and telemetry to read substation loads. Under this arrangement, Sugarbush not only avoids the line extension charge, but receives value for load management in the form of a rate discount for purchased electricity.

²⁰ Based on a report by the Regulatory Assistance Project, "Distributed Resources and Electric System Reliability", 2001, p. 16-18.

2. A concentrated effort by GMP to improve energy efficiency and lower peak demand throughout the entire region. At the Public Advocate's urging, GMP focused some of its demand-side management programs in the area, including among numerous measures converting electric water and space heaters to alternative fuels.

Distinguishing Features of the Green Mountain Power Example:

A single customer would have borne the line extension costs, providing strong motivation to find alternatives.

The customer's interest encouraged participation by the utility and the regulatory and public interest community; participants observed that GMP would have been less likely to participate if upgrade costs were socialized through the tariff, regardless of cost-effectiveness.

Key stakeholders participated in a collaborative process that yielded win-win solutions for all parties.

The curtailment contract requires the customer to take into account the load of other substation customers while managing its own load, engaging it in area load management beyond its own facility.

The program combined the immediate needs of one large customer with a broader, longer-term strategy to reduce system demands in surrounding areas.²¹

2. Bulk power utility focus: Mitigate wholesale prices and transmission congestion.

2.A: Metropolitan Edison and AMP Ohio installed distributed generation to provide peaking wholesale power, transmission reliability, and transmission congestion mitigation.

2.B: Public Service of New Mexico and Commonwealth Edison contract with third party aggregators for access to capacity available from customer-sided generators/loads.

2.C: The Bonneville Power Authority, the New York ISO and Public Service Electric and Gas pay customers to reduce their facility energy demand when requested.

2.A Metropolitan Edison and AMP Ohio installed DG to provide peaking wholesale power, transmission reliability, and transmission congestion mitigation.

Met-Ed Program Description: Metropolitan Edison (First Energy) installed about 100 MW of diesel generators at eight Met-Ed substations in Pennsylvania. The generators were first used in

²¹ A criticism has been that GMP largely abandoned the follow-on DSM work once the reliability challenge was met, suggesting that ground rules for dual-purpose DSM programs must be carefully worked out with regulators or other program advisors.

the summer of 2001 as an alternative to purchasing peak energy from the PJM spot market. This resource has also provided system reliability benefits.

Since summer 2001, Met-Ed has leased the gensets from Cummins Power. They are connected at 19.9 KV to the Met-Ed distribution system and are physically located within the substation fence. Cummins owns the equipment, and has installed a communication network that allows remote dispatch of the units.

In the first year of operations, Met-Ed system operators dispatched the units to mitigate prices when the Locational Marginal Price (LMP) at PJM's local pricing point exceeded \$80/MWh. They also used the generators to provide contingency transmission support when a lightning strike at a nearby 230 KV substation required redistribution of power in the area, until the substation was repaired. The units were dispatched for about 300 hours in summer 2001.

AMP Ohio Program Description: AMP Ohio is a municipal cooperative with a number of municipalities as members. AMP Ohio provides not only generation but transmission services to its members. They have found that off-peak transmission scheduling and delivery rights within their region are available and affordable. They have entered into a combination of long- and short-term fixed price contracts to ensure the deliverability of the power produced by their plants and contract generation they have purchased. They discovered that peak transmission rights for the same power delivery were significantly more expensive than off-peak transmission rights.

AMP Ohio decided to install sixty 1.8 MW diesel generators and use the generators as an alternative to purchasing firm peaking transmission capacity. By using the distributed generation, the cooperative was able to purchase non-firm transmission rights for their peak needs. In times when transmission constraints existed in the grid, AMP Ohio dispatchers call on the DG units until the transmission constraints are mitigated and non-firm transmission becomes available. The DG has been dispatched from 100-500 hours annually to meet this need.

Distinguishing Features of the Met-Ed and AMP Ohio Examples:

Met-Ed:

The DER provider owns the equipment, and dispatches it based on LMP prices or utility requests. The equipment is used for multiple purposes, including peak power supply, local congestion mitigation, and local grid reliability enhancement.

Amp Ohio:

A municipal cooperative uses DG assets to reduce peak transmission costs for its members. DG serves as an alternative to buying fixed price, firm peaking transmission services.

2.B: Public Service of New Mexico and Commonwealth Edison contract with third-party aggregators for capacity from customer-sited generators and/or loads.

PNM Program Description: Fifteen customers (mainly municipal and government agencies) have signed contracts with energy management company Celerity Energy, allowing Celerity to

dispatch their backup generators for up to 400 hours a year (two starts per day maximum, up to eight hours). Celerity aggregates the capacity from these generators and sells it to Public Service of New Mexico (PNM) under a contract that includes capacity and energy components. In return, Celerity agrees to:

- provide free generator maintenance
- upgrade equipment where necessary
- guarantee generator performance

Gen-sets in the program range from 400-2000 kW each. The network's total capacity is about 25 MW, with potential to increase to 75 MW in the future.

Celerity is responsible to maintain the generators and manage their day-to-day operation. All the gen-sets are linked with a communication platform supplied by Sixth Dimension. On notification from PNM, Celerity can dispatch some or all of them from a central control station. FERC has granted the network Exempt Wholesale Generator status, allowing its output to be sold into the wholesale market.

The State of New Mexico has issued each gen-set a permit to operate in peak power mode. Depending on its size, age and air emissions profile, each unit is permitted to run for a specified number of hours annually; most can operate up to 400 hours. Celerity has worked with local air permitting agencies to increase the dispatchable hours, by introducing new technologies to reduce NOx and CO emissions from older diesel gen-sets. Dual-fuel technologies to inject natural gas into the diesel cycle during combustion have been investigated, and pilot applications started.

Celerity manages the installation of synchronous controls and other equipment required for remote monitoring and dispatch. It subcontracts installation, maintenance, and environmental permitting to a number of project partners. Celerity serves as the business developer, chief customer liaison and overall program manager.

ComEd Program Description: Commonwealth Edison (Exelon) has experienced system reliability problems in the Chicago metropolitan area during the last few years. The company agreed with the State of Illinois to examine creative alternatives to reduce system loads during peak summer hours to improve reliability, and to increase investment in community initiatives promoting energy efficiency and renewables.

ComEd and Electric City (a private developer and integrator of energy savings technologies and building automation systems) have contracted for ComEd to pay Electric City an agreed capacity and energy payment for up to 50 MW of demand reduction that Electric City will aggregate from ComEd customers.

Electric City has or will enter into agreements with individual customers, Illinois state agencies and municipalities (including Chicago suburbs Elk Grove, Leydon Township, Franklin Park and River Grove), to install free electronic ballasts, daylight controls and fluorescent dimming devices in customer facilities. In exchange, those customers will allow Electric City to reduce lighting levels or activate demand-limiting strategies during peak summer pricing hours.

Electric City will aggregate total demand reduction as a Virtual 'Negawatt' Power Plant (VNPP). It will sell VNPP capacity to ComEd, which will pay for the opportunity to reduce its peak purchases using this 'negacapacity'. ComEd can remotely control customer lighting systems over a secure network, and can dispatch them at times and for durations of its choosing.

Electric City has signed a long-term supply contract with ComEd, enabling it to secure favorable debt and equity financing to fund development of its virtual network of demand resources. The entire system is expected to cost about \$25 million, and to incorporate about 1,500 systems at various customer sites.

Distinguishing Features of PNM and ComEd examples:

PNM:

- Third-party DER aggregator is responsible to develop customer contracts and assemble supply.
- Aggregator works to reduce environmental impacts of backup generators.

ComEd:

- Utility contracts with a DER aggregator for demand reduction based on prevailing wholesale prices.
- The DER aggregator uses the utility contract as collateral to obtain favorable financing for a multi-million dollar project.
- The 50 MW demand resource is large enough make it a tradable block in wholesale markets.

2.C: The Bonneville Power Authority, the New York ISO and New Jersey's Public Service Electric and Gas pay customers to reduce their facility energy demand on request.

BPA Program Description: Growing pressure from environmental groups has lead to increased scrutiny for the Bonneville Power Administration's (BPA) transmission construction projects. BPA wanted to know whether demand resources could offer viable alternatives, so it established the Demand Exchange Pilot Program to learn more about using demand reduction to relieve transmission line loading during peak events. Program objectives include:

- determining the price that participants expect to receive to operate onsite generation or reduce their demand
- assessing the regulatory trend toward viewing demand resources as equal to generating or transmission resources for meeting capacity needs

Although the Demand Exchange Program can be widely applied, the pilot program is targeted to the Olympic Peninsula, a winter-peaking region where extremely cold weather typically triggers the need for additional resources.

BPA's pilot program represents a market-based approach that enables participants to bid available onsite generation or demand resources. The Demand Exchange system notifies participants 24 hours in advance of an event requiring demand response, and provides a bid price that BPA will pay participants to curtail load or provide generation. If the price meets their needs, participants can elect to bid into the system. The process is iterative, so BPA can raise its offering price if it does not bring forth sufficient resources. Participants must be able to shed or generate at least 1 MW of resources, and may aggregate their resources to meet this minimum.

The program is voluntary. Participants are not required to reduce their load or operate their onsite generation when demand response is requested. However, when they pledge to participate during an event, their pledge represents a firm commitment of resources to BPA.

BPA budgeted \$150,000 for this pilot program, exclusive of staff time. It expected that about \$50,000 would be needed to establish the Demand Exchange platform, \$7,000 to establish individual participant accounts, and the remainder to purchase demand resources. The agency is in the recruiting stage, actively signing up participants to use the Demand Exchange platform during the winter of 2003-2004. Pilot program results should be available after this winter peak season.

New York ISO Program Description: The New York Independent System Operator (ISO) sponsors a similar demand response program, as does PJM and the New England ISO. The programs generally have both emergency and economic components. The emergency programs pay a higher value for reductions (e.g., the higher of \$500/mWh or LMP) than the economic programs. The ISO will trigger an emergency program when a system emergency exists, and its control area loads approach maximum available capacity. It will call for economic curtailments by posting the local real-time energy prices and allowing customers to choose how much load they will curtail and for how long. DG (special case resources) can participate in the NY ISO Unforced Capacity Market (UCAP) (formerly the Installed Capacity Market, or ICAP) under certain conditions spelled out in the UCAP Manual. Customers may also use backup generators to participate in the NYISO Demand Response Programs. In the summer of 2002, the New York ISO reported that a total of 1000 MW participated in the State's demand response programs.

PSE&G Program Description: Rapid residential development has occurred in certain areas of New Jersey, increasing electricity demand. Many of these areas have limited commercial or industrial load to enroll in traditional curtailment programs. Looking for least-cost ways to meet the increasing demand, Public Service Electric & Gas (PSE&G) developed a program to install air conditioner load control switches in single family homes in target growth areas.

PSE&G has installed about 100,000 radio-controlled setback thermostats and load control switches on residential air conditioning systems. PSE&G's dispatch center can send radio signals that cause them to cycle on and off for 7-10 minutes at a time when the utility calls a curtailment event. As a result, PSE&G has a diversified load reduction capability of approximately 100 MW that it can use for up to eight hours a day. Customers agree to have their units cycled in

exchange for incentives that may include a new setback thermostat for the home, or a monthly payment of about \$5.00 during the summer season. Most homeowner contracts limit the utility's ability to use the system to about 100 hours per year.

Distinguishing Features of the BPA, ISO and PSE&G Examples:

BPA:

- A wholesale utility initiated the program so retail customers could help solve operational issues.
- The program seeks to relieve winter loads rather than summer loads.
- Unlike programs designed to mitigate peak power prices, this program uses demand response to avoid transmission construction.

NY ISO:

- The program sets a \$500/mWh minimum regardless of market prices.

PSE&G:

- The utility dispatches aggregated load control as a system resource.
- The programs target residential loads, whereas most load response programs target larger commercial or industrial loads.
- Customers have agreed to allow the utility to control their equipment.

3. DER customer focus: broaden energy options and increase onsite reliability

3.A. Gulf Power residential customers may choose a time-of-use pricing plan that entitles the utility to cycle certain appliances during high price periods.

3.B: The New Yorker Hotel installed a cogeneration system and backup generators to supply on-site electricity and hot water, as well as to enhance reliability.

3.C: A shopping mall in eastern Pennsylvania may install a generator to create make-or-buy options for its energy supply

3.A. Gulf Power residential customers may choose a time-of-use pricing plan that entitles the utility to cycle certain appliances during high price periods.

Gulf Power Program Description:²² Gulf Power offers a residential time-of use pricing option to all its customers. Under this rate, energy is billed according to one of four periods in which it is used. The periods (low, medium, high and critical) are communicated to customers via a thermostat that shows which billing period is in effect at any given time. Customers can schedule their use accordingly, or may allow the utility to control their air conditioner, pool pump, or heat pump when prices are in the critical period. They pay \$4.50 per month for this service, and receive a gateway or thermostat connected via pager signals to the utility control center.

The four major elements of the program are –

1. a time-varying rate design with a near-real-time pricing component
2. an in-home, customer-programmed, automated energy management system
3. a way to communicate rate changes, critical peaks and other messages to participants, and
4. a means of recording and retrieving the requisite billing determinants.

Gulf Power has found that the average customer saves nearly 15% by participating in the program, and that participant satisfaction exceeds that of other utility customers. The savings reflect energy actually saved, as well as rate savings due to shifting consumption patterns.

3.B: The New Yorker Hotel installed a cogeneration system and backup generators to supply on-site electricity and hot water, as well as to enhance reliability.

The New Yorker Hotel Description: This New York City hotel decided to install a 600 kW cogeneration system and two 350 KW backup diesel generators as part of a major renovation. A turnkey project by Hess Microgen, four packaged natural gas-fired units serve a significant portion of the building's electrical needs and thermal loads. Their waste heat provides domestic hot water and preheating for the hotel's space heating boiler.

The units run on a 21-hour daily schedule. In winter, they provide 80% of the hotel's electric needs and 90% of its hot water, and in summer, 50% and 90%, respectively. The cogeneration system could not be used as a synchronous generator due to limitations of Con-Ed's New York network grid, so the hotel installed two backup generators for additional reliability in case of a

²² Information for this summary is taken partially from a presentation to NYSERDA by Dan Merilatt, VP Marketing Services, GoodCents Solutions, Inc., October 3, 2002.

power outage. The system was installed in the hotel's sub-basement 50 feet below street level to meet customer requirements.

The DER provider designed, installed, owns, operates and maintains the system while guaranteeing \$150,000 annual energy savings for the hotel.

3.C: A shopping mall in eastern Pennsylvania may install a generator to create make-or-buy options for its energy supply

The Shopping Mall Description: A large regional mall in eastern Pennsylvania receives HVAC services and electricity from a central power plant located on mall property. A new owner of the power plant will be installing load management hardware to aggregate individual store demand response, and on-site generators to serve the mall's electric needs, or may choose to buy electricity from one of the state's competitive suppliers.

The value of the on-site generator will be driven by the difference in the market price between a fixed-price, all-requirements contract, and an hourly LMP-based contract for the mall. Competitive suppliers offering fixed price contracts take on the risk of supplying power in the summer when wholesale prices may rise unpredictably based on extreme weather or generating or transmission outages. They add a risk premium to cover these contingencies. By installing an on-site generator, customers can effectively provide a hard asset price hedge or risk mitigation tool.

The mall will purchase an hourly-priced product from a supplier that will fluctuate according to variations within PJM market prices at selected hubs. As long as the price stays below a predetermined strike price of \$90/mWh, the mall will buy electricity from the grid. When the local LMP exceeds the strike price, the mall operator will turn on the generators and run them until prices retreat below the strike price.

Distinguishing Features of the Gulf Power, New Yorker and Pennsylvania Mall Examples:

Gulf Power:

- Residential customers have access to a program that lets them control their bills by scheduling their electric usage.
- The utility has positioned the rate as a service offering, with enabling technology that it provides for a fee – possibly an attractive approach for other utilities.

New Yorker Hotel:

- The cogeneration system was installed in New York City, one of the most difficult areas to site local generation.
- The DER provider owns and operates the facility while guaranteeing the host energy savings.

The Mall:

- DG becomes a tool in the customer's energy procurement strategy.
- The value of DER in the wholesale market is much higher than the sum of the avoided hourly purchases of a demand response strategy.

4. Regulatory and societal focus: Increase energy efficiency and improve environmental quality.

- 4.A. New York, California and Texas offer incentives to customers that install clean, efficient and/or renewable energy equipment.
- 4.B. New Jersey requires competitive suppliers in the State to provide a small percentage of distributed solar power in their supply portfolio.

4.A: New York, California, and Texas offer incentives to customers that install clean, efficient and/or renewable energy equipment.

New York Program Descriptions: New York utilities collect from their customers in rates about \$150 million a year in 'system benefit charges' (SBC). These funds are administered by the New York State Energy Research and Development Authority (NYSERDA), which offer incentives to utility customers to install energy efficient equipment, cogeneration systems, and renewable technologies.

As of 2003, NYSERDA has committed \$27 million for 57 CHP projects, \$800,000 for 13 feasibility studies, and \$4 million for 11 projects to develop DG technologies. With co-funding, these projects represent about \$100 million investment in DG/CHP. NYSERDA also offers a peak load reduction program incentive that pays 70% of the costs of installing interval meters; at least 37,000 such meters have been installed in 300 multifamily buildings.

NYSERDA targets \$14 million a year of SBC funding to renewables, with much of that dedicated to large-scale wind development. Eligible customers are New York electric distribution customers of the State's six investor-owned utilities. This funding also targets distributed PV, with most of the funding awarded through competitive RFPs issued as new programs are developed. Program examples follow:

- *New Construction* – \$3 million of Energy Smart New Construction funds are targeted to building-integrated PV. New York's Energy Smart Loan Fund also provides interest rate reductions of 4.5% for up to five years on loans for energy efficiency projects and renewable technologies.
- *Consumer PV incentives* – \$2.5 million PV Incentive Program, until December 2005, provides \$4-5.00/watt, up to 70% of total system cost, for projects up to 15 kW.
- *Larger PV systems* – \$3 million program provides \$5.00/watt, up to \$500,000 per site. Eligible buildings are those in SBC utilities' territory or public buildings in municipal utility areas.

- *PV System and Energy Star® Home Demonstration Project* – NYSERDA is working with the National Association of Home Builders and Steven Winters Associates to develop and implement a demonstration program and awareness campaign to inform builders, realtors, appraisers, bankers, consumers, and building code officials about the benefits of Energy Star homes and grid-connected PV systems for homes, and to provide incentives for both. Grid-connected PV incentives are up to \$20,000 or 100% of system costs on model homes, and 60-75% for additional PV systems in a subdivision.

Long Island Power Authority

Since LIPA is a public entity, its customers are not eligible for NYSERDA-sponsored programs, but LIPA itself has committed \$32 million to develop clean energy alternatives. Part of this commitment is its Solar Pioneer Program, a five-year initiative offering rebates of \$5 per watt (up to \$60,000). Maximum eligible system size is 10 kW. Six percent loan financing is also available.

California Program Descriptions: California offers two direct financial incentive programs to support DER deployment. One, for small renewable resources, is administered by the California Energy Commission (CEC). The other, for some larger technologies including both renewable and non-renewable resources, is administered by California's investor-owned utilities²³ under a legislative mandate interpreted by the CPUC. Both programs are summarized below.

CEC Emerging Renewables Program

The CEC began administering the Emerging Renewables Buy-Down Program (ERBP) in 1998. The ERBP provided cash rebates equal to the lesser of \$4,500/kW or 50% of system costs, for customers of all classes in IOU service areas who installed eligible renewable generating systems. Through 2002, the ERBP helped fund over 3,800 new installations, most of them solar photovoltaic.

Early in 2003, the CEC renamed this program the Emerging Renewables Program (ERP), and modified some of its eligibility criteria. Eligible technologies now include:

- solar PV
- solar thermal electric systems
- wind turbines up to 50 kW
- fuel cells operating on renewable fuels (digester gas, landfill gas, etc.)²⁴

²³ In SDG&E's territory, the program is administered by the nonprofit San Diego Regional Energy Office, to provide a basis for comparing utility and non-utility program administration.

²⁴ Other technologies may be added to this list by petitioning the CEC and demonstrating that they meet specified criteria (e.g., need for funding to become commercially viable; new generating process; commercially available; demonstrated; warranted for 5 years; 20-year useful life, etc.)

To qualify for the CEC's ERP rebates, systems must be new, non-utility owned systems connected to investor-owned utility distribution facilities. They must be sized primarily to offset the customer's electricity needs at the site, producing no more than 200% of the site's needs; have at least a five-year warranty; and install meters that measure total energy output.²⁵

The ERP program reduces the rebate levels offered under the earlier ERBP, both initially and over time:

Table 4. CEC Emerging Renewables Program Rebates²⁶

Technology	Size	Initial Rebate Level ^a
PV Solar thermal electric Fuel cells using renewable fuel ^b	<30 kW	\$4.00 per watt
	≥ 30 kW	Future performance incentive
Wind	First 7.5 kW	\$2.50 per watt
	>7.5 kW up to 30 kW	\$1.50 per watt
	≥ 30 kW up to 50 kW	Future performance incentive

^a. 15% less for owner-installed systems. All rebate levels will be reduced by 20¢ per watt every six months beginning July 1, 2003, and every January 1st and July 1st thereafter.

^b. Fuel cells using non-renewable fuels for CHP applications may be eligible for rebates later, when funds from other sources are no longer available.

CPUC Self-Generation Incentives Program

Complementing this CEC program, California IOUs administer a separate *Self-Generation Incentive Program* (SGIP) that provides similar financial incentives for these and other DG technologies installed on the customer side of the meter and serving part or all of the customer's load. The CPUC established this program in March 2001,²⁷ and has since modified some of its original eligibility requirements.²⁸ The SGIP initially was authorized for a four-year period running through 2004, but was recently extended through 2007.²⁹ Its features are summarized in the following table:³⁰

²⁵ For detailed requirements, see the CEC's *Emerging Renewables Program Guidebook* adopted February 19, 2003, pp. 4-7; available at <http://www.consumerenergycenter.org/erprebate/forms.html>. Additional requirements apply, and higher rebates are available to, affordable housing projects; see *Guidebook* p.21-22. Practically speaking, another important limitation is that funds remain in the CEC's Emerging Renewable Resources Account in a given year.

²⁶ *Id.*, pp. 8-9.

²⁷ D. 01-07-073 (3/27/01), implementing the legislative mandate of AB 970.

²⁸ D. 02-09-051 (9/26/02).

²⁹ California Assembly Bill 1685, signed by Governor Davis September 12, 2003 and added to the California Public Utilities Code as §379.6. The new law also added more stringent NOx reduction and efficiency requirements for fossil-fueled generators, and provided certain NOx credits based on heat recovery for CHP projects.

³⁰ For program details, see e.g., *PG&E Self-Generation Incentive Program Handbook (1/18/03 rev.3)*, and *Interim Handbook Changes (8/23/03)* at http://www.pge.com/suppliers_purchasing/new_generator/incentive/index.html.

Table 5. CPUC / IOU Self-Generation Incentive Program Rebates

ELIGIBLE TECHNOLOGIES	Minimum System Size	Maximum System Size^a	Max. % of Project Cost	\$/kW Incentive
Level 1 <ul style="list-style-type: none"> • Photovoltaics • Fuel cells operating on renewable fuel • Wind turbines 	30 kW	1.5 MW	50%	\$4,500
Level 2 <ul style="list-style-type: none"> • Fuel cells on non-renewable fuel^b 	none	1.5 MW	40%	\$2,500
Level 3-R <ul style="list-style-type: none"> • Microturbines on renewable fuel^c • Internal combustion engines and small gas turbines on renewable fuel^c 	none	1.5 MW	40%	\$1,500
Level 3-N <ul style="list-style-type: none"> • Microturbines on non-renewable fuel^{b, d} • Internal combustion engines and small gas turbines on non-renewable fuel^{b, d} 	none	1.5 MW	30%	\$1,000

^a CPUC caps maximum incentive payout at 1 MW, not 1.5 MW.

^b Must utilize waste heat recovery per Cal. Pub. Util. Code §218.5 (similar to PURPA standard).

^c Must meet CPUC renewable fuel criteria.

^d Must meet CPUC reliability criteria – i.e., generator must operate between 0.95 power factor lagging and 0.90 leading, and facilities over 200 kW must coordinate planned maintenance with the utility.

As of October 2003, California's Self-Generation Incentive Program had paid out about \$38 million in incentives, resulting in about 27 MW of completed projects. Another \$178 million in incentives had been requested for active projects totaling about 136 MW. Of the projects completed, some 69% were Level 3 installations (microturbines, IC engines and small gas turbines); 30% were Level 1 photovoltaics and wind; and less than 1% were Level 2 fuel cells. Of the 136 MW of active projects, about 65% are Level 1 technologies; 33% are Level 3

technologies; and about 2% are Level 2 fuel cells.³¹ Although the program started somewhat slowly, the pace of applications has picked up considerably in 2002-2003.

Texas Program Description: Texas has recently faced significant issues of demand growth and air quality. Although electricity restructuring stimulated more than enough merchant generation, the state lacks transmission capacity in some load pockets, and faces nonattainment issues in large metropolitan areas. De-laminating vertically integrated utilities removed some of their incentives to encourage load management as a means of controlling load growth, particularly in urban areas.

As part of its responsibility to ensure that energy supplies are adequate and cost-effective, the Texas Public Utility Commission promulgated rules³² requiring electric utilities to administer energy savings incentive programs. The programs' goals were to acquire cost-effective energy efficiency savings³³ totaling at least 10% of the utility's annual demand growth by January 1, 2004, and each year thereafter.

Under the program, energy efficiency service providers (EESPs) will contract with the local distribution company to deliver targeted load reduction when requested. EESPs may be local or national energy service companies, retail electricity providers, or individual customers – but not Texas distribution utilities, which generally are barred from providing competitive services, including efficiency services.

Eligible efficiency measures include those that place electricity-consuming equipment under the dispatch control of the EESP, an ISO, or another transmission organization. Load reduction must be available within one hour after utility notification, and measured through time-of-use metering.

Project sponsors apply to the local utility administrator with a plan that identifies project sites, proposed demand reduction, estimated incentive payments, and measurement and verification procedures. Approval of the initial application reserves funding for the minimum load reduction requested. Payments are made after auditing the project's demand reductions.

Utilities pay EESPs through 10-year standard offer contracts for KW and kWh avoided at peak, with payments capped at the theoretical avoided cost of a gas turbine. For 2003, capacity payments have been set at \$78.50/KW/year, and energy payments at \$.0268/kWh. Utilities can recover these incentive payments and their administrative costs through their distribution tariffs.

³¹ These numbers are derived from a presentation given by CPUC staff at PG&E's October 17, 2003 Self-Generation Workshop.

³² Texas Administrative Code, Tit. 16, Part II, Chapter 25. §25.181; effective January 1, 2003.

³³ Projects using self-generation or cogeneration equipment are not eligible for incentives, except for 'renewable DSM technologies' – i.e., customer-sited equipment that uses a renewable resource to reduce net kWh and/or kW purchases. Id., §§25.181(i)(6)(D), (c)(28), (j)(2)(M).

Distinguishing features of the New York, California, and Texas examples:

New York:

- An independent state agency (NYSERDA) administers the incentive program, avoiding the appearance of conflict that sometimes arises when utilities are asked to administer such programs.
- The incentive program specifically recognizes the efficiency value of CHP projects.

California:

- The CEC-administered emerging renewables buydown (rebate) program has stimulated substantial increased market activity for small PV systems.
- The CPUC-directed self-generation incentive program, targeted to reduce peak demand,, offers tiered incentives for customer-side distributed generation, with significantly higher payments for cleaner, more efficient technologies.
- Although the utility-administered self-generation incentive program started slowly it has gained momentum, resulting so far in about 27 MW of self-generation (mostly microturbines, IC engines and small gas turbines), with an additional 136 MW in progress and more expected now that the program has been extended through 2007.

Texas:

- The PUC sets the value of deferred demand and the maximum contract term, so EESPs can determine project economics more transparently than through a multi-step RFP process.
- Distribution utilities cannot participate in demand response or renewable DG projects.

4.B. *New Jersey requires competitive suppliers in the State to provide a small percentage of distributed solar power in their supply portfolio.*

New Jersey Program Description: New Jersey opened its electricity market to competition in 1999. Competitive suppliers have not offered lower energy prices than the utilities' default tariffs, so consumer shopping has been limited. In order to facilitate competitive markets, the New Jersey Board of Public Utilities (BPU) has required all utilities in the state to serve their default loads with energy and capacity purchased through a competitive bidding process called the Basic Generation Service (BGS) auction.

BGS auction winners must furnish a percentage of the power they provide to customers from renewable energy sources, under New Jersey's Renewable Portfolio Standard (RPS). BPU RPS rules define Class One and Class Two renewables and the percentage of each that must be furnished. The BPU has proposed changes recommended by the Governor's Renewable Energy Task Force that would increase the Class One and Class Two requirements, and would require competitive suppliers in the state to provide a small percentage of *distributed* solar power in their supply portfolio. Suppliers can either purchase renewable energy credits (REC) from solar PV projects, or make Alternative Compliance Payments (ACP). To encourage REC purchases, the BPU will administratively set the ACP amounts at a premium over the price of solar RECs in the marketplace.

The proposed rule was published in the New Jersey Register on October 6, 2003, and is expected to take effect around January 2004, before the next BGS auction round scheduled for February 2004. Suppliers will need to purchase solar RECs to cover their obligations for the first program year (June 1, 2004-May 31, 2005). The BPU is also proposing rule changes to further simplify interconnection, and to increase the net metering limit from 100 kW to two MW.

Distinguishing features of the New Jersey example:

- Most RPS programs do not provide incentives specifically for DER. The least-cost renewable resources used to meet RPS requirements are usually wind or landfill gas, often located far from customer loads. New Jersey's solar REC program will create a market for distributed solar as well.
- Solar RECs will be available for projects located at customer facilities, permitting recognition of DER retail value as well as REC value for the RPS market.
- Increased size limits for net metered systems will enable larger seasonal users (e.g. schools) to recognize PV's retail value of even if their facility loads are not consistent across the year.

* * *

2

DER COSTS, BENEFITS, AND ALLOCATION ISSUES

This chapter provides analysis to identify potential win-win distributed energy resources (DER) projects. The analysis includes an investigation of the costs and benefits of DER, and a discussion of the allocation issues for developing win-win applications of DER. As part of this work, a cost and benefit model was developed. The model shows costs and benefits by stakeholder and can provide an economic evaluation of the potential incentives. The model can also identify problems that exist in our current rate and regulatory structures that limit win-win DER opportunities with particular focus on California.

The information provided in this chapter is intended for use along with the cost benefit model. Figure 1 below shows the summary output sheet from the model.

Figure 1: Summary Output Sheet from Model

Costs and Benefits				Input Settings	
Units	Levelized \$	Analysis Horizon Years (20 Years Max)			
DER Customer					
Participant Cost Test: Is it worth it to the DER customer to install the DER?					
Annual Electricity Bill Savings	352,547.30	Annual Capital Cost		115,766.11	
Annual Avoided Fuel Savings (Thermal)	141,592.01	DER Maintenance Cost		69,374.77	
Wholesale Energy Sales	-	DER Fuel Cost		330,216.16	
Sales of Renewable Energy Credits	-	Emissions Offset Purchases		9,891.91	
CEC Buydown / CPUC Self-gen Program	32,157.25	Interconnection Study Cost		275.98	
Incentive / Credit from Other Ratepayers	-	Insurance		-	
Incentive from Public Funds / Tax Credit	-	Other Utility Upfront Costs		-	
		Other Utility Operational Costs		-	
Total Benefits	526,296.55	Total Costs		526,524.93	
		Net Benefit			
Utility Shareholders and Other Ratepayers					
RIM Test: How much will the impact be on earnings or rates?					
Avoided Wholesale Energy Purchases	411,693.43	Revenue Reductions Due to DER (a)		352,547.30	
Avoided Generation Capacity	-	System Upgrades		-	
Avoided T&D Capacity	25,488.36	Interconnection Study Cost		275.98	
Customer Payment for Interconnection Study	275.98	Credit to DER Customer (b)		-	
Credit from Public Funds / Tax Incentive (c)	-			-	
Total Benefits	437,658.77	Total Cost		352,623.28	
		Net Benefit			
Combined DER Customer, Shareholders, Other Ratepayers					
Total Resource Cost Test: What is the net tangible benefit that can be reallocated to produce a 'win-win'?					
Sum of DER Customer, Shareholder, and Other Ratepayer Perspectives					
		Net Benefit			
Incremental Societal Value					
Societal Cost Test: What are the additional net intangible benefits?					
Reduced Central Generation Emissions	13,612.35	DER Emissions		60,400.77	
		CEC Buydown / CPUC Self-gen Program (d)		32,157.25	
		Public Funds / Tax Credit to Utility (c)		-	
		Public Funds / Tax Credit to Customer (e)		-	
Additional Benefits	13,612.35	Additional Costs		92,558.02	
		Incremental Societal Net Benefit			
		Net Societal Benefit (TRC+Societal)			
Notes:					
(a) transfer assumes there is no incremental change in rates, otherwise this would appear in RIM test					
(b) transfer assumes the credit leads to a change in rates to non-participants, otherwise this would appear in the societal cost test					
(c) transfer assumes the credit would not increase costs to shareholder or non-participants					
(d) we assume that the CEC / CPUC programs will not increase the level of the current Public Goods Charge					
(e) Net of Standby Charges (if not a DER technology) and Exit Fees					
Wholesale Energy Forecast					
SP15 9/9/2003					
Generation Multiplier		Medium - 3x			
Residual Net Short Position		Medium - 5%			
Generation Capacity Avoided		Zero Cost			
T&D Avoided Cost		Average (50%)			
Customer Characteristics					
Utility		SCE			
Customer Rate		SCE GS-2 Proposed			
DER Type (Qualify for DER Rate?)		Non-DER (Does not qualify)			
Customer Size (kW)		Enter → 1500 kW			
Customer Load Factor		90% Load Factor			
DER Technology Type and Financing					
DER Type		Caterpillar G3516 LE - 800kW w/C			
DER Operation		High Cap - 2 Outages			
DER Financing		10-Years			
Natural Gas Rate (if Nat. Gas)		Cogen Discount Customer			
Diesel Cost (if Diesel)		Industrial			
Interconnection Cost		Medium - \$200			
Customer Payment for interconnection		High - 100%			
Other Inputs					
Rebates		California CPUC			
Emissions Costs		Low			
Attainment Area		Non-Attainment			
REC Credits		None - \$0/MWh			

When a DER project is identified as a winning or cost-effective application, it raises the question "cost-effective for whom?" There are a number of parties that have a stake in the outcome of a DER application: (1) the DER customer, represented in the top left hand box in Figure 1; (2)


utility rate-payers and utility shareholders, represented in the second left hand box in Figure 1; and (3) society, represented in the bottom box in Figure 1. The third box in Figure 1 combines the DER customer and utility (rate payers and shareholders) perspectives to show the total resource value. Each stakeholder faces a different set of costs and benefits, for example, the electricity bill reduction that the DER customer sees as a benefit will show up as a cost of lost revenue from the utility perspective. In Section ___ of this chapter there is a discussion of the stakeholder perspectives, and a list of the costs and benefits incurred for each stakeholder. Detailed descriptions and ranges for the costs and benefits are provided in Sections _ through _ of the chapter.

While there may be DER applications that work for all stakeholders, it is often the case that DER results in a net benefit for one stakeholder, e.g. the DER customer, but at a net loss for another, e.g. the utility or other ratepayers. By including all stakeholders in the economic analysis one can compare the financial impacts of the DER on them and look for ways of reallocating benefits to make the DER cost-effective for everyone, i.e. the win-win design. The flow diagram in ___ illustrates the simplified process for identifying and developing these win-win applications.

First, and the focus of this report, the stakeholders are identified and their costs and benefits of the DER are estimated. The cost and benefit assumptions are entered into the model that calculates the cost effectiveness from each stakeholder perspective. If the evaluation shows the DER to be cost-effective for all stakeholders then this is identified as a winning application and it goes forward to the next stage of implementation. However, if the DER does not work for all stakeholders, but is cost effective from the total resource or societal perspectives, then there exists the potential for reallocating benefits and making the DER work from all stakeholder perspectives. The issue of allocation, i.e. "how to allocate the costs and benefits between stakeholders to get to a win-win design", is addressed in Section ___ of this report and the accompanying model, and is further developed in the net chapter. Possible allocation methods include the use of incentive payments (or locational credits) to DER providers and utility rate design.

If the DER is not cost-effective from the total resource or societal perspective then the next step is to determine how to further leverage the DER value, i.e., look for further value streams that are not recognized using traditional approaches. If there are, then these values are fed back into the evaluation modal.

Figure 2: Process for Identifying and Developing Win-Win DER Applications



STAKEHOLDER PERSPECTIVES

Cost-effective DER applications are identified by calculating their benefit/cost (B/C) ratios. A B/C ratio greater than one indicates that the DER application has benefits greater than its costs, and therefore is potentially cost-effective. Suggesting that an application is "cost-effective" however immediately raises the question, "cost effective to whom?"

There are several stakeholder perspectives from which DER can be considered cost-effective. The following stakeholders are included in the analysis: (1) the DER customer; (2) utility rate-payers (generally defined as non-participating rate-payers); (3) utility shareholders of investor-owned utilities; and (4) society. Rate payers and utility shareholders are grouped together in this analysis.³⁴ A number of cost-effectiveness tests from the stakeholder perspectives are listed below:

- Participant Cost Test (PCT) (Is it worth it to the customer to install the DER?)

³⁴ Allocation of costs and benefits between the rate payers and shareholder would be determined in a rate case.

- Rate-payer Impact Measure (RIM) (What is the impact of the DER on utility earnings or rates?)
- Total Resource Cost Test (TRC) (What is the net tangible benefit that can be reallocated to produce a win-win solution?)
- Societal Cost Test (SCT) (What are the additional societal costs and benefits including externalities?)

These perspectives are further classified by: (1) definition of the utility (e.g., Vertical Integrated Utility, Transmission Company, Distribution Company, Energy Service Provider, etc.); and (2) DER ownership (i.e., utility, customer, or third party).

The purpose of including all perspectives is to find solutions that are cost-effective or “winners” for all stakeholders. Looking at all perspectives also aids in program design. For example, one of the allocation methods that can be used is an incentive (or locational credit) paid by the utility to the provider of the DER. This would translate as a cost to the utility and a benefit to the DER provider. A win-win program design is one that would set the incentive level payment such that both the utility’s rate-payers and the program participant are better off, i.e., the RIM and Participant B/C ratios are both greater than one. If such a balance can be found, this is a measure that warrants further investigation.

However, there are competing views of the appropriate criterion for cost-effectiveness. The principal debate is between the Rate-payer Impact Measure (RIM) and the Total Resource Cost test (TRC). RIM measures the incremental effect on the utility’s rates of the DER measure. The TRC test measures the net benefit of the DER from the perspective of both the DER customer and the utility’s non-participating rate-payers/shareholders (regardless of who pays costs, or receives benefits). While a DER measure that passes TRC but not RIM could increase the utility’s rates, there exists the potential for additional coordination to successfully implement the alternative. For example, the additional costs could be funded through existing or new public benefits charges, rates could increase, or utility return could decrease.

The Societal Cost Test includes an evaluation of environmental externalities and other “intangible” benefits. Even if the result of the TRC test is a net cost to the stakeholders, these other societal benefits could exceed the shortfall (the net cost from the TRC perspective).

Cost-Effectiveness Tests

Participant Cost Test

The participant cost test measures the life-cycle net benefits for the customer that installs the DER. This cost test is a good indicator of how acceptable a measure or program will be to individual customers.

Rate-payer Impact Measure (RIM)

This benefit/cost test measures the impacts on the utility’s rates. The benefits included are: the capacity cost savings from the deferral of wires investments and changes in O&M costs; avoided

energy purchases; increased system reliability and other transmission and distribution (T&D) system benefits.

The costs included are the incentive payments paid by the utility to the providers of the DER, utility administrative costs, and lost revenues due to reduced sales. If the program benefit/cost ratio is less than one, this program would tend to increase the per unit rates that the utility would charge to collect its revenue requirement. Measures that have a high reduction in sales relative to peak load reductions, such as conservation, are generally not cost-effective from the RIM perspective.

Total Resource Cost Test (TRC)

The TRC test measures the costs and benefits from a broader perspective and includes all of the direct cash costs associated with the DER measure. The benefits include the avoided costs of transmission, distribution, generation capacity and energy, including losses. The costs include the lifecycle costs of the measure, O&M costs, program administrative costs, and interconnection costs. Transfers such as incentive payments between the utility and its customers, as well as bill savings, are not included from this perspective since the net cost of transfers between the utility and customers is zero.

Societal Cost Test

The societal cost test includes the broadest set of costs and benefits. In addition to the direct cash costs accounted for in the TRC test, any environmental externalities such as reduced air emissions are included as a benefit.

Cost and Benefit Tables

The cost and benefit components for DER from each perspective are listed in __ through __. The numbers refer to the section in the chapter where the derivation and ranges of the values are discussed. In some cases, a cost or benefit component appears in more than one table. For example, "reduced utility bills" is a benefit to a customer, and a cost to the utility. In these cases, the component is shown in both places, but is only described once in the report with a reference where appropriate.

The components listed as direct benefits and costs relate to components included in the model. The indirect benefits and costs listed in the tables, and discussed further in this report, identify some of the intangible benefits and costs, but these are not included in the model to date. Each table also includes a line that shows the allocation methods that can be employed to change the level of benefits and/or costs that are attributed to each stakeholder. These allocation mechanisms will be built into the model, making it possible to test different allocation levels and methods to achieve the win-win DER design.

Table 1: Customer Costs and Benefits

	Customer Benefits	Customer Costs
Direct Benefits/ Costs	<ul style="list-style-type: none"> - Annual Electricity Bill Savings - Annual Avoided Fuel Costs (Thermal) - Wholesale Energy Sales - Renewable Energy Credits (Sales of) 	<ul style="list-style-type: none"> - Annual Capital Costs; DER Maintenance; DER Fuel Costs (including siting and permitting if customer-owned project) - Emissions Offset Purchases - Interconnection Study, Equipment, and Electric System Upgrade Costs - Insurance - Other Utility Infrastructure Costs and Operational Costs
Indirect Benefits/ Costs	<ul style="list-style-type: none"> - Customer Reliability 	
Allocation Methods	<ul style="list-style-type: none"> - Incentives/credits from Utility/Public Purpose Fund/Rebate from State or Federal Taxes 	<ul style="list-style-type: none"> - Standby Rates

Table 2: Utility Costs and Benefits

	Utility Wire Co Benefits	Utility Wire Co Costs
Direct Benefits/ Costs	<ul style="list-style-type: none"> - Avoided Wholesale Energy Purchases and Generation Capacity - Avoided T&D Capacity - Customer Payment for Interconnection Costs 	<ul style="list-style-type: none"> - Revenue Reduction Due to DER (ref.) - Interconnection Study and Equipment Costs - Electric System Upgrades
Indirect Benefits/ Costs	<ul style="list-style-type: none"> - System Reliability - Other T&D System Benefits 	<ul style="list-style-type: none"> - System Reliability
Allocation Methods	<ul style="list-style-type: none"> 3.1 - Incentives/credits from Public Purpose Fund 	<ul style="list-style-type: none"> - Incentives/credits to DER Customer

Table 3: Total Resource Costs and Benefits (Combining the utility and DER customer perspectives)

	Total Resource Benefits	Total Resource Costs
Direct Benefits/ Costs	- Avoided Wholesale Energy and Capacity Purchase - Avoided Fuel Costs - T&D Avoided Costs - Increased Reliability	- DER Capital Costs, Maintenance and Fuel Costs - Interconnection Study, Equipment, and Electric System Upgrade Costs - Other Utility Infrastructure Costs and Operational Costs
Indirect Benefits/ Costs	Not Applicable	Not Applicable
Allocation Methods	Not Applicable	Not Applicable

Table 4: Society Costs & Benefits

	Societal Benefits	Societal Costs
Direct Benefits/ Costs	Total Resource Benefits - Reduced Central Generation Emissions	Total Resource Costs - DER Emissions (depending on DER technology)
Indirect Benefits/ Costs	- Reduced CO2 Emissions from Central Generation	- CO2 Emissions from DER
Allocation Methods		3.1- Incentive from Public Purpose Fund/State Rebate/Federal Taxes (to customer and/or utility)

ALLOCATION ISSUES

Incentives/Locational Credits

Use current applicable Combined Heat and Power (CHP), fuel cell, and solar incentives for California in the analysis for these technologies. Incentives from the utility to make societal DER benefits cost effective for both utility and customer will be designed in the collaborative DER programs.

Incentives/credits are a key benefit to DER customers, and are often required to make the project economically viable. However, these incentives can also represent a cost to the utility rate-payers or to society depending upon who provides the incentive value. In California, there are numerous existing incentive and rebate programs that apply to DER customers. In most cases, these incentives are only available to customers who have installed renewable energy technologies. Utilities, on the other hand, can provide monetary incentives/credits to DER

customers through a tariff structure, a competitive request for proposals, or a bilateral contract for generation services. The design and application of utility tariffs will be explored in detail in the collaborative DER program development.

There are two funding alternatives for the incentives/credits:

1. An incremental charge that could result in a change to rates or shareholder earnings and therefore is included in the RIM test. This could be either a utility program that gives locational credits to DER customers, or a pass through of costs to rate payers from a regulatory mandated program.
2. A transfer from public funds or tax revenue that will not impact end-use rates or shareholder earnings. This is classified as a societal cost, because the funds that are used for the DER incentives/credits are no longer available for other programs.

For some time now, the California Energy Commission (CEC) has offered the *Emerging Renewables Buy-Down Program*. This program is rate payer funded through the Public Purpose Program and provides cash rebates of \$4,500 per kW or 50% of system costs (whichever is less) for customers of all classes in investor-owned utility (IOU) service areas who install eligible renewable generating systems. This is defined as a societal cost in the model because it is assumed that the level of the Public Purpose Charge does not increase to fund the Buy-Down Program. Therefore, there is no incremental impact on rate-payers, but the funds allocated to the Buy-Down program are not available for other purposes. Eligible systems include the following, so long as they are grid-connected, operate in parallel, and produce no more than 200% of the site's electricity needs:³⁵

- solar photovoltaics (PV)
- solar thermal electric systems
- wind turbines up to 10 kW, or
- fuel cells operating on renewable fuels (digester gas, landfill gas etc.)

Complementing this CEC program, California IOUs administer a separate *Self-Generation Incentive Program* (SGIP) that provides similar financial incentives for these and other DER technologies installed on the customer side. _____ identifies the levels of these incentives.

³⁵ Size limitations are described in the CEC's *Emerging Renewable Resources Account Guidebook, Vol 3., 9th Ed.* (September 25, 2002, at pp. 13 *et seq*; available at <http://www.energy.ca.gov/renewables/documents/index.html#greengrid>) The *Guidebook* (p.6) indicates an effort to coordinate the size of projects eligible under the CEC program with those available under IOU-administered self-generation incentive programs, and CEC staff has advised us that a new version of the handbook due out shortly will contain an explicit maximum limit of 30 kW per project, corresponding to the lower limit of IOU-administered programs for the same resources. Practically speaking, another important limitation is that funds remain in the CEC's Emerging Renewable Resources Account in a given year.

Table 5: California IOU Self-Generation Incentive Program

Eligible Technologies	Incentive Offered (\$/kW)	Maximum % of Project Cost	Minimum System Size	Maximum System Size ¹
Level 1 Photovoltaics Fuel cells operating on renewable fuel Wind turbines	\$4,500	50%	30 kW	1.5 MW
Level 2 Fuel cells operating on non-renewable fuel ²	\$2,500	40%	none	1.5 MW
Level 3-R Microturbines operating on renewable fuel Internal combustion engines and small gas turbines operating on renewable fuel	\$1,500	40%	none	1.5 MW
Level 3-N Microturbines operating on non-renewable fuel ^{2,3} Internal combustion engines and small gas turbines operating on non-renewable fuel ^{2,3}	\$1,000	30%	none	1.5 MW

1. CPUC caps maximum *incentive payout* at 1 MW, not 1.5 MW.

2. System must utilize waste heat recovery per Cal. Pub. Util. Code 218.5 (similar to PURPA standard)

3. System must meet CPUC reliability criteria – i.e., generator must operate between 0.95 power factor lagging and 0.90 leading, and facilities over 200 kW must coordinate planned maintenance with the utility.

The California Public Utilities Commission (CPUC) established the SGIP in March 2001,³⁶ and recently modified some of its original eligibility requirements.³⁷ The SGIP is currently authorized for a four-year period, running only through 2004. The program could be extended, but has not yet been. It is not clear how the SGIP will be funded, it may be through the Public Purpose Program or an incremental utility charge. The SGIP is currently treated as a societal cost, which assumes that it will be funded through the current level of Public Purpose funds. This assumption can be altered when the source of funding is clarified.

Utility Rates

Use standby and other utility charges applicable to California Investor-Owned Utilities (PG&E, SCE, and SDG&E)

Evaluate two scenarios on equipment outage, one where equipment has failures on peak to drive demand charge, one where equipment is always available on peak

Utilities impose standby rates on customers that require the utility to provide back-up power when their on-site generation or third-party supply is non-operational. The more firm³⁸ the

³⁶ D. 01-07-073 (3/27/01), implementing the legislative mandate of AB 970.

³⁷ D. 02-09-051 (9/26/02)

³⁸ Firm service refers to the customer having a reasonable expectation of the utility being able to meet their energy usage 100% of the time, allowing for infrequent outages for facility failures (car pole incidents, lightning strikes etc). Nonfirm service is a

standby requirements, the higher the standby charges. The justification used by utilities for imposing this special rate is that the cost to provide firm standby service is significantly different from the cost to provide service to other customers. Specifically, firm standby service has a high demand for capacity, but little energy usage. The infrequent usage also leads to difficulties in determining the amount of peak capacity that might be required for shared facilities, such as transmission. Customers do have the option to provide their own reliability through the construction of redundant facilities, and disconnect from the grid to avoid standby charges. Standalone power, however, is rarely a cost-effective option, and could be subject to exit fees (discussed below).

Standard practice was to charge customers with DER standby charges in addition to their otherwise applicable tariff. The standby charge is typically based on a "reserved" or ratcheted amount of capacity, although some are usage-based. To avoid double counting demand when a customer actually requires standby power, the standby usage is typically subtracted from the billing demand under the otherwise applicable tariff.

Standby charges can vary by voltage level, with the highest charges at the distribution voltage level. The reason for the higher charges at the lower voltage level is twofold: 1) the lower delivery voltage implies that relatively more utility infrastructure is required to support that customer; and 2) at lower voltages, the distribution equipment becomes more "dedicated" to the customer, so the distribution capacity cost reduction from a customer installing on-site generation is lower.

Typical standby charges are shown below in _____. Note that residential and small commercial customers that qualify for net metering can typically avoid any standby charges. The net metering qualifying customers are typically renewable resource projects such as small solar photovoltaic projects.

lower level of reliability provided to customers in exchange for lower rates. The concept is that utilities will not have to build facilities to meet the peak demands of nonfirm customers, and those savings are passed to those customers through rate discounts or incentive payments. To the extent that standby customers were to elect nonfirm standby service, the cost of that service would be significantly lower (possibly zero) than firm standby service.

Table 6: Supplemental Standby Rates

Utility Rate	Distribution	Primary	Transmission	Charge Type
SCE	6.77 \$/kW-mo	6.96\$/kW-mo	1.00\$/kW-mo	
SDG&E	3.24\$/kW-mo	3.09\$/kW-mo	.27\$/kW-mo	Contract Demand
ConEd	\$3.36 to \$5.88 /kW-mo \$7.59 to \$12.30 \$0.0557 to \$0.2383	\$2.57 to 3.36 \$4.56- \$7.05	\$2.57 to 3.36 \$4.56- \$7.05 \$0.0557 to \$0.2359	\$/kW-mo Contract Demand. \$/kW-mo actual demand (0 in winter) \$/kWh energy charge
Hawaii	11.40			\$/kW-month. 100% annual demand ratchet
Arizona Public Service	Reservation charge of a) \$5.01/kW-mo if >90% cap factor b) \$6.59/kW-mo is 80-90% cap factor, or c) \$12.53.kW-mo plus standby energy of \$0.01006 up to 0.02961/kWh			Contract Capacity
Net Metering	NA	NA	NA	Customer billed under otherwise applicable schedule only

below shows the PG&E and SDG&E standby tariffs that can be applied to a customer's entire load (no need for the otherwise applicable tariff). For PG&E, industrial customers (in excess of 500kW maximum demand) may elect to use supplemental standby power, in which case, the customer's normal usage is billed under the OAS, and only the backup power is billed under the standby rates. For SDG&E the tariffs shown below only apply to qualifying DER facilities.

PG&E and SDG&E take two fundamentally different approaches to the standby customer rate design. PG&E imposes a small reservation charge and high energy charges. The energy charges are significantly higher than the tariff rates for the otherwise applicable rate schedules. For qualifying DER facilities, PG&E waives the reservation charge. SDG&E's Schedule AL-TOU- DER rates are the same as their Schedule AL-TOU rates (non-residential time of use rates). Qualifying DER customers are billed the same as regular AL-TOU customers, with no adjustment for any higher cost of service. Similarly, qualifying residential DER customers pay the same rates as all other residential customers on TOU rates. The authors expect that if DER were to become a significant portion of SDG&E's customer base, then SDG&E would revise its rate design to reflect the cost characteristics of the DER customers.

Table 7: PG&E and SDG&E Standby Tariffs by Service Voltage Level^{39,40}

	PG&E (\$)			SDG&E (AL-TOU-DER)					(DR-TOU-DER)
	S	P	T	S	P	S Sub	P Sub	Trans	Residential
Reservation Charge (\$/kW-mo)**	2.55	2.55	0.35						
Standby charge (\$/kW-mo)				7.04	6.87	1	0.6	0.59	
Max Demand (\$/kW-mo)				11.26	10.85	7.3	6.48	6.43	
Smr				5.14	5.07	1.77	1.53	1.53	
Wtr									
Energy Charges (\$/kWh)									
Smr Peak	0.50598	0.50755	0.49884	0.01589	0.01564	0.01504	0.01458	0.01454	0.10687
Wtr Pk				0.01465	0.01444	0.01396	0.01357	0.01354	0.08419
Smr Ptl	0.16779	0.15945	0.11085	0.01313	0.01298	0.01228	0.01203	0.01200	
Wtr Ptl	0.15422	0.14604	0.12267	0.01299	0.01284	0.01230	0.01205	0.01202	
Smr Off	0.08427	0.08043	0.08145	0.01995	0.01186	0.01145	0.01130	0.01128	0.08987
Wtr Off	0.09620	0.09127	0.09125	0.01198	0.01190	0.01148	0.01133	0.01131	0.08220
Monthly charge. (\$/month)*	172.48	55.20	361.23	48.18	48.18	13760.43	13760.43	52.98	3.78

*PG&E monthly rates vary according to the customers' reservation capacity. Values shown are for customers between 50kW and 500kW. Monthly charges are shown for a 30 day month.
 **PG&E applies the charge to 85% of the reservation demand.

The scenario analysis will incorporate the range of charge levels and charge types identified above for the evaluation of fossil-fuel DER technologies. Renewable technologies will be evaluated with zero standby charges, as well as the full range of costs used for the fossil fuel technologies.

Exit Fees

Exit fees have been a significant issue in the past for departing customer load. While it has largely gone out of favor by Commissions, the effort by utilities to classify more of their systems as being "connection-related" rather than "usage-related" could provide a stronger basis for utilities to assign infrastructure costs to individual customers. Exit fee risk increases with the size of the customer relative to the neighboring businesses and industries: the larger the contributor-to-area-peak-load, the stronger the utility argument for exit fees. Conversely, this could also increase the value to the utility for the customer to depart the system. Of course, while utilities are quick to assess exit fees, utilities are not offering exit payments for customers to depart and thereby reduce peak demand in capacity constrained areas. For this study, the focus is on DER for customers that remain grid-connected, so zero exit fees are assumed. However, the cost effectiveness analyses do estimate the value of peak load reductions, so the value of peak demand reduction is assessed, even if those costs are not currently signaled or passed on to customers.

³⁹ T= Transmission; S-Sub= Secondary Substation; P-Sub = Primary Substation; P = Primary; S= Secondary

⁴⁰ Note that SDG&E customers are also subject to Schedule EECC (Electric Energy Commodity Cost). Schedule EECC bills for utility supplied energy and CA DWR purchases. The current EECC tariffs for AL-TOU and ASL-TOU-DER customers are On-Peak=0.09976; Semi-Peak=0.07574; and Off-Peak = 0.07574 (\$/kWh).

CUSTOMER BENEFITS OF DER

Annual Electricity Bill Savings

Calculate the electricity and gas bill for the customer with the original rate assuming a set of billing determinants. The range for this benefit will vary dependent upon the level of customer demand and the utility territory the customer operates within.

The structure of the utility rates affects the bill savings that a customer could attain through the installation of “behind the meter” DER technologies. The larger the fixed charge, the less bill savings potential for DER. In most cases, fixed charges are a small portion of a customer’s monthly bill. The small fixed charge is a result of rate design decisions that have viewed large fixed charges as inequitable toward customers with lower levels of electricity usage. Generally, volumetric (per kWh) charges have been viewed as a “fairer” way to charge for electric service. However, many utilities are trying to shift more of the customer bill into fixed charges. The argument used by utilities for the shift is that much of the electric delivery infrastructure costs are fixed and do not vary with customer consumption levels. As the fixed charges increase, the energy charges decrease, and the value of behind the meter energy production decreases. Southern California Edison is one example of a utility that has proposed to lower kWh charges and increase fixed charges to reflect the fixed costs of the grid infrastructure costs. That case is still before the CPUC at this time.

Sample fixed charges are shown in __ below.

Table 8: Fixed Charges

	PG&E			SDG&E		
	A-1 <50,000 kWh/yr	A-10 <500kW	E-19 500kW - 1000kW	A <20kW	AL-TOU < 500kW	AL-TOU > 500kW
Energy (\$/kWh)						
Summer Peak			0.18843		0.11496	0.11496
Summer Partial			0.10941		0.08818	0.08818
Summer Off			0.09199		0.087	0.087
Summer All	0.2201	0.15957		0.17533		
Winter Peak					0.11372	0.11372
Winter Partial			0.11523		0.08804	0.08804
Winter Off			0.09169		0.08703	0.08703
Winter All	0.14031	0.11167		0.14228		
Demand Charges						
Max Demand - Smr		6.7	2.55		7.04	
Max Demand - Wtr		1.65	2.55		7.04	
All					11.26	
Summer Peak			13.35		5.14	
Winter Peak						
Summer Partial			3.7			
Winter Partial			3.65			
Customer Charge (\$/day)	0.26612	2.46407	5.74949			
Customer Charge (\$/Month)				8.61	48.18	192.69

SDG&E Max Demand Charge shall be based on the higher of the Maximum Monthly Demand or 50% of the Maximum Annual Demand.

The PG&E demand charges use the maximum observed demand in each month. The SDG&E rates use the larger of the observed demand in each month or 50% of the maximum demand observed over the prior 11 months. This is a ratcheted demand charge. The demand charge variations are described below in ___.

Table 9: Demand Charge Variations

Charge	Characteristics	DER Impact
Monthly Demand	Billing based solely on the customer's peak demand observed in that month. In some cases, the peak demand may be measured over a subset of hours (e.g., on-peak period)	The customer's bill saving is reduced to the extent that the customer takes power from the grid to replace the DER at the time of the monthly peak. In the extreme case, there can be zero demand charge DER bill savings for the month.
Ratcheted Demand	Billing based on the larger of the customer's peak demand in that month and some fraction of the peak demand over some prior period. A common ratchet provision uses the highest demand (100% fraction) over the prior 11 months.	Greatly reduces the demand charge savings for DER. Any forced outage can potentially affect 12 months of billing. However, this could also increase the value of DER: If a customer has a usage pattern that spikes over a limited number of hours each year, the DER could be used to reduce that limited spike to reduce the customer's bills for 12 months. This peak shaving can be very beneficial to the customer --- as long as the DER does not have an outage during the limited spike period.
Coincident demand	Customer usage at the time of the simultaneous peak on some part of the delivery system. Difficult to administer, as the timing of the peak is only known ex-post.	Authors are unaware of this form being used outside of wholesale transmission transactions.

Natural Gas Costs

Although DER reduces consumption of electricity, natural gas fueled DER will increase natural gas usage. The gas rate structure (level of fixed verses volumetric charges) impacts the economics of the DER similarly to the electric rate structure, but because gas consumption is increasing this impact is reversed. That is, to the extent that a customer's natural gas bill has a high fixed charge component, the lower the incremental cost for any additional natural gas required by the DER.

Annual Avoided Fuel Costs

Include thermal value of combined heat and power systems as avoided fuel costs. This value will be in the range of \$0.005/kWh to \$0.06/kWh.

Generators that provide waste heat recovery provide additional value to the generator owners. The waste heat from this type of application is typically used for hot water or steam at the customer site and displaces the cost of purchasing natural gas or some other fuel to heat the

water. The range of value these CHP installations provide depends most critically on the amount of waste heat that can be captured from the generator and put to use, and the cost of the fuel being displaced.

An example calculation of the thermal value of waste heat recovery is shown in ___. With 40% of the energy in the fuel being recovered and put to use, and an avoided fuel cost of \$6.00 per MMBtu, the thermal value is \$0.03 per kWh generated. This is calculated by first estimating the energy no longer purchased to heat hot water per kWh generator in Line D (Heat Rate \times Energy Recovered / Efficiency of Replaced End Use) and then multiplying by the cost of the replaced fuel in Line F.

Table 10: Example Calculation of the Value of Waste Heat

Line	Variable	Result	Calculation
A	Heat Rate Btu/kWh	10,000	Input
B	Energy in Fuel Recovered for Waste Heat	40%	Input
C	Replaced End Use Efficiency (i.e. Boiler)	80%	Input
D	Btu Not Purchased per kWh	5,000	A \times B/C
E	Replaced Fuel Cost \$/MMBtu	\$ 6.00	Input
F	\$/kWh in Waste Heat Savings	\$ 0.030	D \times E/10 ⁶

The example above is repeated for different assumptions of replaced fuel cost and waste heat capture. Sensitivity analysis on the range of generator heat rates, or efficiency of the replaced end use is not performed because these inputs vary less between applications and are generally better known. Within the range of 'replaced fuel cost' and 'amount of energy recovered and put to use', shown in ___, the thermal savings can vary significantly from \$0.005 to \$0.063/kWh generated. In particular, the customer installing the CHP unit must be able to utilize a significant portion of the waste heat to have significant benefits.

Table 11: Value of Waste Heat Recovery (\$ per kWh generated)

		Replaced Fuel Cost \$/MMBtu			
		\$ 4.00	\$ 6.00	\$ 8.00	\$ 10.00
Percentage of Energy in Fuel Recovered as Usable Waste Heat	10%	\$ 0.005	\$ 0.008	\$ 0.010	\$ 0.013
	20%	\$ 0.010	\$ 0.015	\$ 0.020	\$ 0.025
	30%	\$ 0.015	\$ 0.023	\$ 0.030	\$ 0.038
	40%	\$ 0.020	\$ 0.030	\$ 0.040	\$ 0.050
	50%	\$ 0.025	\$ 0.038	\$ 0.050	\$ 0.063

Assumption 1: DER Heat Rate of 10,000 Btu / kWh

Assumption 2: Replaced End Use Efficiency of 80%

Wholesale Energy Sales

In the base case, assume that the DER customer does not sell energy to the wholesale electricity market.

Scenarios can set up to 100% of DG output to be sold to the wholesale market. The wholesale prices are driven by the Wholesale Energy Forecast as discussed in Section ____

In addition to the net metering discussed in Section ____, it may also be possible for the DER customer to sell energy into the wholesale energy market. In that case, revenues from the wholesale transaction will be included as a benefit to the DER customer. There will be a corresponding drop in the avoided wholesale energy purchases and revenue reductions on the utility's side, since the energy the DER customer sells to the wholesale market does not reduce their consumption from the utility.

The base case does not include sales by the DER customer to the wholesale market, but it is possible to set the model to allow for customer sales. The percentage of output from DG that is sold to the wholesale market is an input to the model. The market prices are the same as those used to calculate the avoided energy costs for the utility, see Section ____.

Renewable Energy Credits

In the base case, assume that the DER customer is not able to sell renewable energy credits (RECs), and that the REC value is zero. However, for renewable energy installations, a value of RECs to the customer could be realized. In this case, the value in the model for RECs ranges from a low of zero to a high of \$15/MWh

Low: zero (\$0)

Medium: \$6/MWh

High: \$15/MWh

A Renewable Energy Credit (REC) represents the specific renewable characteristic of electricity that is generated from either a renewable technology or from using a renewable fuel. The term green tag is also used to describe a REC as the "tag" defines the specific generation source: facility, vintage, technology type. One important element of the REC market is that RECs can be purchased separately from the generation that led to the creation of the REC. RECs must be from a verified source such as wind, solar, or biomass. This type of market could result in an additional revenue stream for the DER customer who elects to install a renewable technology.

While there is presently not an active REC market in California, other states, such as Texas, have successfully been operating a market for RECs since 2000. The values used in the model as a proxy for California REC prices are from published trade results in the Texas market. These values are only intended to show that other markets may be available to DER customers with renewable generation and to observe the effect of an additional revenue stream on the net benefit from the customer perspective.

Customer Reliability

In the base case, assume that the DER customer is not operating their equipment to operate independently from the grid, and that the reliability value is zero.

Grid-connected DER can provide customer reliability services that wires cannot, serving as a combination of utility service, backup generator, and Uninterruptible Power Supply (UPS) in a single package. An integrated wires and DER system cannot provide peak availability as high as a wires-only system of the same capacity, however, availability at lower loads, which occur more of the time, can be improved. If most of the reliability value is associated with lower loads, wires-integrated DER can achieve more value than a wires-only solution. *Thus, DER can improve reliability for critical loads.*

What matters to customers are the frequency, duration and timing of service interruptions. When partial service is available (as with a backup generator or power rationing), the magnitude of firm service is also relevant. Residents incur inconvenience costs at a minimum, and direct costs if food spoils or if working from home, and discomfort on a hot (or cold) day where electricity is needed to stay cool (warm). Commercial and industrial customers tend to incur higher direct costs from lost productivity and equipment damage. ___ summarizes the inconvenience, discomfort, and direct cost determinants.

Table 12: Summary of outage cost determinants.

<u>Inconvenience</u>	Reset clocks and equipment Entertainment: miss Oprah Appliances: no microwave or toaster Idle time
<u>Discomfort</u>	HVAC Lack of light Lack of security
<u>Direct Cost: Residential</u>	Home office: lost productivity Spoiled food Equipment damage
<u>Direct Cost: C&I</u>	Lost production Damaged equipment Idle labor and factors Overtime Foregone sales Lost customers and future business Recovery costs Lost data

Reliability Value for Customers


Numerous studies have explored the value of reliable service, or cost of unreliable service, through surveys of willingness to pay to avoid interruption, willingness to accept payment to compensate for interruption, direct costs incurred, revealed preference through participation in

curtailable rate programs or investment in standby generation and uninterruptible power supplies, conjoint analysis, etc.⁴¹

Costs of interruption vary by customer class. Outage costs to commercial and industrial customers include lost sales, reduced manufacturing output, spoiled inventory, damaged equipment, extra maintenance, and overtime. Costs imposed to residential customers include spoiled frozen foods, substitute heating and lighting costs, and inconvenience. Some customers have a high per-outage cost, where even a brief interruption causes large problems, such as a semiconductor fabrication plant or a stockbroker, while others may have few problems until the outage lasts long enough, such as an ice cream factory or plastic molder.

Reported outage costs vary tremendously. One common approach is to normalize outage cost on a per kWh basis of energy not supplied. A range of values from the literature is illustrated in ___ for several residential, commercial, industrial, and combined commercial and industrial surveys. Estimates typically range by an order of magnitude.

Figure 3: Typical range of reported values for customer value of service (VOS).



The range is due to survey methods used, the types of outages considered, and the specific residents or industries involved. Typical mid-range VOS values are listed in ___.

Table 13: Mid-range customer value of service (VOS) estimates

Customer Class	\$ per 1 hour	\$ per 4 hour	\$ per kWh
Residential ⁽¹⁾	\$4-5	\$15-20	\$4-5
Commercial ⁽²⁾	\$400-600	\$1,000	\$30-50
Industrial	\$10,000-20,000	\$40,000-50,000	\$10-20

⁴¹ Customer outage costs estimates are surveyed in Woo, C.K. and R.L. Pupp (1992) "Costs of Service Disruptions to Electricity Customers", *Energy*, v12n2, 109-126. Recent information is also presented in a recent report from SCE, *Customer Value of Service Reliability Study*, March 1999.

Agricultural	\$100 (summer)	\$400 (summer) \$2,500 (winter)	\$5-10
--------------	-------------------	--	--------

(1) Home office customers have not been specifically surveyed. The magnitude of this market is uncertain but growing, and has VOS much higher than a typical residence.

(2) The fast-growing "data center" sector has not been specifically surveyed, but may account for a significant fraction of new growth and have demonstrated much higher value of service than the average commercial business.

Estimated annual outage costs incurred by various types of customers are listed in ____, under "typical" (fairly high for many areas) and "extreme" (poor) reliability levels. Fewer than 0.2% of customers in California fall into the "extreme" case, possibly more in rural woodland areas. The value to residential customers in the worst areas with high VOS is on the order of \$400 per year, but a more typical value is only about \$10 per year. Extremely high values must be gauged against the cost of a standard UPS. Credible home office numbers are not available, and are therefore estimated based on direct cost anecdotal information from published survey results.

Table 14: Maximum outage cost estimates for customer types

			Typical Interruption Level			Extreme Interruption Level		
			Interruptions (per year)	Duration (minutes each)		Interruptions (per year)	Duration (minutes each)	
			1.5	100		10	200	
Annual Outage Cost	Per Outage	Per Hour	Events	Duration	Total	Events	Duration	Total
Residential: Typical VOS	\$ 1	\$ 3	\$ 2	\$ 8	\$ 9	\$ 10	\$ 100	\$ 110
Residential: High VOS	\$ 5	\$ 10	\$ 8	\$ 25	\$ 33	\$ 50	\$ 333	\$ 383
Residential: Home Office	\$ 50	\$ 100	\$ 75	\$ 250	\$ 325	\$ 500	\$ 3,333	\$ 3,833
Commercial: Typical VOS	\$ 200	\$ 200	\$ 300	\$ 500	\$ 800	\$ 2,000	\$ 6,667	\$ 8,667
Commercial: High VOS	\$1,000	\$1,000	\$1,500	\$2,500	\$4,000	\$10,000	\$33,333	\$43,333

Anecdotal data indicate that many customers think that brief interruptions can cost them between \$40,000 and \$200,000 in business. Some manufacturers such as pharmaceuticals companies consider their outage cost to be on the order of \$2 million per hour.⁴² Internet-based data centers require extremely high levels of reliability, which reflect VOS values orders of magnitude higher than those reported for conventional commercial loads.

For example, Sure Power is selling 1-MW grid-independent power supply systems for critical loads, based on the ONSI fuel cell technology and flywheel storage. Sure Power contractually guarantees 99.9999% (six nines) reliability, which is backed by a \$5 million insurance policy. With highly expensive technology and extreme redundancy, this product is clearly aimed at a premium-price market niche.

⁴² E Source, *Distributed Generation: A Tool for Power Reliability and Quality*, Report DE-5, November 1998.

CUSTOMER COSTS OF DER

Annual Capital Costs, DER Maintenance, and DER Fuel Costs

Use average equipment capital and maintenance costs for each DER technology

Range in model will span plus or minus 20% of the average costs above

Focus on natural gas technology, with and without combined heat and power

Assume financing rates applicable for an industrial customer

Direct costs to the DER customer include the equipment capital costs and financing, maintenance, and fuel costs. These costs are based on values that the E3 team has collected, typically from publicly available sources. DER equipment costs vary by manufacturer, technology type, and size. Maintenance costs will reflect the type of usage of the equipment. Fuel costs, which are tied to the natural gas market prices, are variable with the hours of operation and equipment efficiency.

Given these cost ranges and uncertainties, the analysis begins by using average values for these costs as shown in _____. The values shown below reflect E3's ongoing survey of current DER costs. After generating baseline results from these average values, sensitivity analyses are conducted using a 20% cost increase and decrease. Since there are so many options in terms of size and technology type, the focus is on one example of each that reflects the prevailing economics for that type.

Table 15: Average Costs and Operating Characteristics of DER Technologies

Technology	Generator Life (Years)	Heat Rate Btu/kWh (Net Heat Rate for CHP Applications)	Capital Cost \$/kW	Fixed O&M \$/kW-yr	Variable O&M \$/kWh	Annual Load Factor	Environmental Externality Benefit? 0=no, 1=yes
Fuel Cell Technologies							
200kW PAFC Fuel Cell	10	10,428	4,500	7	0.029	90%	
10kW PEM Fuel Cell	10	12,507	5,500	18	0.033	90%	
200kW PEM Fuel Cell	10	10,725	3,800	7	0.023	90%	
250kW MCFC Fuel Cell	10	8,723	5,000	5	0.043	90%	
200kW MCFC Fuel Cell	10	8,182	2,800	2	0.033	90%	
100kW SOFC Fuel Cell	10	8,338	3,500	10	0.023	90%	
200kW PAFC Fuel Cell CHP	10	5,348	4,500	7	0.020	90%	
10kW PEM Fuel Cell CHP	10	7,007	5,500	18	0.033	90%	
200kW PEM Fuel Cell CHP	10	5,775	3,800	7	0.023	90%	
250kW MCFC Fuel Cell CHP	10	6,303	5,000	5	0.043	90%	
200kW MCFC Fuel Cell CHP	10	5,720	2,800	2	0.033	90%	
100kW SOFC Fuel Cell CHP	10	5,731	3,500	10	0.023	90%	
Microturbine & ICE Technologies							
Capsora Model 330 - 30kW w/ CHP	10	5,573	2,804	3	0.020	90%	
IR Energy Systems 70LM - 70kW w/ CHP	10	7,840	1,929	4	0.011	90%	
Bowman T300 - 80kW w/ CHP	10	6,588	1,962	3	0.013	90%	
Turbac T100 - 100kW w/ CHP	10	6,188	1,785	4	0.015	90%	
Capsora Model 330 - 30kW	10	15,443	2,201	3	0.020	50%	
IR Energy Systems 70LM - 70kW	10	13,544	1,863	3	0.011	50%	
Bowman T300 - 80kW	10	14,103	1,862	3	0.013	50%	
Turbac T100 - 100kW	10	15,127	1,485	3	0.015	50%	
Small ICE (100kW)	20	11,500	1,200	3	0.015	45%	
Large ICE (50kW)	20	10,000	1,200	3	0.015	45%	
Solar & Wind Technologies							
PV-1	20	0.00	3,850	14	0.00	50%	
PV-50	20	0.00	3,975	3	0.00	50%	
PV-100	20	0.00	3,875	2	0.00	50%	
Bergey Windrower WD-10kW	18	0.00	2,955	6	0.00	45%	
Large Wind - GE 750 kW	20	0.00	1,200	15	0.00	45%	

For the majority of the DER technologies that use a fossil fuel, it is assumed that natural gas is the primary fuel. However, in some cases, diesel is required to operate the DER equipment. Fuel cost assumptions can vary by organization but this analysis incorporates the CEC's natural gas price forecast shown in _____. For combined heat and power applications, the natural gas prices these technologies receive are used (which typically do not include local distribution charges).

Financing Assumptions

The appropriate financing rates are applied depending on the application. There are three main ranges for cost of financing and required pay-back period for a DER application. The ranges are as follows:

- **Industrial Customer:** Appropriate for behind-the-meter generation where the customer's main emphasis is savings and risk reduction in their energy bill. This is the appropriate perspective for most of the analyses. Assume financing of 8% over 10 years in the base case.
- **Merchant Plant Financing:** Appropriate for large-scale generation where profit from energy sales is the main driver of the project. This type of application is not the focus of this analysis.
- **Residential Customer:** The optimistic case for residential financing is to use a 30-year home mortgage rate. This may be appropriate for small-scale photovoltaic applications. The small residential applications are not the focus of this analysis.

Emissions Offset Purchases

Include best estimate of environmental permitting fees in two scenarios, urban and rural. This would include the permit application as well as the engineering and purchase of offsets.

Depending upon the jurisdiction, permitting costs can add a significant amount of time and cost to fossil-fuel DER. For smaller projects in particular, the costs of environmental permitting can be prohibitive. For example, the Bay Area Air Quality Management District's (BAAQMD) specific fees that could be required as part of the environmental permitting process for DER facilities include:

- Administrative (Hearing Board) fees
 - Lower for smaller firms
- Combustion of fuel fees
- Major stationary source fees
 - only for larger units emitting more than 50 ton/year of organic compounds, sulfur oxides, nitrogen oxides, and/or PM10
- Major stationary source fees
- Excess emission fees

The specific BAAQMD fees for the combustion of fuel are shown in ____.

Table 16: BAAQMD Combustion of Fuel Permit Fees

	Variable Fee	Minimum Fee (per source)	Maximum Fee (per source)
Initial Fee (per source)	\$32.52 MMBtu/hr	\$179	\$62,545
Permit to Operate Fee (per source)	\$16.76 MMBtu/hr	\$128	\$31,272

The BAAQMD fees for major stationary sources are shown in ____.

Table 17: BAAQMD Major Station Source Fees

Emission Type	Variable Fee
Organic Compounds	\$53.35/ton
Sulfur Oxides	\$53.35/ton
Nitrogen Oxides	\$53.35/ton
PM10	\$53.35/ton

The example fees identified above only represent the fees for the Bay Area of California. Each air district will have different fee structures with which a DER owner will have to comply.

Additionally, the list of potential fees described does not include the time and resources required from the generation owner to complete the necessary permit paperwork for the managing air district. As this process can be lengthy and require significant resources, the overall cost of environmental permitting for fossil fuel burning DG is considerable. The permitting costs can be identified for specific DG technologies and an assumed resource factor can be added to the direct permit costs to appropriately model the impact of permitting on DG cost-effectiveness.

Interconnection Study, Equipment, and Electric System Upgrade Costs

Include base case cost of \$2,000 for interconnection. This includes study and basic customer interconnection equipment. Assume a zero cost in the base case for electric system upgrade costs

Range of interconnection study and customer costs span from zero to \$30,000 per DER installation

Actual electrical system upgrade costs to interconnect DER are very location-dependent.

Interconnection Study Costs

Prior to the passage of Assembly Bill (AB) x1-29 in April 2001, customers making generation requests were responsible for the engineering study costs. However, ABx1-29 reduces customer responsibility for study costs by raising the cost exemption limit from 10 kilowatt (kW) to 1,000 kW for renewable (e.g., solar and wind) self-generation metered by reversible flow meters and covered under the E-net (net energy metering service) rate schedule. The effect of ABx1-29 is that utilities (and potentially other customers) will now bear the study costs for eligible self-generation projects. PG&E estimates that the average engineering study cost is \$800.

Customer Interconnection Costs

Interconnection costs are the incremental costs to safely connect DER to the utility grid. Typically they are defined as the non-refundable fees that the DER customer pays to the utility to facilitate connection to the utility grid. The utility fees can cover: 1) any equipment that the utility must install in order for the DER customer to connect safely to the grid; 2) engineering costs borne by the utility to evaluate the DER installation, such as the identification of necessary protection scheme modifications; 3) switching; 4) metering; and 5) administrative costs. Interconnection costs can also include customer payments to third parties such as the DER provider. Because most DER projects are small, interconnection costs can add a significant percentage to the total installed cost of a project. Efforts have been underway in the DER community to reduce interconnection costs through the establishment of uniform national standards and "pre-certified" DER with integrated protection devices.

Utility Upgrade Costs

Refer to Section ____.

Insurance

This cost is relatively small in comparison with the other customer costs so in the base case, it is assumed that insurance costs are zero. Although this can be adjusted for specific cases, it is assumed that in all scenarios the incremental cost of insurance is zero.

Some jurisdictions allow utilities to require that DER customers provide insurance and indemnification naming the utility as the payee. In some cases, the amount of required coverage is limited by the Public Utility Commissions (PUC). As an alternative, the NY Public Service

Commission removed the requirement for a separate insurance coverage for DER and instead merely required that homeowners prove at least \$100,000 in homeowner's policy coverage.

Other Utility Infrastructure Costs and Operational Costs

The base case assumption is that there will be no significant upgrade requirements for utilities other than the electric utility. It is also assumed in the base case that there are no additional operational costs. These assumptions will be updated during the pilot studies when more location-specific information is available.

Only the electric utility is included as a stakeholder in the current version of the model. The interconnection study costs and system upgrades discussed in Sections __, __, and __ refer to the upgrades required to connect to the electrical system. However, the DER application may necessitate upgrades to other utility systems, for example natural gas pipeline compression. Investigation of the occurrence and level of such costs is beyond the scope of this study, but there are placeholders in the model to add other utility costs as when they are identified in the course of the pilot studies. The base case assumption is that the DER will be situated where there is sufficient natural gas delivery capacity.

Similarly there may be on-going (non-electric) operational costs that are not included in the specifications of the DER technologies. An example is a high level of water usage for certain fuel cells. Again, a field study of the operating characteristics of all the technologies included in the model is beyond the scope of this study, but there are placeholders to add other operational costs as they are identified in a more detailed pilot study. The base case assumption is that there are no significant operational costs other than those listed in the technology specifications.

UTILITY BENEFITS OF DER

Avoided Wholesale Energy Purchases

In the base case, use E3's internal forecast for forward energy prices as avoided utility costs in the base case.

In testing the scenarios, this forecast will be compared with CEC forecasts and/or utility data (if available).


In jurisdictions where there is an active wholesale market, such as California, current quotes for forward electricity contracts are used to generate short-term (0-3 years) forecasts of power prices. For long-term forecasts (>3 years) there are a number of alternatives.

1. The utility may provide its own forward price curve. This does not usually happen as the data is confidential and the utility will not want to use them if the results and underlying assumptions of the analysis are to be publicly available.

2. Use E3's forecast.
3. Use publicly available forecasts of long term power costs from such sources as the Energy Information Administration (EIA), CEC, Northwest Power Planning Council, etc.

_____ below shows the range of current forecasts for California. The historical data and Platts forward prices shown are for delivery to NP15 (north of path 15). The wholesale prices quoted for California are for firm delivery of energy and therefore include both energy and capacity. In New York there is also a capacity market, so there forecasts for both energy and capacity would be generated. The EIA projections are for retail prices for the Western Electricity Coordinating Council / California region hence they are higher than the wholesale projections from the CEC and Platts.

Figure 4: Range of forward electricity prices for delivery to NP15




Note: EIA prices are projections of annual average retail rates. CEC prices are projections of annual average wholesale spot prices. Platts are traded prices for monthly, quarterly, and annual average on-peak wholesale prices. The Platts forwards are adjusted to monthly averages using the historical ratio of on-peak to off-peak prices.

The E3 forecasts of energy costs in California use a combination of electricity forward contracts, natural gas futures contracts, and estimates of the long run marginal costs of a gas-fired combined cycle turbine (CCGT). _____ illustrates the method for generating the avoided energy costs.

- Step 1: The first three years of the forecast is based on the electricity forwards contracts
- Step 2: The percentage changes in average gas prices from the gas futures data are applied to the average electricity price to extend the electricity forecast to 2008.
- Step 3: Assume the resource balance year to be 2010.
- Step 4: Assume that the average market price in the resource balance year will be the long run marginal cost of a 500 MW Combined Cycle GT (CCGT).

- Step 5: Use a simple linear trend between the end of the short-term forecast (2008) and the beginning of the long-term forecast (2010).
- Step 6: From 2010 use the long run marginal cost of the CCGT escalated for inflation.

Figure 5: Long-term forecast of electricity prices for delivery to NP15



For sensitivity analyses, adjust the resource balance year (from 2006 to 2014), and test different scenarios of the underlying natural gas price forecasts and the plant and operating costs of the CCGT. ___ below gives the range of estimates for the CCGT.


Table 18: Plant Cost and Performance Data for a 500 MW Combined Cycle GT

Operating Data	
Heat rate (BTU/kWh)	6,500 to 7,500
Lifetime (yrs)	15 to 25
Plant Costs	
In service Cost in 2004 (\$/kW)	500 to 650
Financing Costs (\$/kW-yr)	75 to 90
Other Fixed Costs (\$/kW-yr)	12 to 25
Total Fixed Costs (\$/kW-yr.)	87 to 115
Fuel Costs (\$/MMBtu)	4 to 6
Total Variable Costs (c/kWh)	.03 to .06
Capital (c/kWh)	2 to 3
Variable (c/kWh)	3 to 6
Total Costs in 2004 (c/kWh)	5 to 9

The NYMEX Henry Hub future contracts are used to forecast the natural gas prices used in the short-term electricity price forecasts. The futures prices are adjusted for basis differential to the relevant market. The NYMEX contracts are traded 72 months in advance giving five years of

market data. As with electricity prices there are alternative sources of gas price projections for long-term forecasts. ___ below shows a current range of forecasts for natural gas delivery to California (So Cal Gas and PG&E Citygate).

Figure 6: Historical and projected natural gas prices (averaged over delivery month)



Generation Multiplier Effect

In the base case, assume a generation multiplier effect of 1.0 (no effect). In the scenarios test the following range of values:

Low Effect: 1

Medium Effect: 3

High Effect: 5

A system-wide benefit DER can provide is the reduction of market prices. This benefit applies to all customers in the region, including the DER owner as well as stakeholders purchasing energy from the market. Economic intuition suggests that implementation of distributed generation reduces the electricity demand of program participants and shifts the market demand curve downwards along a given market supply curve, thus effecting a price reduction that can benefit all electricity consumers.

A system demand reduction can decrease market prices in three specific and important ways. First, it reduces the output from units with high marginal production cost that drives the price offers of those units. Second, it can mitigate capacity shortages, thus diminishing the above-marginal-cost markup (i.e., shortage cost) required to balance system demand and supply. Third,

it can counter energy sellers' market power, the ability to raise market prices through capacity withholding.

The benefit to an electricity consumer is his/her gain in consumer surplus (CS). This CS gain consists of (1) the bill saving directly attributable to the price drop, and (2) the benefit from incremental consumption induced by the price drop. When the consumer's individual demand is highly price insensitive, the incremental consumption (and therefore its ensuing benefit) is small, close to zero. In this case, the CS gain is mostly bill savings.⁴³

The California Measurement Advisory Committee (CALMAC) acknowledges the importance of the price effect of a system demand reduction.⁴⁴ It affirms the use of escalators for the purpose of quantifying the system benefit of a load reduction. This practice is further supported by the assigned Administrative Law Judge's 10/25/2000 ruling (ALJ Ruling) on *Applications 99-09-049, 99-09-050, 99-09-057 and 99-09-058*, which states that "[t]he escalators are determined by looking at the 'load reduction value' or 'consumer surplus' relative to the market price and taking a ratio. The escalators are multiplied by the market price – either during peak or off-peak – to arrive at system value." (p.13).

The CALMAC report opined that the size of the on-peak escalator is 5X as long as market power is exercised and drops to 2.5X after market power conditions are mitigated. See CALMAC (2000) *Avoided Cost*, Report on Public Workshops on PY 2001 Energy Efficiency Programs, 09/12/00 – 09/21/00 and 09/26/00, California Measurement Advisory Committee (CA: San Diego), pp.21-22.

Avoided T&D Capacity

T&D value is extremely area and time specific. Use three scenarios based on the E3 analysis of the PG&E system in 1994 (looking forward to 1999); \$0/kW, \$289/kW, and \$1330/kW for 20 years.

Include reduction of utility loss savings due to DER in estimation of avoided energy (9% losses assumed) and MDCC costs (12% losses assumed).

Include in the evaluation a consideration of DG reliability (redundancy) requirements to provide 'firm' capacity.

Using information from existing utility system costing studies, which include detailed analysis on many 'distribution planning areas' within several utilities, we can develop a range of the potential value the avoided T&D capacity costs. This will provide one estimate of the range of value that DER could provide for deferral of utility investment. Once the overall range of avoided T&D costs are defined for some existing systems, several high cost areas will be analyzed individually to illustrate the systems we expect to be in place today and in the future.

A 1994 E3 study of four US utilities illustrates the variation in marginal distribution capacity cost (MDCC) by time and location, both within and between different utilities. This study

⁴³ Woo, C.K. (1984) "A Note on Measuring Household Welfare Effects of Time-of-Use Pricing," *Energy Journal*, 5:3, 171-181.

⁴⁴ CALMAC (2000) *Avoided Cost*, Report on Public Workshops on PY 2001 Energy Efficiency Programs, 09/12/00 – 09/21/00 and 09/26/00, California Measurement Advisory Committee (CA: San Diego).

estimated the MDCC value in 378 utility planning areas across four utilities including Pacific Gas and Electric (PG&E), Kansas City Power and Light (KCP&L), Central Power and Light (CPL), and Public Service of Indiana (PSI), now CINergy.

The four utilities vary from each other by location, customer mix, load profile and size. PG&E, for example, is larger than many national utilities, with annual sales of about 75 TWh (75 billion kWh). ___ and ___ provide information on each of the utilities studies.

The MDCC was estimated in the 378 planning areas across these utilities. The range and variation of MDCC within and between these four utilities is shown in ___ and ___, which show the utilities' MDCC estimates for 1994 and 1999. In this study, the MDCC was estimated as a lifecycle value over 20 years. For example, a MDCC of \$500/kW means that a 1-kW reduction for 20 years is worth \$500.

Table 19
Customer Mix, Residential Rate and kWh Use, and Employment

Utility	State	Customer Mix	Residential Customer Average	Number Of Full-Time Employees
PG&E	California	Residential: 3,637,374 C&I (Small): 446,487 C&I (Large): 1,145 Others: 111,781 Total 4,196,787	Rate: 10.41¢/kWhr Usage: 6,443 kWhr/yr	17,770
PSI	Indiana	Residential: 522,769 Commercial: 71,008 Industrial: 2,923 Others: 1,308 Total: 598,008	Rate: 6.00¢/kWhr Usage: 11,953 kWhr/yr	3,962
CP&L	Texas	Residential: 476,555 Commercial: 2,153 Industrial: 6,441 Others: 3,540 Total: 558,689	Rate: 7.90¢/kWhr Usage: 11,492 kWhr/yr	2,330
KCP&L	Missouri	Residential: 362,787 Commercial: 48,042 Industrial: 2,372 Others: 134 Total: 413,426	Rate: 8.10¢/kWhr Usage: 9,959 kWhr/yr	3,233

Table 20
Sales, Peak, and Substations

Utility	1991 Sales (GWhr)	System Peak (MW)	Bulk Power Substations	Distribution Substations
PG&E	74,195	Summer: 18,620 Winter: 14,876	No. 87 kva: 33,130,000	No. 828 kva: 24,547,000
PSI	27,185	Summer: 4,756 Winter: 4,083	No. 114 kva: 20,200,154	No. 426 kva: 5,705,896
CP&L	16,925	Summer: 3,291 Winter: 2,762	No. 56 kva: 3,565,000	No. 226 kva: 3,919,050
KCP&L	13,106	Summer: 2,751 Winter: 1,674	No. 16 kva: 9,389,998	No. 101 kva: 4,972,034

Source: Directory of U.S. Utilities, Electric World, 1993; 101st edition.

Table 21
Descriptive Statistics for 1994 MDCC (\$/kW) by Utility

Utility	Number of Areas	% of Areas with \$0/kW	1st Quartile	Medium	3rd Quartile	90th Percentile	Maximum	Mean	Standard Deviation
PG&E	201	18.91%	\$166	\$240	\$303	\$392	\$1,173	\$230	\$156
PSI	152	73.03%	\$9	\$0	\$28	\$197	\$1,040	\$64	\$169
CP&L	17	0.00%	\$269	\$344	\$712	\$1,638	\$1,801	\$550	\$659
KCP&L	6	0.00%	\$78	\$129	\$162	\$201	\$233	\$130	\$67

Table 22
Descriptive Statistics for 1999 MDCC (\$/kW) by Utility

Utility	Number of Areas	% of Areas with \$0/kW	1st Quartile	Medium	3rd Quartile	90th Percentile	Maximum	Mean	Standard Deviation
PG&E	201	18.91%	\$207	\$289	\$335	\$433	\$1,330	\$267	\$179
PSI	152	72.37%	\$0	\$0	\$29	\$171	\$1,641	\$73	\$217
CP&L	17	0.00%	\$321	\$534	\$859	\$1,732	\$1,795	\$556	\$690
KCP&L	6	0.00%	\$62	\$99	\$108	\$146	\$182	\$94	\$54

_____ compares the distribution of MDCC in 1994 for each of the utilities. This chart shows the MDCC for the different utility planning areas as a percentage of utility load. For example, 50% of PG&E's load is served into areas with a MDCC of approximately \$300/kW.

From _____, _____ and _____, we see that the MDCC variations can be dramatic: 72% of PSI's planning areas have zero MDCC over the 20-year planning horizon, while 75% of CP&L's planning areas have MDCC values greater than \$320/kW. The MDCC distributions vary substantially by utility. The MDCC for KCP&L ranges from \$50/kW to only \$182/kW, while the range for PG&E is from zero to over \$1300/kW. The mean MDCC varies from \$73/kW for PSI to \$556/kW for CP&L.

Amount of Load at Different Levels of MDCC




Figure 7: Distribution of MDCC Values for Four Utilities

DER Value at Various Penetration Levels

The MDCC results from the four utilities described above can be used to estimate the amount of DER that would be needed to defer distribution capacity at a given MDCC level. One should be very cautious about extrapolating such results from one utility to another, and as the results show, the values for an individual utility change over time. However, the results from these four utilities provide a representative range for comparison.

The wide range of potential avoided distribution capacity costs shown by the MDCC values for each utility provides an estimate of the marginal distribution capacity value. This is the value that a small amount of DER can provide the distribution system in different areas. However, with high penetrations of DER in a given utility market, the marginal cost of distribution overestimates the actual avoided cost for the DER. This over-estimation occurs because as more DER is introduced, the incremental value of additional DER is reduced. In other words, there are decreasing returns to additional DER, because not every kW of DER can offset the highest-cost distribution capacity.

At significant penetration levels, the value of DER decreases because investments are deferred farther and farther into the future, which has less and less value. The highest marginal value can be achieved by deferring the highest-cost planning area for one year. However, this may not amount to a significant amount of DER potential at a given time.

In order to estimate the amount of DER potential at a given avoided cost, as indicated by the distribution of MDCC values, it is important to understand the relationship between DER capacity and the potentially deferred distribution capacity. The DER source does not have to

meet the entire load of a distribution planning area, nor any of the existing load. Rather, the DER source can defer planned distribution capacity by reliably meeting the new load growth that is expected in the coming years.

Thus, the maximum amount of DER potential at a given MDCC is considerably less than the existing loads in the distribution planning areas where the MDCC value applies. Once the DER capacity is sufficient to offset new load growth and defer capacity expansion, additional DER capacity would not provide any more deferral benefit. On the other hand, the DER source must have at least sufficient capacity to replace one year's load growth to be sure that some deferral is achieved.

___ shows the MDCC value of DER as a function of penetration for the four-utility sample. ___ displays the same information graphically and provides an overall picture of the range of achievable MDCC with significant DER penetration. The "percent of utility load" data in ___ correspond to the maximum share of total load that could be deferred by DER at a given MDCC, assuming that the DER is placed in the ideal point in the system to capture the maximum distribution capacity deferral value. The DER penetration values are estimated assuming a maximum deferral period of 10 years. At an average annual load growth rate of 3%, this corresponds to a maximum of 30% of the utility load that could feasibly defer distribution investments.

For example, at 1% of the utility load, the MDCC ranges from \$174/kW at KCP&L to \$1,535/kW at CP&L. For PG&E, which is by far the largest of these utilities, the first 1% penetration or 186MW (corresponds to 1% times 18,600MW from ___) would have a value of \$388/kW.

Table 23
Capacity Value as a Function of Penetration for Each Utility

% of Utility Load	PG&E	PSI	KCP&L	CP&L
1.00%	\$388	\$395	\$174	\$1,535
2.50%	\$335	\$132	\$160	\$1,219
5.00%	\$290	\$53	\$138	\$548
10.00%	\$241	\$27	\$112	\$269
20.00%	\$182	\$0	\$55	\$211
30.00%	\$0	\$0	\$0	\$0

Maximum Distribution Value of Targeted DG




Figure 8: Range of achievable MDCC with significant DER penetration

At high level of penetrations, the value of distribution capacity decreases as more and more DER is installed. There are also a minimum number of units that must be installed in order to defer planned transmission and distribution investments by at least a year. Since utility planners work on an annual cycle to prepare plans to meet each years forecasted peak load, deferral for less than a full year of load growth has no economic value.

Problems and Costs of Siting Transmission and Distribution

Another factor that leads to higher distribution capacity costs is the increased siting sensitivity to new distribution capacity investments since the four-utility study was conducted. This siting sensitivity leads to higher costs, since projects are studied longer, and they are more likely to include underground facilities, different routes, and other 'camouflaging measures.' This is particularly true in expanding suburbs that are now developing their own business-centers, such as the example from Tri-Valley in PG&E's service territory discussed below.

Key Drivers of Distribution Deferral Value

The relationships between the key drivers of deferral value include the following:

- Expected load growth, which drives the need for new capacity, but also causes such capacity to be used (fast load growth reduces the time new capacity can be deferred);
- Deferrable planned investments, the cost of which drives the MDCC;
- Siting constraints (right-of-way, undergrounding, etc.), which can exclude technical options, complicate distribution design and increase the cost of needed investments;

For the most part, the effects of load growth and siting constraints are captured in the distribution capacity investments that are called for in the expansion plan. The costs of these deferrable investments drive the MDCC value and indicate the utility cost savings that can be achieved by DER.

Ideal Target Distribution Planning Area

The ideal distribution planning area for DER is the one with high MDCC, which represents a high avoided utility cost for potential DER investments. Such an area usually has a need for new distribution utility investment, and a moderate level of load growth. In such an area, it may be possible to defer the investment for several years with only a few MW of on-peak capacity load reduction.

Contrary to popular belief, the area with the most concentrated utility investment is not necessarily the area with the highest value. These areas have high costs for potential deferral, but they usually also have very high load growth. Fast growth makes it difficult to defer capacity expansion for very long, or requires large peak load reductions (from DER, for example) to do so. Therefore, the value of reducing load per kW is not necessarily high even though there are a lot of dollars at stake.

Realizing Deferral Benefits

To defer the distribution investment, one of the following has to apply:

4. DER must have reliability at least as good as the conventional wires solution,
OR:
5. DER must meet the same minimum reliability standards as the conventional wires solution.

The subtle difference can have a large impact because of the discrete or "lumpy" nature of system failures and capacity. A wires solution may result in 99.99% availability in order to meet a minimum standard of 99.9%, because the next best solution may only be 99.8%. There is clearly a large difference for the DER system to meet a 99.99% versus 99.9% target.

The second point of tension is which metric or metrics are to be used to judge "equivalence." Availability at peak load is a metric familiar to distribution system planners, but so are expected unserved energy (EUE), annual expected outage time and expected number of outages per year. It is possible (and not uncommon) for potential solutions to rank in one order in terms of availability and the reverse order for EUE.

Reduction of Losses

Utility distribution companies (UDCs) try to limit energy losses on their systems. Reduced losses can improve the overall efficiency of the distribution system and allow the UDC to purchase less energy to meet the same customer demand. Cases in which high losses are a problem are usually solved by upgrading conductors on a long circuit, or by providing reactive power support where reactive power losses are high.

DER can also reduce system losses by reducing the current flow from the transmission system through the transformers and conductors on the distribution system. Because losses are

proportional to the square of the current load (I^2), the effect of DER on losses is most pronounced during times of peak loading. The presence of DER in the right location can possibly defer or eliminate the need to re-conductor specific feeder segments, although this is usually not a major component of the MDCC. The effect of DER on reducing losses in the system is quantifiable in energy savings to the utility, with some limited capital savings.

A secondary benefit that DER-based loss reduction provides to the UDC is the reduction of the UDC's total installed capacity as seen by the transmission system and Independent System Operator (ISO). Capacity payments and ancillary services charged by the ISO to each UDC are allocated in part by total load, including losses. Therefore, incremental loss reductions provided by DER can help reduce these payments from the UDC.

Conclusions on Distribution Capacity

The value of deferring distribution capacity investments, indicated by the MDCC values, varies widely by area. The relatively low *mean* MDCC values imply that little DER would be cost-effective, *if implemented at the same time system wide*, at PG&E and especially at PSI, unless system-level (generation and transmission) avoided costs were large, which is unlikely because these utilities had excess generating capacity and slow system-wide load growth at the time of the study (but not now).

The individual area-specific MDCC values also fluctuate considerably over time, although the system-wide MDCC estimates were similar in 1999 compared to 1994. Few of the high-cost areas in 1994 continued to be high-cost areas in 1999; rather they were replaced by other planning areas that become high-cost areas as a result of imminent distribution capacity expansion. Similarly, some of the high-cost areas in 1999 may continue to be high-cost areas in 2001 and beyond, but others will be replaced by other planning areas where distribution capacity expansion is planned.

_____ and _____ illustrate the importance of MDCC information to evaluating the cost-effectiveness of potential DER sites. For example, based on the 1999 results, a DER unit with a cost of \$320/kW would be cost effective in more than 75% of CP&L's planning areas on the basis of MDCC alone, while it would only be justified in about half of PG&E's areas, less than 10% of PSI's areas, and not at all for KCP&L. A DER application with a cost of \$500/kW would be cost-effective in more than half of CP&L's planning areas but in less than 10% of the other three utilities' areas.

In addition to the area- and time-specific variations in the MDCC values, the deferral value of DER decreases at high penetration levels, for the following reasons:

- As more DER is introduced, the incremental value of additional DER is reduced.
- Distribution investments are deferred farther into the future, reducing their value.
- Once the DER capacity is sufficient to offset new load growth and defer capacity expansion, additional DER capacity provides no more deferral benefit.

The four-utility study is a few years old, as it was performed looking forward from 1994 to 1999 and beyond. However, the fundamentals of utility planning and growth, costs, and technology that drive the costs of increasing capacity have not changed significantly. Therefore, the level

and ranges of the marginal capacity costs across utility planning areas in 1999 should be fairly representative of the current distribution of costs.

Assuming the highest growth areas have been the first priority for distribution investments, the remaining areas that have not yet been upgraded are likely to have high marginal costs looking forward. Simply put, there are probably more high-cost areas with planned distribution expansion projects now than there were in the 1994 study cited above.

Customer Payment for Interconnection Study Costs

Refer to Section ____

System Reliability

Assume in the base case that utility reliability metrics remain unchanged due to DER. In a high DER penetration case, we can estimate an improvement.

Reliability of electrical service refers to the adequacy and security of the distribution system. It generally means whether electric service is available or not, and if not, then how often, when, for how long, losing how much load, and affecting how many customers?

Power quality refers in general to waveform specifics such as voltage or frequency abnormalities, power factor, harmonic distortion, or aberrations from an ideal sinusoidal AC wave shape.

Outages and shortages affect utilities, even when they do not lead to service interruptions. For example, a blown transformer in a substation with extra or redundant capacity still requires repair even if no customers are affected. Likewise, a shortage initiates costs of implementing load curtailment programs and (depending on the grid configuration and market structure) scheduling and balancing headaches and price volatility.

Utility outage costs include loss of revenue from customers not served, loss of customer goodwill, loss of future potential sales due to adverse reaction, and increased expenditure due to maintenance and repair. Reliability is generally treated as a constraint in engineering design practices rather than considered explicitly as a cost, requiring that the system meet specific availability, loss-of-load probability (LOLP) or other reliability index criteria.

What matters to the utility is the cost associated with repair, lost revenue due to unserved energy, public perception and goodwill, penalties or foregone performance incentives, manning call centers, and in some extreme cases civil penalties and related legal costs. In the longer term, reliability problems could prompt customers with the greatest sensitivity to simply bypass the utility system altogether.

Table 24: Summary of utility outage cost determinants.

<u>Direct Cost</u>	Emergency response/repair Lost revenue Call center SCADA systems Paperwork
<u>Indirect Costs</u>	Penalties Foregone incentives Accelerated investment Legal costs
<u>Risks</u>	Bypass: lost customers Regulatory repercussions (rate hearings)
<u>Intangibles</u>	Goodwill Public perception

Reliability Value for Utilities

Direct repair costs are dominant and estimation is straightforward. Based on publicly available rate cases and outage data, utilities on average spend approximately \$2,000 to \$3,000 per event that results in a sustained outage. These costs vary widely, from a few hundred to several million dollars. DER will not prevent trees from hitting wires or cars from hitting poles. DER will in general only be able to reduce outages attributable to overloads and a portion attributed to "equipment failure" and "unknown" (which can be due in part to overloading). In all, these may constitute 10-30% of all outages, depending on the utility and the area. A reduction in overloading does not eliminate these outages, but it incrementally reduces the failure rate. Additionally, repair costs in an area with DER could increase due to the added complexity of safe procedures with the possibility of "islanding", or isolated dispersed generation still connected to the grid.

As restructuring evolves across the country, performance-based rates (PBR) are being designed and implemented to provide a financial incentive for utilities to contain costs and provide cost-effective enhancements to customer service, power quality, and reliability. The mechanisms generally are symmetric penalty-reward schedules based on annual SAIDI and SAIFI values for sustained outages, total number of sustained outages, or maintenance and repair outages per mile of line. These are symmetric in that the reward or penalty is scaled relative to a historical or "adequate" level of service.

The actual dollar amounts are the result of a ratemaking or negotiation process. They tend to fall somewhere between reported residential and commercial value of service values. Typical PBR incentive schedules for one utility are shown in _____. The expected rewards or penalties (dotted lines) are estimated using the total number of customers and assuming that the index is normally distributed based on historical data. Rewards are typically in the range of \$20 per customer

interruption and \$10 per interrupted customer-hour. The incentives represent direct economic value to the utility, paid ultimately by customers.

Figure 9: Representative performance-based (PBR) reliability incentives.




Table 25: Expected rewards/penalties for a utility facing the schedules in Error! Reference source not found..

	<u>SAIDI</u>	<u>SAIFI</u>
Expected Reward per Reliability Unit	\$800,000 per customer-minute/customer	\$900,000 per .01 customer-outages/customer
Expected Reward per Unit Improvement	\$10 per customer-hour	\$20 per customer-outage

There is also a direct link between "reliability improvement" and "capacity expansion" projects, in that capital investments can be triggered by emergency ratings of equipment relative to the anticipated demand level, even if there has been historically excellent reliability in the area. The investment is basically reliability-triggered, albeit indirectly. From a pure cost-effectiveness perspective, such an investment is prudent when the decrease in failure probability weighted by the extent and duration of a potential outage is sufficient to warrant investment (i.e., it costs less than utility savings and reduced customer outage costs).

Engineering guidelines do not take this extra step. Whether an investment is triggered by engineering-standard reliability limits or by probabilistic availability goals, deferral of the investment can be thought of as a reliability benefit, but can only be counted once (we cannot credit the savings as a capacity and a reliability benefit). As a constraint on capital investment, a reliability standard implies a "shadow price" of an avoided or deferred investment. The value of the savings (costs) that would be realized if the reliability standard were relaxed (tightened) slightly. This value is in theory computable on a case-by-case basis and is a direct measure of the value of reliability to the utility. However, this approach requires data unavailable to most utility planning analysts and is rarely used in practice.

Finally, depending on the reliability measure, an integrated "wires and DER" electricity delivery system offers the opportunity to provide the same level of reliability while relaxing (lowering) the reliability requirements for the wires themselves. This feature is evident in energy-related measures such as expected unserved energy (EUE) or in partial-peak measures such as availability at 50% of peak or at average load.

The resulting improvement (in EUE, for example) is due to greater weight applied to low load periods, which constitute a high percentage of time and total energy consumed for low load-factor (loads with sharp peaks) customers. The magnitude of the potential cost savings has not yet been studied and is likely modest in most cases, but not all.

Other T&D System Benefits

Include reduction of utility loss savings due to DER in estimation of avoided energy (9% losses assumed) and MDCC costs (12% on-peak losses assumed).

In the base case, assume zero value for other engineering benefit categories.

DER can provide additional economic value beyond capital deferral and improved reliability. Although these value parameters are implicit in the engineering assumptions used to design distribution capacity expansion, they are typically not analyzed explicitly in terms of economic value. As a result, significant economic savings can often be realized by designing a DER-based solution to a specific distribution problem, without wholesale capacity expansion.

This section describes a variety of services that DER is capable of providing, and gives a detailed example showing how such savings can be quantified. The example illustrates the response of a UDC to various operational issues, and the conventional measures that would ordinarily be applied to correct them. A scenario with significant DER penetration is then analyzed to evaluate the ability of DER to provide comparable engineering benefits and to quantify the potential UDC cost savings.

The example also demonstrates how the potential DER benefits are highly case-specific. The results suggest that it is more important to develop a generalized approach for quickly determining the DER benefits in a specific case than to seek a generalized DER benefit value. The last section of this report will address issues surrounding the actual treatment of these savings from an institutional and regulatory perspective.

Voltage Support

A UDC defines criteria for maintaining voltage within prescribed tolerances throughout the system. These criteria require the UDC to take measures to prevent voltage from being either too high or too low under normal or contingency conditions. The greater concern is typically keeping the voltage above minimum limits, because voltage drops are more precipitous during peak load periods.

Conventional measures used to provide voltage support include the installation of voltage regulators (essentially series transformers with variable output settings), or capacitors, boosters, and in some cases upgraded line segments. (An inadequately sized line can exacerbate a voltage

drop problem because of its higher impedance). Reactive power (VAR) support has a powerful impact on supporting voltage, as there is a more direct relationship between voltage and reactive power flow than with real power flow. Thus, capacitors that provide VAR support are often preferred over regulators.

DER can help support voltage in areas of the distribution system that experience significant drops at high loads. In most cases voltage support entails raising the voltage in the area of the DER site during the load periods when it is needed. Voltage support is provided by injecting power into the system at the DER site, thereby reducing the current and corresponding voltage drop from the substation to the area. With the correct technology, voltage support can be provided by DER through reactive power injection as well. To the extent that DER can provide voltage support functions to a UDC, it can defer or eliminate the need for the UDC to purchase and install the conventional equipment listed above. The economic value of voltage support will often overlap with both capacity and VAR support benefits.

Voltage Regulation

Voltage regulation refers to controlling periodic swings of the voltage on a particular part of the system caused by large, fluctuating loads. UDCs typically install voltage regulators with automatic tap changing mechanisms to solve a voltage regulation problem. DER can potentially regulate voltage in such situations by balancing the fluctuating loads with fluctuating generation output. If properly sized, DER technologies that are capable of reactive power control can dampen these voltage swings, while maintaining a constant real power output. An effective DER application would improve utility operations, potentially improve the life of voltage regulators by reducing tap changing operations, and possibly eliminate the need for purchasing the voltage regulator equipment altogether.

Reactive Power Support

Reactive power (VAR) support most often refers to the injection of reactive power into the distribution system to balance the reactive power demand from inductive loads, motor loads, and the inherent inductance in the power delivery components. A high VAR demand results in higher current demand for the same amount of real power delivered. The higher VAR demand reduces the system's power factor, which is the standard measure for real and reactive power balance.⁴⁵ UDCs limit VAR demand on the system with the use of capacitors, and they generally require that customer loads do not have power factors below 80%.

The result of improved reactive power flows (or improved power factor) is less current and apparent energy required from the transmission system, less current (and therefore losses) on the distribution components, and better control of system voltage. DER can help balance reactive power flows on the distribution system with both real and reactive power injection. Real power injection reduces current in the conductors, which is a major source of VAR demand. As mentioned earlier, DER technologies with VAR support capability can provide more current reduction than technologies with only real power generation.

⁴⁵ Power factor is the ratio of real power to *apparent* power, where apparent power is the vector sum of real and reactive powers. Therefore, a power factor of 1 (or unity) includes no reactive power.

Equipment Life Extension

The theoretical impact of current loading on the life of equipment such as the substation transformers, regulators, and feeder conductors is well documented and can be estimated using software algorithms. For substation transformers, several software programs incorporate algorithms defined in ANSI/IEEE Standard C57. This standard provides a guide for transformer loading based on thermal limits that affect the accelerated aging of coil insulation. Internal oil and "hot spot" temperatures are determined by the transformer load and ambient temperature over time, as well as the size and design characteristics. Loading that causes the calculated loss of life to exceed 0.037% in a single day during normal operation is considered to cause an accelerated loss of life (given a 40-year life expectancy). For emergency conditions, it is typical for utilities to limit loading such that the loss of life never exceeds 1% over a single 24-hour period.

Therefore, measures taken to prevent daily loss of life from exceeding the normal and emergency limits are theoretically providing an economic value equal to the costs associated with the transformer's otherwise premature replacement.

The problem with using this type of cost function is that it incorrectly assumes a utility bases its equipment replacement decisions on an accurate account of historical loading data. Furthermore, the ANSI C57 guide itself acknowledges that it is not possible to predict with any real degree of accuracy the length of a transformer's life. As such, it is not likely that DER owners can successfully pursue payments based on this type of cost function, which unfortunately cannot be reliably measured.

Many utilities merely use the ANSI guide to define loading limits for their particular load and ambient conditions, and they make expansion planning decisions to prevent loads from exceeding those limits. The value of DER in these cases relates back to capacity deferral: by limiting thermal overloads on the transformer, they are deferring expansion costs, not replacement costs.

Where DER can selectively provide value for equipment life extension is in aging facilities. Utilities regularly face the need to replace equipment that is deteriorating from age or harsh environmental conditions. By extension, there is also the occasional need to replace or upgrade equipment that is obsolete or incompatible with newer facilities.

Projects to replace old and/or weakened facilities compete with capacity expansion projects for limited capital budgets, and the replacement projects often lose. However, an important factor (of many) that influences the urgency of a replacement project is the equipment loading. Lightly loaded systems that experience little growth are less likely to be replaced as quickly as similarly situated systems that operate near their ratings. If DER is used to keep loading levels on these facilities below a predefined de-rated value, the DER source could reasonably be credited for the deferral of replacement costs.

Reduced Facility Maintenance

One of the primary functions provided by a UDC is routine and corrective maintenance on components at all levels of the distribution system. From an operations standpoint, the UDC performs day to day monitoring of system operating conditions and equipment status, controls

sectionalizing equipment, capacitors and voltage support components, and solves problems with equipment as they occur.

DER installations can potentially reduce certain operations and maintenance (O&M) functions required by a UDC. One specific example is maintenance on the tap changer of voltage regulator. Maintenance intervals for these regulators are determined by a certain number of tap changing operations (25,000 is one typical value). If DER were used to provide voltage regulation in an area that would otherwise have multiple tap-changing operations per day, the DER would effectively reduce the maintenance intervals on the regulator. Other examples include reduced operation of capacitors and sectionalizing equipment, where DER is used to provide voltage or capacity support.

However, it is unclear what net impact DER could have on UDC O&M budgets. Penetration levels of 10-20% may very well increase overall O&M labor needs for UDCs, given the monitoring that might be required and the potential impacts to protection equipment such as reclosing breakers and fuses.

UTILITY COSTS OF DER

Revenue Reduction Due to DER

The reduction in customer bills from Section ___ represents the lost revenue to the utility.

The structure of the utility rates impacts the utility's lost revenue from a customer's installation of "behind the meter" DER technologies. The larger the fixed charge, the less lost revenue potential for DER. In most cases, fixed charges are a small portion of a customer's monthly bill. The small fixed charge is a result of rate design decisions that have viewed large fixed charges as inequitable toward customers with lower levels of electricity usage. Generally, volumetric (per kWh) charges have been viewed as a "fairer" way to charge for electric service. Many utilities, however, are trying to shift more of the customer bill into fixed charges. The argument for the shift is that much of the electric delivery infrastructure costs are fixed and do not vary with customer consumption levels.

Refer to Section ___ for examples of fixed charges.

Interconnection Study and Equipment Costs

Refer to Section ___

System Upgrades

In the base case, assume that there are no system upgrade costs.

Depending upon the type of DER and the specifics of the installation, DER can aid or hinder the delivery of high power quality. DER manufacturers attempt to address many of these issues through their power electronics equipment, and utilities may require additional relays and other protective devices to manage voltage and frequency on the distribution lines. For smaller DER, it can be assumed that the system stability costs are incorporated into the interconnection costs. As DER gets larger, transmission system concerns and potential benefits may also merit consideration.

For example, the grid must allow for power flows in both directions between the DER source and the substation. To allow parallel operation of DER sources larger than 1-2 MW, moderate substation upgrades may be needed. Depending on the distance between the source and the substation, and on the capacity of the existing distribution feeder lines, distribution network upgrades may be needed.

Transformer capacity at the substation can also limit the maximum amount of power that can be exported from DER sources without incurring major new investments. For most areas, this limit is at least 5-10 MW. If the power exports exceed this capacity limit, then the capacity of the DER source would surpass that needed to offset the local-area load growth. The costs of a large increment of capacity would have to be justified more by its system-level benefits than its local-area benefits.

The potential cost of electrical protection is a particular concern with respect to the viability of DER. Protective relays and other equipment are needed to sense fault currents and disconnect before equipment damage and other serious problems result. A large DER source, if sited a significant distance from the substation that connects it to the transmission network, can also increase the risks associated with islanding⁴⁶ and other contingencies.

The cost of connection and protection equipment could indeed be prohibitive for some potential DER sites. The connection and protection costs tend to be lower for DER sources that are relatively large (up to a threshold that varies by area) and that are sited relatively close to the substation (or perhaps connected directly at the transmission level).

To help reduce the connection and protection costs associated with DER sources, the Institute of Electrical and Electronic Engineers (IEEE) is working to develop national interconnection standards. Most Commissions have issued interconnection standards for small generation sources.

Incentives to DER Customers

In the base case there are no incentives from the utility to the customers. In the collaborative DER program, we will design customer incentives to make DER economic from both customer and utility perspectives if possible.

⁴⁶ Islanding is the condition that occurs in localized areas of a power system, where a delivery area may be isolated from generating resources. Islanding occurs when a fault in the distribution system separates a generating source from the rest of the system, creating an electrical "island." The DER source can continue to operate in such conditions, and thereby increase the reliability of service to the adjacent loads. However, if the main grid is later reconnected to this source, there is the chance that the islanded source would no longer be synchronized with the main grid. In such a case, reconnecting the two sources could cause severe over-currents that might cause additional system faults, damage both distribution system components and customer equipment, and possibly pose a safety risk to utility personnel.

While a key benefit to DER customers, incentives can also represent a cost to the utility depending upon who provides the incentive value. In California, there are numerous existing incentive and rebate programs that apply to the DER customers. In most cases, these incentives are only available to customers who have installed renewable DER technologies. Utilities, on the other hand, can provide monetary incentives to DER customers through a tariff structure, a competitive request for proposals, or a bilateral contract for generation services.

Refer to Section ___ for ranges of incentive payments

TOTAL RESOURCE BENEFITS OF DER (COMBINING THE UTILITY AND DER CUSTOMER PERSPECTIVES)

Avoided Energy Purchases

Refer to Section ___

Avoided Fuel Costs

Refer to Section ___

T&D Avoided Costs

Refer to Section ___

Increased Reliability

Refer to Sections ___ and ___.

TOTAL RESOURCE COSTS OF DER (COMBINING THE UTILITY AND DER CUSTOMER PERSPECTIVES)

DER Equipment, Maintenance, and Fuel Costs

Refer to Section ___

Interconnection Studies, Equipment and Electric System Upgrades

Refer to Sections ___ and ___

Other Utility Infrastructure Costs and Operational Costs

Refer to Section ____.

SOCIETY BENEFITS OF DER

Total Resource Benefit

The societal cost test takes the results from the total resource cost test and adds incremental social costs and benefits.

Reduced Central Station Emissions

Use statewide average emissions reductions for renewable technologies. For fossil technologies assume no improvement or decline relative to central station in the base case.

The benefit of avoided pollution emission can only be applied to those technologies that are either renewable technologies (e.g. solar PV) or non-combustion technologies (e.g. fuel cells). The benefit of avoiding emissions varies depending upon whether emissions are entirely avoided or simply reduced as a result of increased efficiency or non-combustion. Renewable DER technologies avoid all pollutant emissions during their operation whereas non-combustion technologies which employ fossil fuels do emit residual pollutants as part of their generating process. ___ identifies the specific pollutants for which there exist emissions limits that electric generators need to comply with to operate in California. Any new facility construction or major modifications to existing facilities that emit air pollutants must undergo the New Source Review permit process in California. The local air districts are responsible for issuing the permits to facilities that meet the local air quality requirements.

If traditional abatement technologies cannot reduce the emissions below the threshold set in the specific air district, then the generator is responsible for acquiring emission reduction credits (ERCs) to offset their local air impact.

Table 26: Typical (Non-Toxic) Pollutants Regulated in California for Electric Generators

Pollutant Type	Metric
Oxides of Nitrogen (NO _x)	tons/year
Volatile Organic Compounds (VOC)	tons/year
Carbon Monoxide (CO)	lbs/day
Particulate Matter (PM ₁₀)	lbs/day
Sulfur Oxides (SO _x)	lbs/day

Mitigating and managing pollutant emissions represents a significant cost to the generator. Thus, DER customers who install technologies which avoid these costs, benefit both society as a result of reduced air emissions and the utility as a result of specific avoided costs.

The cost and benefit components of these avoided pollution emissions include:

6. Emission reduction credits and offsets
7. Abatement technologies (SCR with ammonia, scrubbers, ancillary equipment)
8. Reduced facility permitting

Emission Reduction Credit Prices

The range of ERC prices for offset emissions is substantial - over \$100,000 range for NO_x, - and represents significant cost exposure for any new energy generator if offsets have to be purchased on the market. ___ shows the price ranges for five different pollutants in the California ERC market during 2002.


Table 27: Range of California ERC Prices for 2002

	NO _x	HC	PM10	CO	SO _x
Average	\$ 35,261	\$ 9,633	\$ 49,327	\$ 27,802	\$ 14,156
Median	\$ 30,000	\$ 8,630	\$ 20,000	\$ 38,356	\$ 7,450
High	\$ 140,000	\$ 70,000	\$ 136,986	\$ 47,397	\$ 65,753
Low	\$ 990	\$ 485	\$ 3,289	\$ 300	\$ 3,289

*Source: California Air Resources Board: Emission Reduction Offsets Transaction Cost Summary Report for 2002

The ERC prices have been increasing over time in California as shown in ____. The prices of NO_x offsets have increase by 154% over the past four years whereas the prices of CO have increased over 800% since 1999. This trend suggests that traditional generation sources could expect to pay higher prices for emissions ERC into the future. Avoiding these direct operating costs for traditional generators characterizes the type of benefits that could accrue to utilities in the form of avoided costs from the installation of DER and especially renewable DER.

Figure 10: Average California ERC Prices 1999 – 2002



*California Air Resources Board: Emission Reduction Offsets Transaction Cost Summary Reports for 2002, 2001, 2000, and 1999

Abatement Equipment Costs

One other direct cost associated with facility emissions is the cost of abatement systems and equipment. For example, for PM10 abatement, this equipment could involve an entire pollution control system of a scrubber (wet/dry), baghouse, fabric collector, or microclone technology. For NOx, the most common abatement technology in use is the selective catalytic reduction (SCR) which requires the introduction of ammonia to act as a catalyst.

If emission pollutants are avoided by installing a renewable DER unit, then pollution abatement costs can be either reduced or eliminated. As an example of the level of abatement costs, several cost estimates for NOx abatement technologies that are currently used by the California Air Board district offices are shown in _____. These cost data were collected directly from manufacturers in 1999 and many of these data are close to today's costs as well to a generator. In any case, pollution abatement costs add to the overall cost of a traditional electricity generator using fossil fuels. Avoiding these costs represents a benefit to the DER owner.

Table 28: Estimated Costs of NOx Abatement Technologies for a 150 MW Facility

Control Technology	\$/ton	cents/kWh
Conventional SCR (9 ppm)	1,938	.117
Water/Steam Injection (42 ppm)	476	0.152
High Temperature SCR (9 ppm)	2,359	0.134
SCONOx (2 ppm)	6,938	0.289
Catalytic Combustion (3 ppm)	371	0.146

*Source: ONSITE SYCOM Energy Corporation Contract No. DE-FC02-97CH10877

Reduced Facility Permitting Costs

The costs of facility siting and permitting are often reduced as a result of DER installation. The cost reduction represents a direct benefit to the DER customer. Renewable, CHP, and non-combustion DER technologies are not as limited in the locations for where these facilities may be sited and the siting process generally takes less time to complete. If the DER installed is exempt from the air permitting requirements, the cost in fees, time, and resources is effectively eliminated. Otherwise, the steps for air permitting generally include:

- Air permit application fees
- Emissions estimates
- Air toxics studies
- Permit to construct
- Emissions testing
- Permit to operate

The direct costs to accomplish each step in the process vary by site but some cost estimates can be identified. ___ shows some of the basic air permit fees associated with permitting different size engines through the South Coast Air Quality Management District (SCAQMD).

Table 29: Example SCAQMD Permit Fees for Engines

Permit Fees for Engines	New Engine	Renewal Fee
All non-emergency engines 50 hp to 500 hp	\$811	\$184
All non-emergency engines >500 hp	\$2088	\$660

*Source: Onsite Power Generation; Southern California Gas Company
http://www.socalgas.com/business/useful_innovations/onsite_generation.shtml#Airquality

Estimates of source testing costs range from \$2000 to \$4000 per test which are required every three years for on-site natural gas engines.

Avoided CO2 Emissions

Carbon Dioxide (CO₂) emissions are not regulated in the United States. The only exception is the State of Oregon, which began to regulate CO₂ emissions in 1997 through the implementation of the Carbon Dioxide Standard legislation. This standard dictates the maximum level of CO₂ emissions that new energy facilities are allowed to emit. Energy facility owners can offset their CO₂ emissions by guaranteeing cogeneration. Alternatively, facility owners can implement an offset program or pay a monetary fee to an external third party (The Oregon Climate Trust) to offset their emissions. The typical price per ton for CO₂ offsets ranges from \$3 to \$12/ton CO₂ emitted. The factors that contribute to individual facility offset costs vary and can include fuel type, plant/equipment efficiency, and hours of operation.

Table 30: Oregon CO₂ Standards for Energy Facilities

Facility Type	CO ₂ Standard
Base load gas plants (only natural gas)	0.0675 lb. CO ₂ /kWh
Non-base load gas plants (all fuels)	0.0675 lb. CO ₂ /kWh
Non-generating facilities	0.504 lb. CO ₂ /horsepower-hour

* from Oregon Office of Energy website: <http://www.energy.state.or.us/siting/co2std.htm>

Since CO₂ is not presently regulated in the U.S. as a pollutant, the direct benefit of reducing CO₂ emissions cannot be realized monetarily from the renewable DER owner perspective. However, if the type of legislation that is instituted in Oregon becomes more prevalent in state air quality regulation, there is a tangible benefit of avoiding CO₂ emissions in the future.

DER Emissions

While central station emissions are greater than the emissions of an individual DER unit, these smaller units do produce operational emissions. Should the penetration level of installed DER increase substantially, however, emission levels from DER technologies could become a problem. ___ shows the average emission rates included in the model for several different DER technologies. These emission rates can vary substantially from the average levels shown below but these values capture the differential impact between major technology classes. As such, the overall societal costs from DER emissions would increase if the penetration of reciprocating engines dramatically increased. However, if solar technologies were installed on a widespread basis, the costs to society would decrease.

Table 31: Emissions Rates for DG Technologies

lb/MWh	N0x	PM10	CO ₂
Diesel Reciprocating Engine	20	0.75	1450
Gas Reciprocating Engine	18.7	0.05	1100
Microturbine	1	0.06	800
Fuel Cell - Low Temp	0.01	0	280
Fuel Cell - High Temp	0.02	0	220
Renewables (Solar/Wind)	0	0	0

SOCIETY COSTS OF DER

Total Resource Cost

The societal cost test takes the results from the total resource cost test and adds incremental social costs and benefits.

DER Emissions

Refer to Section 10.1

Incentives/ Locational Credits

Refer to Section 3.1

APPENDIX 2-1: NATURAL GAS PRICE FORECASTS

CEC Energy Demand Forecast
Table G-7
End Use Natural Gas Price Forecast
PG&E
 Reference Case Price Forecast 02-21-03
 2000 Dollars per MCF

	1	2	3	4	5	6	7	8	9	10
Year	Res	Comm	Indust	Comm	Indust	TEOR	Cogen	EG		System PG&E
1990	6.73	6.64	5.87	3.80	4.13	3.08	3.82	3.82		4.89
1991	6.76	6.75	5.91	3.14	3.29	3.64	3.30	3.30		4.58
1992	6.50	7.10	5.29	3.04	2.43	2.86	3.01	3.01		4.14
1993	6.15	6.58	5.21	3.26	2.41	2.56	3.25	3.25		4.29
1994	6.40	6.62	5.10	3.16	2.15	2.14	2.43	2.43		3.87
1995	6.67	6.73	4.90	2.65	1.94	1.60	2.36	2.36		4.00
1996	6.02	6.01	4.94	3.41	2.42	2.10	2.48	2.48		4.04
1997	6.21	6.22	5.31	2.89	2.83	3.12	2.81	2.81		4.08
1998	6.18	7.45	4.33	3.32	2.66	2.47	2.63	2.63		4.14
1999	7.61	7.59	4.34	3.89	2.87	2.76	2.71	2.71		4.30
2000	8.96	8.95	6.53	6.08	5.31	5.15	5.24	5.23		6.40
2001	9.94	9.87	7.78	7.58	6.81	6.77	6.79	6.79		7.76
2002	6.75	6.68	4.49	4.06	3.24	3.22	3.22	3.22		4.42
2003	6.87	6.81	4.63	4.22	3.41	3.39	3.39	3.39		4.60
2004	6.99	6.93	4.74	4.32	3.51	3.50	3.49	3.49		4.71
2005	6.92	6.86	4.77	4.40	3.61	3.59	3.59	3.59		4.68
2006	7.01	6.95	4.87	4.50	3.70	3.70	3.68	3.68		4.74
2007	7.18	7.11	5.00	4.62	3.80	3.81	3.78	3.78		4.87
2008	7.13	7.07	5.02	4.65	3.85	3.86	3.83	3.83		4.88
2009	7.20	7.13	5.09	4.72	3.92	3.94	3.90	3.90		4.95
2010	7.27	7.21	5.17	4.79	3.99	4.02	3.97	3.97		5.03
2011	7.28	7.22	5.22	4.85	4.07	4.09	4.05	4.05		5.08
2012	7.30	7.24	5.27	4.91	4.14	4.16	4.12	4.12		5.14
2013	7.38	7.32	5.36	4.99	4.22	4.24	4.20	4.20		5.22
2014	7.36	7.30	5.40	5.05	4.30	4.31	4.28	4.28		5.27
2015	7.40	7.35	5.47	5.12	4.38	4.39	4.36	4.36		5.33
2016	7.46	7.40	5.54	5.19	4.46	4.47	4.44	4.44		5.41
2017	7.50	7.44	5.61	5.27	4.54	4.55	4.52	4.52		5.47
2018	7.54	7.48	5.68	5.34	4.63	4.63	4.61	4.61		5.54
2019	7.59	7.54	5.75	5.42	4.71	4.72	4.69	4.69		5.62
2020	7.66	7.60	5.83	5.51	4.80	4.81	4.78	4.78		5.70
2021	7.72	7.67	5.91	5.59	4.89	4.89	4.87	4.87		5.78
2022	7.79	7.73	5.99	5.68	4.98	4.98	4.96	4.96		5.87

**CEC Energy Demand Forecast
Table G-9
End Use Natural Gas Price Forecast
SDG&E**

Reference Case Price Forecast 02-21-03
2000 Dollars per MCF

1	2	3	4	5	6	7	8	9	10
Year	Res	Comm	Indust	Comm	Indust	TEOR	Cogen	EG	System Average
1990	6.74	6.71	6.39	4.63	4.63	-	3.89	3.89	5.06
1991	6.35	6.44	6.41	4.07	4.07	-	3.41	3.41	4.61
1992	6.77	6.99	7.08	4.22	4.22	-	3.36	3.36	4.94
1993	7.18	6.76	7.05	2.70	2.61	-	3.49	3.49	5.10
1994	7.22	5.79	6.33	3.77	4.08	-	3.19	3.19	5.00
1995	6.76	5.58	6.26	2.84	2.87	-	2.28	2.28	4.13
1996	6.83	5.91	6.70	3.29	2.94	-	2.66	2.66	4.56
1997	7.53	6.93	7.84	3.40	3.40	-	3.07	3.07	4.74
1998	7.37	6.28	7.28	2.79	2.79	-	2.78	2.78	4.39
1999	6.91	6.22	4.78	3.34	3.34	-	3.21	3.21	4.49
2000	8.61	8.08	6.48	5.53	5.53	-	5.02	5.02	6.23
2001	11.47	10.82	9.19	7.36	7.36	-	6.90	6.90	8.68
2002	6.98	6.32	4.68	3.79	3.79	-	3.27	3.27	4.54
2003	7.36	6.67	4.96	3.89	3.89	-	3.36	3.36	5.36
2004	7.26	6.61	4.97	3.92	3.92	-	3.45	3.45	5.51
2005	7.41	6.75	5.09	3.98	3.98	-	3.52	3.52	5.72
2006	7.34	6.70	5.12	4.06	4.06	-	3.62	3.62	5.63
2007	7.48	6.83	5.22	4.18	4.18	-	3.74	3.74	5.77
2008	7.62	6.96	5.33	4.29	4.29	-	3.84	3.84	5.86
2009	7.56	6.93	5.35	4.40	4.40	-	3.97	3.97	5.53
2010	7.47	6.87	5.36	4.46	4.46	-	4.05	4.05	5.54
2011	7.54	6.92	5.44	4.54	4.54	-	4.14	4.14	5.60
2012	7.74	7.11	5.60	4.64	4.65	-	4.19	4.19	5.75
2013	7.81	7.19	5.69	4.72	4.72	-	4.27	4.27	5.83
2014	7.93	7.30	5.79	4.81	4.81	-	4.36	4.36	5.93
2015	8.04	7.41	5.90	4.89	4.90	-	4.44	4.44	6.03
2016	8.09	7.47	5.98	4.97	4.97	-	4.52	4.52	6.10
2017	8.09	7.47	5.98	4.99	5.00	-	4.55	4.55	6.12
2018	8.28	7.66	6.17	5.14	5.14	-	4.69	4.69	6.29
2019	8.38	7.76	6.27	5.22	5.22	-	4.77	4.77	6.38
2020	8.43	7.82	6.35	5.30	5.30	-	4.83	4.83	6.44
2021	8.49	7.89	6.44	5.37	5.37	-	4.92	4.92	6.52
2022	8.55	7.96	6.52	5.45	5.45	-	5.00	5.00	6.60

GLOSSARY

B/C Ratio	Benefit/Cost Ratio
CALMAC	California Measurement Advisory Committee
CEC	California Energy Commission
CHP	Combined Heat and Power
CPUC	California Public Utilities Commission
DER	Distributed Energy Resources
EIA	Energy Information Administration
EUE	Expected Unserved Energy
HVAC	Heating Ventilation and Air Conditioning
IOU	Investor Owned Utility
MDCC	Marginal Distribution Capacity Cost
NP15	North of Path 15
PG&E	Pacific Gas and Electric
PUC	Public Utilities Commission
REC	Renewable Energy Credits
RIM	Rate-payer Impact Measure
SAIDI	System Average Interruption Duration Index
SAIFI	System Average Interruption Frequency Index
SCADA	Supervisory Control and Data Acquisition
SDG&E	San Diego Gas and Electric
SCE	Southern California Edison
SGIP	Self-Generation Incentive Program
SP15	South of Path 15
T&D	Transmission and Distribution
TRC	Total Resource Cost
UDC	Utility Distribution Company
UPS	Uninterruptible Power Supply