


FIRE DEPARTMENT
CITY AND COUNTY OF HONOLULU

3375 KOAPAKA STREET, SUITE H425 • HONOLULU, HAWAII 96819-1869
TELEPHONE: (808) 831-7761 • FAX: (808) 831-7750 • INTERNET: www.honolulufire.org



JEREMY HARRIS
MAYOR



ATTILIO K. LEONARDI
FIRE CHIEF

JOHN CLARK
DEPUTY FIRE CHIEF

September 21, 2004

Mr. Carlito Caliboso, Chairman
State of Hawaii
Public Utilities Commission
465 South King Street, Room 103
Honolulu, Hawaii 96813

Dear Mr. Caliboso:

Subject: Draft Environmental Assessment (DEA)
Project: East Oahu Transmission Project
46kV Phased Project
Location: Honolulu, Oahu, Hawaii
Tax Map Key: Zone 2, Various Plots and Parcels

We received a letter from Lesley A. Matsumoto of Belt Collins Hawaii Ltd., dated August 30, 2004, requesting that our comments on the above-mentioned DEA be submitted to you.

The Honolulu Fire Department requires that the following be complied with for the duration of the project:

1. Maintain fire apparatus access throughout the construction site.
2. Notify the Fire Communication Center at 523-4411 regarding any interruption of the existing fire hydrant system.

Should you have any questions, please call Battalion Chief Lloyd Rogers of our Fire Prevention Bureau at 831-7778.

Sincerely,

ATTILIO K. LEONARDI
Fire Chief

AKL/SK:bh

cc: Lesley A. Matsumoto, Belt Collins Hawaii Ltd.

PUBLIC UTILITIES
COMMISSION

SEP 24 10 25 AM '04

FILED