

DIVISION	UNIT	BUILDING NAME	STREET ADDRESS	CITY/TOWN	ZIP CODE	BUILDING MANAGER & PHONE NUMBER (DAGS OR IF PRIVATE, GIVE NAME)
BESSD	Oahu Branch & Neighbor Island Branch Administration	Haseko Center	820 Miliilani Street, Suite 710	Honolulu	96813	PM Realty Group/Corinne Sakazaki 550-8383
BESSD	Nuuanu	Ka Hale O Kameha'ikana	1485 Linapuni Street, Suite 124	Honolulu	96819	Urban Management/Tiva Aga 832-6016
BESSD	Kuakini	Waiakamilo Business Center	420 Waiakamilo Road, Suite 117C	Honolulu	96817	CB Richard Ellis/Mike Cox 541-5134 Management Office 521-1200
BESSD	Palama, Kalihi, Moanalua, Kinau, Kapalama	Waiakamilo Business Center	420 Waiakamilo Road, Suite 101	Honolulu	96817	CB Richard Ellis/Mike Cox 541-5134 Management Office 521-1200
BESSD	Punawai, Makiki, Pawaa	Pohulani Elderly Housing	677 Queen Street, Suite 400B	Honolulu	96813	HCDCH/Bill 586-5338
BESSD	Child Care Connection HI Office 1, Downtown FTW 2	Pohulani Elderly Housing	677 Queen Street, Suite 400A	Honolulu	96813	HCDCH/Bill 586-5338
BESSD	Social Work Office, Quality Assurance Office	O R & L Building	333 North King Street, Room 101	Honolulu	96817	DAGS
BESSD	Pauahi	O R & L Building	333 North King Street, Room 201	Honolulu	96817	DAGS
BESSD	Iwilei	O R & L Building	333 North King Street, Room 200	Honolulu	96817	DAGS
BESSD	Downtown FTW 1	O R & L Building	333 North King Street, Room 100	Honolulu	96817	DAGS
BESSD	Central Files	Kakuhihewa Building	601 Kamokila Blvd., Room 262	Kapolei	96707	DAGS
BESSD	Ewa & Waipahu	Kakuhihewa Building	601 Kamokila Blvd., Room 106	Kapolei	96707	DAGS
BESSD	Nanakuli	Kakuhihewa Building	601 Kamokila Blvd., Room 117	Kapolei	96707	DAGS
BESSD	Waianae FTW	Kakuhihewa Building	601 Kamokila Blvd., Room 138	Kapolei	96707	DAGS
BESSD	Kamokila	Kakuhihewa Building	601 Kamokila Blvd., Room 468	Kapolei	96707	DAGS

BESSD	Waipahu FTW	Waipahu Civic Center	94-275 Mokuola Street, Room 105	Waipahu	96797	DAGS
BESSD	Child Care	Waipahu Civic Center	94-275 Mokuola Street, Room 203	Waipahu	96797	DAGS
	Connection HI					
	Office 2					
BESSD	Waialeale	Waipahu Civic Center	94-275 Mokuola Street, Room 303	Waipahu	96797	DAGS
BESSD	West Oahu	Waipahu Civic Center	94-275 Mokuola Street, Room 303A	Waipahu	96797	DAGS
BESSD	Waianae	Cathay Commerical Center	86-088 Farrington Hwy., Suite 101	Waianae	96792	Lambert Lau (Building owner) 696-9477
BESSD	Ka'ala	Cathay Commerical Center	86-088 Farrington Hwy., Suite 106	Waianae	96792	Lambert Lau (Building owner) 696-9477
BESSD	Wahiawa	Wahiawa Civic Center	929 Center Street	Wahiawa	96786	DAGS
BESSD	Wahiawa FTW		1008 California Avenue, Building B	Wahiawa	96786	GMR (Graham, Murata & Russell)/David Yamada 524-5151
BESSD	Kailua FTW	Kailua Business Center	354 Uluniu Street, Room 401	Kailua	96734	50th State Management Corp./Monique Yap 263-1234
BESSD	Waikalua	Kaneohe Civic Center	45-260 Waikalua Road	Kaneohe	96744	DAGS
BESSD	Windward	Kaneohe Atrium	46-005 Kawa Street, Room 307	Kaneohe	96744	Merle (member of Yim family who owns this building) cell: 223-5486
BESSD	Kaneohe & Kailua		45-513 Luluku Road	Kaneohe	96744	Janis Chun (Building owner) 235-4390 Janis' cell: 384-2486

DIVISION	UNIT	BUILDING NAME	STREET ADDRESS	CITY/TOWN	ZIP CODE	BUILDING MANAGER & PHONE NUMBER (DAGS OR IF PRIVATE, GIVE NAME)
BESSD	North Hilo IM Units I, II and III	Kulana Naauao	13 Kekaulike Street	HILO	96720	DAGS
BESSD	South Hilo IM Units I, II and III	Kinoole Shopping Plaza	1990 Kinoole Street	HILO	96720	Glenn Kaneshiro 959-0524
BESSD	Kamuela-Hamak Unit	Honokaa State Office Building	45-3380 Mamane Street	HONOKAA	96727	DAGS
BESSD	Kohala Sub Unit	Kohala State Office Building	54-3900 Akoni Pule Highway	KAPAAU	96755	DAGS
BESSD	North Kona I	Anthurium Building	75-5995 Kuakini Highway	KAILUA-KONA	96740	Margaret Takata 331-8585
BESSD	North Kona II	Kona Center	75-5722 Hanama Place	KAILUA-KONA	96740	Patti Kieman 329-5999
BESSD	South Kona	Captain Cook Civic Center	82-6130 Mamalahoa Highway	CAPTAIN COOK	96704	DAGS
BESSD	Kau Sub Unit	Naalehu Civic Center	95-5669 Mamalahoa Highway	NAALEHU	96772	DAGS
BESSD	Maui Section		1955 Main Street	WAILUKU	96793	Kathy Sherman 243-8600
BESSD	Central Maui Unit	Waiehu Beach Center	270 Waiehu Beach Road	WAILUKU	96793	Haleakala Group 244-9766
BESSD	West Maui I, II	Lunalilo Building	35 Lunalilo Bldg	WAILUKU	96793	Steve Walker

						270-9120
BESSD	East Maui I, II	Wailuku State Office Building	54 High Street	WAILUKU	96793	DAGS
BESSD	Molokai Unit	Kauanakakai Civic Center	55 Makaena Place	KAUNAKAKAI	96748	DAGS
BESSD	Lanai Sub Unit		730 Lanai Avenue	LANAI	96763	Mae Ulep 565-4802
BESSD	South Unit	Dynasty Court	4473 Pahee Street	LIHUE	96766	Dixie Daniel 246-0334 or 651-0059
BESSD	Central Unit	Lihue State Office Building	3060 Eiwa Street	LIHUE	96766	DAGS
BESSD	East Unit	East Kauai Professional Building	4-1579 Kuhio Highway	KAPAA	96746	Dorothy Aiwohi 792-3055 or 295-6348

BUILDING NAME	STREET ADDRESS	CITY/TOWN	ZIP CODE	BUILDING MANAGER & PHONE NUMBER (DAGS OR IF PRIVATE, GIVE NAME)
Kakuhihewa State Office Building	601 Kamokila Blvd., 5th Floor, Room 518 Rooms 506A & B	Kapolei, HI	96707-2021	DAGS Richard Arakaki, 808-586-0537
Campbell Estate Kapolei Building	1001 Kamokila Blvd., Room 317 1001 Kamokila Blvd., Rooms 300 & 313	Kapolei, HI	96707-2005	Colliers, Monroe, Friedlander Jennifer Bradley, 808-523-8322
Kakuhihewa State Office Building	601 Kamokila Blvd., Room 415	Kapolei, HI	96707-2021	DAGS Richard Arakaki, 808-586-0537
801 Dillingham Blvd.	801 Dillingham Blvd., 3rd Floor	Honolulu, HI	96817	Private, Castle & Cooke Commercial, Inc. Berta Herndon, 808-548-3748
Waiakea Kai Shopping Plaza	88 Kanoelehua Ave., Room 107	Hilo, HI	96720-4670	Private, Knight Corporation Pegge Rawlins, 1-808-681-9118
Lanikai Professional Building	75-5591 Palani Road, Suite 3004	Kailua-Kona, HI	96740-3633	Private, Frame 10 A Hawaii Ltd. Partnership by WLW Development Methods, Inc. William L. Wong, 1-808-329-0911
Dynasty Court Building	4473 Pahee Street, Suite A	Lihue, HI	96766-2037	Private, Dynasty Court, LLC. Dixie Daniels, 1-808-246-0334/1-808-822-5010
Wells Professional Building	2145 Wells Street, Room 103	Wailuku, HI	96793-2225	Private, Ohiana Property Management John Sullivan, 1-808-244-7684
State Civic Center	65 Makaena Place, Room 110	Kaunakakai, HI	96748-0169	DAGS Peter Ward, 1-808-553-5233
Old Administrative Building	730 Lanai Avenue	Lanai City, HI	96763	Private, Castle & Cooke Properties May Ulep, 1-808-565-4802

09	total	2004	Federal 2005	Portion 2006	Projection 2007	2008	2009	total
	0.00							0.00
	0.00							0.00
	0.00							0.00
	0.00							0.00
	0.00							0.00
	24,705.45	7,341.05	5,505.79					12,846.83
	0.00							0.00
	0.00							0.00
	300,062.73	6,546.82	6,546.82	4,910.12				18,003.76
	152,711.46	24,433.83	24,433.83	18,325.38				67,193.04
	131,577.60	47,846.40	47,846.40	35,884.80				131,577.60
	195,705.18							0.00
	0.00							0.00
	0.00							0.00
	0.00							0.00
	0.00							0.00
	0.00							0.00
	0.00							0.00
	0.00							0.00
	36,692.95	10,819.18	4,958.79					15,777.97

Department of Human Services
Lease Schedule
Period Ending FY 2004

DAGS LS#	UNIT	LESSOR	LOCATION	LEASE PERIOD OR					GEN %	FED %	Expenditure					total	Federal					total
				AREA	TERM END	RENT	2004	2005			2006	2007	2008	2009	2004		2005	Portion 2006	Projection 2007	2008	2009	
S91-33-0481	SSD/EH CWS III	John V. Bellman	Pahoa Village Center Building F, Space B, C Pahoa, Hawaii 96778	2,100	07/01/02-07/07/02	724.50	100.00%	0.00%							0.00							0.00
					07/08/02-10/14/05	1,449.00	100.00%	0.00%	17,388.00	6,520.50					23,908.50							0.00
					10/15/05-06/30/07	1,554.00	100.00%	0.00%		11,655.00	18,648.00	18,648.00			48,951.00							0.00
S92-33-0096	SSD, ACCSB, CWSB, SSO, FRPS, MIC, POS, SOU, MWS	250 Queen Street Investment Co	City Center 810 Richards St. 4th & 5th Floors Honolulu, Hawaii 96813	12911	04/30/04		66.00%	34.00%							0.00							0.00
					06/01/99-07/31/99	10,936.50	66.00%	34.00%							0.00							0.00
					08/01/99-05/31/02	19,366.50	66.00%	34.00%							0.00							0.00
					06/01/02-05/31/03	20,012.05	66.00%	34.00%							0.00							0.00
					06/01/03-04/30/04	20,528.49	66.00%	34.00%	205,284.90						205,284.90	69,796.87						69,796.87
S92-33-0184	SSS, LCWSS, DHCWSS, CCWSS	Trustees of the Estate of BPB	Waiakamilo Business Center 420 Waiakamilo Road Suite 300B Honolulu, Hawaii 96817	17,319	04/01/99-02/29/04	12,989.25	65.00%	35.00%	103,914.00						103,914.00	36,369.90						36,369.90
S92-33-0406	SSD/ACCSB/ SCP	CUNA Mutual Investment Corp.	One Kapiolani Bldg 600 Kapiolani Blvd., 3rd floor Honolulu, Hawaii 96813	2009	06/06/05		72.00%	28.00%							0.00							0.00
					08/07/00-08/06/01	1,004.50	72.00%	28.00%							0.00							0.00
					08/07/01-06/06/05	2,009.00	72.00%	28.00%	24,108.00	22,099.00					46,207.00	6,750.24	6,187.72					12,937.96
S92-33-0449	SSD/OCWSS 2/ACM II	Lambert/Susan Lau	86-090 Farrington Hwy Suite 201 Waianae, HI 96792	3404	12/1/98 - 11/30/01	3,835.23	0.00%	100.00%							0.00							0.00
					12/1/01-10/31/03	3,939.59	0.00%	100.00%	15,758.36						15,758.36	15,758.36						15,758.36
S92-33-0493	DHCWSS, CCWSS, OACCS	Trustees of the Estate of BPB	Waiakamilo Business Center 420 Waiakamilo Road Suite 300A Honolulu, Hawaii 96817	16,090	04/01/99-02/29/04	12,067.25	65.00%	35.00%	96,538.00						96,538.00	33,788.30						33,788.30
S94-33-0260	SSD/East/ Kauai/CWS	East Kauai Properties, LLC	Kauai East Professional & Commercial Center 4-1579 Kuhio Hwy. No. 106 Kapaa, Hawaii 96746	2200	05/01/04-04/30/07	2,310.00	100.00%	0.00%	4,620.00	27,720.00	27,720.00	23,100.00			83,160.00							0.00
					05/01/07-03/31/09	2,376.00	100.00%	0.00%				4,752.00	28,512.00	21,384.00	54,648.00							0.00
S94-33-0462	SSD/ACCS Kauai	Watumull Sons	Kukui Grove Executive Center 4370 Kukui Grove St. Suites 203, 204, 205 Lihue, Hawaii 96766	2400	12/01/99-11/30/01	1,392.00	100.00%	0.00%							0.00							0.00
					12/01/01-11/30/03	1,488.00	100.00%	0.00%	7,440.00						7,440.00							0.00
					12/01/03-10/31/04	1,584.00	100.00%	0.00%	11,088.00	6,336.00					17,424.00							0.00
S95-33-0233	SSD/Maui ACCS/Adm., NHWW	Tavares, Edmond J. & Edwina A.	1733 Wilipa Loop Wailuku, Maui, Hawaii 96793	2403	07/01/02-06/30/05	3,123.90	100.00%	0.00%	37,486.80	37,486.80					74,973.60							0.00
					07/01/05-05/31/07	3,244.05	100.00%	0.00%			38,928.60	35,684.55			74,613.15							0.00
S95-33-0289	SSD/Maui CWS	Main Street Partnership	1955 Main St. Suite 300 Wailuku, Maui, Hawaii 96793	638	2/1/2003-12/31/07	957.00	60.00%	40.00%	11,484.00	11,484.00	11,484.00	11,484.00	5,742.00		51,678.00	4,593.60	4,593.60	4,593.60	4,593.60	2,296.80		20,671.20
S95-33-0404	SSD/Maui CWS I, II	S/2C Family Limited Partnership	1885 Main Street, Suites 303 - 306 Wailuku, Hawaii 96793	4657	03/01/02-6/30/05	9,127.72	100.00%	0.00%	109,532.64	109,532.64					219,065.28							0.00

Department of Human Services
Lease Schedule
Period Ending FY 2004

DAGS LS#	UNIT	LESSOR	LOCATION	LEASE PERIOD OR		RENT	GEN %	FED %	2004	Expenditure	For Fiscal	Year Ending	2008	2009	total	2004	Federal	Portion	Projection	2008	2009	total	
				2005	2006					2007	2005	2006					2007						
B92-33-0494	OBS1-Kuakini	Trustees of the Estate of BPB	Waiakamilo Business Center 420 Waiakamilo Road Suite 117 Honolulu, Hawaii 96817	14,744	04/01/99-02/29/04	11,058.00	65.00%	35.00%	88,464.00						88,464.00	30,962.40							30,962.40
B92-33-0495	OBS1-Kalihi, Kapalama, Kinau, Palama, WHAU	Trustees of the Estate of BPB	Waiakamilo Business Center 420 Waiakamilo Road Suite 101 Honolulu, Hawaii 96817	10,873	04/01/99-02/29/04	8,154.75	65.00%	35.00%	65,238.00						65,238.00	22,833.30							22,833.30
B92-33-0509	OBS1-Nuuanu	HCDC of Hawaii	Ka Hale O Kameha'ikana 1485 Linapuni St. Suites 122A, 124 Honolulu, HI 96819	3,141	06/01/03-05/31/06	1,570.50	52.00%	48.00%	18,846.00	18,846.00	17,275.50				54,967.50	9,046.08	9,046.08	8,292.24					26,384.40
					06/01/06-05/31/07	1,633.32	52.00%	48.00%			1,633.32	17,966.52			19,599.84			783.99	8,623.93				9,407.92
					06/01/07-04/30/08	1,696.14	52.00%	48.00%			1,696.14	16,961.40			18,657.54				814.15	8,141.47			8,955.62
B94-33-0122	BESSD/NIB Kauai East IM	East Kauai Properties, LLC	East Kauai Professional Bldg. 4-1579 Kuhio Hwy Suite 101 Kapaa, Hawaii 96746	2,182	05/01/04-04/30/07	2,291.10	57.00%	43.00%	4,582.20	27,493.20	27,493.20	22,911.00			82,479.60	1,970.35	11,822.08	11,822.08	9,851.73				35,466.23
					05/01/07-03/31/09	2,356.56	57.00%	43.00%				4,713.12	28,278.72	21,209.04	54,200.88				2,026.64	12,159.85	9,119.89		23,306.38
B94-33-0126	BESSD/West Kauai IM	Sakahashi, Miyoko & Shigemi	1-3491 Kaunualii Hwy. Hanapepe, Kauai, Hawaii 96716	2625	09/01/99-08/31/00	1,865.00	57.00%	43.00%							0.00								0.00
					09/01/00-08/31/02	1,958.25	57.00%	43.00%							0.00								0.00
					09/01/02-07/31/04	2,051.50	57.00%	43.00%	24,618.00	2,051.50					26,669.50	10,585.74	882.15						11,467.89
B94-33-0371	BESSD/NIB Kauai/Adm., FTW	Dynasty Developments	Dynasty Court 4473 Pahee Street Units E, F, G, & H Lihue, Hawaii 96766	3664	09/01/03-08/31/06	4,873.12	39.00%	61.00%	48,731.20	58,477.44	58,477.44	9,746.24			175,432.32	29,726.03	35,671.24	35,671.24	5,945.21				107,013.72
					09/01/06-07/31/08	4,946.40	39.00%	61.00%				49,464.00	59,356.80	4,946.40	113,767.20				30,173.04	36,207.65	3,017.30		69,397.99
B94-33-0461	BESSD/INVO Kauai	Watumull Sons	Kukui Grove Executive Center 4370 Kukui Grove St., Suite 103 Lihue, Hawaii 96766	750	12/01/99-11/30/01	435.00	43.00%	57.00%							0.00								0.00
					12/01/01-11/30/03	465.00	43.00%	57.00%	2,325.00						2,325.00	1,325.25							1,325.25
					12/01/03-10/31/04	495.00	43.00%	57.00%	3,465.00	1,980.00					5,445.00	1,975.05	1,128.60						3,103.65
B95-33-0124	BESSD/NIB/ West Maui/ IM I, II	Gulsons, LLC	Ting Lunaillo Building 35 Lunaillo St. #300 Wailuku, Maui, Hawaii 96793	4652	5/1/2004-04/30/07	6,373.24	57.00%	43.00%	12,746.48	76,478.88	76,478.88	63,732.40			229,436.64	5,480.99	32,885.92	32,885.92	27,404.93				98,657.76
					05/1/07-03/31/09	6,605.84	57.00%	43.00%				13,211.68	79,270.08	59,452.56	151,934.32				5,681.02	34,086.13	25,564.60		65,331.76
B95-33-0299	BESSD/INVO Maui	Gaylord, George S. Trust & Gertrude	33 Market St. Suite A101 Wailuku, Maui, Hawaii 96793	745	Mo. - Mo. 07/31/95	1,229.25	55.00%	45.00%							0.00								0.00
B95-33-0342	BESSD/NIB Maui/Adm., FTW	Waihui LLC	Waiehu Beach Center 270 Waiehu Beach Rd Suites 107 & 108 Wailuku, Hawaii 96793	4380	09/01/03-08/31/06	5,212.20	50.00%	50.00%	10,424.40	62,546.40	62,546.40	10,424.40			145,941.60	5,212.20	31,273.20	31,273.20	5,212.20				72,970.80
					09/01/06-07/31/08	5,387.40	50.00%	50.00%				53,874.00	64,648.80	5,387.40	123,910.20				26,937.00	32,324.40	2,693.70		61,955.10
B95-33-0505	BESSD/NIB Maui Adm., Closed Files	1955 Main St. Partnership	1955 Main St. Suite 302 Wailuku, Maui, Hawaii 96793	1,810	01/01/03-11/30/07	2,715.00	60.00%	40.00%	32,580.00	32,580.00	32,580.00	13,575.00			111,315.00	13,032.00	13,032.00	13,032.00	5,430.00				44,526.00

ADA SELF-EVALUATION SUMMARY OF INACCESSIBLE FEATURES AND PROGRAM ACCESS OPTIONS

FACILITIES/ADDRESS	INACCESSIBLE FEATURES	PROGRAM ACCESS OPTIONS
Wells Street Professional Center 2145 Wells Street Wailuku, HI	<ul style="list-style-type: none"> • Elevator: Call buttons too high. • Restrooms: Toilet stall too narrow and water closet too high (20). 	Staff shall ensure that persons with disabilities are notified of the inaccessible features of facility. Outreach services, telephone contact, and other services shall be provided to ensure equal access to program.
Fujimoto Building 224 Haili Street Hilo, HI	<ul style="list-style-type: none"> • Parking: No accessible parking stalls and appropriate signage. • Accessible Route: No access route to office. • Program Office: No tactile or braille signage for main door. • Restrooms: No signage, door entry too narrow, opening force exceeds 5 lbs., door hardware non-compliant, toilet stall too narrow, no grab bars, lavatory hardware needs to be replaced, no insulation on pipes. 	Persons with disabilities shall be informed of the office's inaccessible elements. Outreach services shall be provided to ensure equal access to services.
Ace/Foodland Building 218 Kalahiki St. Naalehu, HI	<ul style="list-style-type: none"> • Parking: No accessible parking or signage. • Accessible Route: No marked route from paved parking area. • Building Entrance: Inaccessible. • Program Office: There are stairs that lead to front door of office. No ramp. • Restroom: Restroom located inside office. Restroom is non-compliant. 	Outreach services shall be provided by the Kau Social Services Unit.
Waiakea Kai Shopping Plaza 88 Kanoelehua Ave. Room 107 Hilo, HI	<ul style="list-style-type: none"> • Parking: There are four accessible parking stalls, two have no access route to office without crossing traffic. Another stall, individual would have to cross through a loading zone. Parking signage needed. • Accessible Route: Ramp from parking needs to be replaced. • Elevator: Not in compliance, too narrow, no accessible interior call buttons. • Restrooms: Located on 2nd floor only. No signage. Threshold too high, toilet stall too narrow, no rear grab bars in stall, no pipe insulation, lavatory hardware not ADA compliant, paper towel dispenser too high. • Program Office: No tactile signage on office door. 	Persons with disabilities shall be informed of the office's inaccessible features. When participants with mobility impairments inform the program that they are unable to visit the office, other arrangements shall be made to ensure program access.
Bank of Hawaii Hilo Building 120 Pauahi Street Rm. 210 Hilo, HI	<ul style="list-style-type: none"> • Restrooms: Signage needs to be provided. • Program Office: Door opening force exceeds 5 lbs. Tactile signage on latch side of door needs to be provided. 	For the most part, this facility is accessible.

FACILITIES/ADDRESS	INACCESSIBLE FEATURES	PROGRAM ACCESS OPTIONS
<p>Lanai Office Building 730 Lanai Ave., Ste. 5 Lanai City, HI</p>	<ul style="list-style-type: none"> • Parking: There are no marked parking stalls in front of building. Need accessible parking and appropriate signage. • Accessible Route: Need handrails for ramp as slope exceeds 5%. No exterior signage on building. • Restrooms: No signage, door too narrow, toilet stall too narrow, no grab bars, no accessible lavatory (no knee clearance), no insulation on pipes, paper towel dispenser too high. • Program Office: No signage on office door, no turnaround space. 	<p>Program office is currently negotiating for a larger office space within the same complex. The larger space will address the 60" turnaround radius required inside office. To address the structural barriers, staff shall ensure that persons with disabilities who are unable to visit the office, are provided with a level of access equal to those individuals without disabilities.</p>
<p>Harbor Center 98-030 Hekaha St. Aiea, HI</p>	<ul style="list-style-type: none"> • Accessible Route: Not enough passing space on route to office (route distance exceeds 200 ft.). • Elevator: No hall lanterns, no raised or braille characters, door protective/re-opening device not provided. • Restrooms: Door too narrow, water closet too low, flush mechanism not ADA compliant, no grab bars, no knee clearance for lavatory, no insulation on pipes, paper towel dispenser too high. • Program Office: Door has no signage, threshold too high, door force exceeds 5 lbs. 	<p>The program will accommodate participants in other locations, if necessary, for meetings, appointments, training, etc. Participants are notified in writing of the availability of accommodations, if needed.</p>
<p>Dynasty Court 4473 Pahee St. Lihue, HI</p>	<ul style="list-style-type: none"> • Restrooms: No signage, flush mechanism on top (hard to flush with closed fist), mirror too high. • Program Office: No tactile signage for office door. 	<p>Persons with disabilities shall be informed of inaccessible elements. The program shall ensure that services are provided through alternate methods, to ensure program accessibility.</p>
<p>Kauai East Professional & Commercial Center 4-1579 Kuhio Hwy. Kapaa, HI</p>	<ul style="list-style-type: none"> • Parking: Stall width too narrow, no van accessible signage. • Accessible Route: Insufficient passing space on route to office. Directional signage not provided at front of building indicating accessible entrance through back of building. • Restrooms: There are no restrooms available to the public. • Program Offices: There are two DHS offices located in this facility. Thresholds for both office doors too high. Door opening force exceeds 5 lbs. For Room 101, not enough approach clearance. 	<p>Room 101, an Income Maintenance Unit shall make appropriate arrangements for persons with disabilities to ensure equal access. Home visits, telephone contact, and the use of authorized representatives, shall continue to be alternate methods of providing services.</p> <p>Room 106, a Child Welfare Services Unit shall provide outreach services to the community.</p>
<p>1-3491 Kaunualii Hwy. Hanapepe, HI</p>	<ul style="list-style-type: none"> • Parking: No marked accessible parking or signage. • Accessible Route: No accessible route to office, non-compliant ramp. • Restrooms: Door too narrow, non-compliant door hardware, water closet too low, flush mechanism not on wide side, no grab bars, no insulation. • Program Office: No signage, improper door hardware, threshold too high, opening force exceeds 5 lbs. 	<p>The program is planning to obtain a new state vehicle in which to make home visits, as the site is not accessible to persons with mobility impairments. Staff will continue to conduct telephone interviews, and interviews with authorized representatives on behalf of clients.</p>

FACILITIES/ADDRESS	INACCESSIBLE FEATURES	PROGRAM ACCESS OPTIONS
1009 California Ave., B101 Wahiawa, HI	<ul style="list-style-type: none"> • Parking: Stall too narrow, width of access aisle too narrow, no connection to route to office, no signage in parking lot. • Restrooms: No signage, door hardware needs to be replaced, water closet too low, rear grab bar needs to be replaced, lavatories not accessible. • Program office - No tactile character signage, no front approach clearance (on slope). 	As necessary, appointments will be held in alternate locations more conducive to clients' needs. At point of intake, clients are informed of the availability of accommodations, if needed.
45-513 Luluku Road Kaneohe, HI	<ul style="list-style-type: none"> • Parking: Stall too narrow, access aisle slope too steep, no signage. • Restrooms: No signage at door indicating restroom accessibility, door too narrow, door hardware needs to be replaced, water closet too low, too close to side wall, rear grab bars need to be replaced, toilet paper dispenser too far away from rear wall, mirror too high, not enough knee clearance for lavatory, no insulation on pipes. • Program Office: No tactile signage at front door. 	As necessary, appointments will be held in alternate locations to accommodate the clients' needs.
801 Dillingham Blvd. Honolulu, HI 96817	<ul style="list-style-type: none"> • Parking: Surface slopes exceed 2%, no van accessible signage. • Accessible Route: Ramp - level landing not provided, edge protection not provided, height of handrails too low. • Elevator: Hall lanterns are not provided, raised or braille characters not provided. • Restrooms: No signage, door opening force exceeds 5 lbs., water closet too far away from nearest side wall, urinal not in compliance (too high), no knee clearance for lavatory, no insulation on pipes. 	Plans to renovate are currently being negotiated with the landlord. Inaccessible elements identified in this survey will be addressed during renovations. During the interim, clients will be assured equal access to services through the provision of reasonable modifications to the program. Clients who are unable to visit the office, will be provided services through alternate means, such as through outreach services, telephone contact or through the use of authorized representatives.
888 N. King St. Honolulu, HI	<ul style="list-style-type: none"> • Parking: No van accessible stall, no signage at head of stall, access aisle does not connect to route to accessible entrance. • Accessible Route: Parking stall does not connect to accessible route. Curb ramp - running slope too steep. • Restroom: No 12" latch clearance to doorway, tile floor not level at side of water closet, rear grab bar needs to be replaced, lavatory too high, no insulation on pipes, mirror too high. • Program Office: No signage (including directional, raised and braille signage). Back door needs sign for buzzer. 	Landlord currently working on restriping parking area to designate accessible stall closer to accessible entrance. A buzzer already in place for use by person requesting assistance, and staff assist persons with disabilities through back entrance. If a person is unable to visit the office, home visits, telephone interviews, etc., will be conducted to ensure program access.
Cathay Commercial Center 86-088 Farrington Hwy. Waianae, HI	<ul style="list-style-type: none"> • Parking: No vehicle or van signage. • Restrooms: Toilet stall too narrow, no rear grab bars. • Program Office: No tactile or braille signage. 	There are two offices within this building. Staff within each office shall inform persons with disabilities of the building's inaccessible features. As indicated above, modifications will be provided as necessary to accommodate clients' needs.

FACILITIES/ADDRESS	INACCESSIBLE FEATURES	PROGRAM ACCESS OPTIONS
Hawaii Medical Association Bldg. 1360 Beretania Street Honolulu, HI	<ul style="list-style-type: none"> • Parking: The designated parking stall does not meet ADAAG. Arrangements have been made with City Bank (adjacent to HMA Bldg.) to use van accessible stall. Sign at HMA's parking entrance is needed to alert drivers as to the location of the accessible stall. • Accessible Route: No marked accessible route from City Bank parking to HMA Building. • Elevator: No raised braille or tactile call buttons. Raised and braille sign not provided on both jambs at the elevator entrance. Call box need to be fixed for easier opening. • Restrooms: Toilet stalls too narrow, water closet too far away from nearest wall, no rear grab bars, paper towel dispenser in men's restroom is too high, lavatory needs to be changed or removed to allow turning clearance. For men's restroom, urinal needs to be relocated to allow for turning clearance. Threshold needs to be beveled. Signage on door needs to be replaced. • Program Office: Door opening force exceeds 5 lbs., no braille and raised signage. 	<p>There are two VR offices located on the 4th and 5th floors of this building. Although the program will be addressing the structural barriers with the landlord, steps will be taken to ensure that program access is a priority. Outreach services shall be provided by VR counselors for those clients who are unable to access this facility.</p>
	<ul style="list-style-type: none"> • 	
	<ul style="list-style-type: none"> • 	
	<ul style="list-style-type: none"> • 	

FACILITIES/ADDRESS	INACCESSIBLE FEATURES	PROGRAM ACCESS OPTIONS
<p>Kaneohe Civic Center 45-260 Waikalua Road Kaneohe, HI</p>	<ul style="list-style-type: none"> • Parking: Existing parking stall surface is not level, no vehicle signage, no van accessible space or signage. • Accessible Route: Need new built-up curb ramp. Walkway non-compliant. • Building Entrance: No signage, door too narrow. • Restrooms: No accessible signage, door opening too narrow, no turning clearance, lavatory non-compliant, mirror too high, need new paper towel dispenser, urinal non-compliant, toilet stalls too narrow, water closet non-compliant, need to replace grab bars, need to change soap dispenser. • Program Office: No accessible signage, door too narrow, door hardware needs to be replaced. 	<p>DAGS will address structural barriers. During the interim, program shall ensure equal access to services to persons with disabilities through home visits, telephone contact, or through the use of authorized representatives.</p>
<p>Kaunakakai Civic Center 55 Makaena Place Kaunakakai, HI</p>	<ul style="list-style-type: none"> • Parking: No van accessible stall or van signage. • Building Entrance: No signage. • Restrooms: No accessible signage, door-opening force exceeds 5 lbs., lavatories too low, no insulation on lavatory pipes. • Program Office (MOD): No accessible signage, need to replace door closure with 5 lbs. force type. 	<p>DAGS will address inaccessible elements. Program will ensure that services are provided to persons with disabilities at a level equal to those provided persons without disabilities.</p>
<p>Kona State Office Bldg. 2 82-6130 Mamalahoa Hwy. Captain Cook, HI</p>	<ul style="list-style-type: none"> • Parking: No van accessible stall, access aisle too narrow. • Accessible Route: Curb ramp slope does not comply. • Building Entrance: No accessible signage. • Restrooms: No accessible signage, toilet stalls too narrow, lavatories non-compliant, mirror too high, water closet too high, no 60" turnaround radius. • Program Offices (BESSD/VR): No accessible signage, door hardware does not comply. 	<p>DAGS will address inaccessible elements in its transition plan. Program will continue to make reasonable program modifications to service persons with disabilities. Services such as home visits, telephone contact, and meeting in alternate accessible locations shall be provided to persons with disabilities.</p>
<p>Kona Former District Court 82-6130 Mamalahoa Hwy. Captain Cook, HI</p>	<ul style="list-style-type: none"> • Program Office: No accessible signage. • Restroom: Provide accessible signage at non-accessible restroom. 	<p>DAGS will address inaccessible elements. For the most part, facility is accessible.</p>

FACILITIES/ADDRESS	INACCESSIBLE FEATURES	PROGRAM ACCESS OPTIONS
<p>Kona State Office Bldg. No.1 82-6130 Mamalahoa Hwy. Captain Cook, HI</p>	<ul style="list-style-type: none"> • Parking: No accessible stalls & signage, no van accessible stalls or signage. • Accessible Route: Ramp not in compliance. • Building Entrance: No accessible signage. • Restrooms: No signage, door opening too narrow, door hardware needs to be replaced, lavatories not accessible, urinals non-compliant, toilet stalls too narrow, water closet needs to be replaced, need new grab bars, need to relocate toilet seat cover dispenser. • Program Office: No signage, no 60" turnaround space. 	<p>DAGS will address inaccessible features through its transition plan. The Quality Control Office of the DHS Management Services Office, will continue to make home visits.</p>
<p>North Kohala State Office Bldg. 54-3900 Government Main Road Kapaa, HI</p>	<ul style="list-style-type: none"> • Parking: No accessible stalls in upper parking lot, no van accessible stall or signage. • Accessible Route: Not clearly marked, curb ramp not compliant. • Building Entrance: No accessible or directional signage, symbol of accessibility. • Restrooms: No accessible signage, door opening too narrow, opening force exceeds 5 lbs., lavatories too low, urinal non-compliant, toilet stalls too narrow, water closet too low, grab bars not in compliance, toilet paper dispenser needs to be relocated, toilet seat cover dispenser needs to be relocated. • Program Office: No accessible signage, door opening force exceeds 5 lbs., door hardware needs to be replaced, no 60" turnaround radius. 	<p>DAGS will address inaccessible elements through its transition plan. Program will continue to provide equal access to services to persons with disabilities by making reasonable program modifications.</p>
<p>Naalehu State Office Bldg. 85-5669 Mamalahoa Hwy. Naalehu, HI</p>	<ul style="list-style-type: none"> • Parking: No van accessible stall, access aisle needs to be widened, no van accessible signage. • Accessible Route: Route from parking is too narrow. • Building Entrance: No accessible signage, no directional signage at non-accessible entrance, door too narrow. • Restrooms: No accessible signage, door opening force exceeds 5 lbs., no insulation on lavatory pipes, water closet too low, toilet paper dispenser needs to be relocated. • Program Office: No accessible signage and symbol of accessibility. 	<p>DAGS will address inaccessible elements in its transition plan. The program located in this facility will continue to make reasonable modifications to policies and practices to ensure equal access to services.</p>

FACILITIES/ADDRESS	INACCESSIBLE FEATURES	PROGRAM ACCESS OPTIONS
<p>Honokaa State Office Bldg. 45--3380 Mamane St. Honokaa, HI</p>	<ul style="list-style-type: none"> • Parking: No accessible vehicle or van stalls, no signage. • Accessible Route: Parking slopes away from the building; thus, access route is steep and difficult. Need new ramp and handrails. • Building Entrance: No directional signage at inaccessible entrance. • Restrooms: No accessible signage, door too narrow, door opening force exceeds 5 lbs., lavatories non-compliant, mirror too high, paper towel dispenser too high, toilet stalls too narrow, water closet too low, need to replace grab bars. • Program Office: Information not available. 	<p>DAGS will address inaccessible elements. Program shall continue to make reasonable program modifications to ensure equal access to persons with disabilities.</p>
<p>Wailuku State Office Bldg. 54 S. High Street Wailuku, HI</p>	<ul style="list-style-type: none"> • Parking: No van accessible stalls or signage. • Accessible Route: Curb ramp does not comply. • Building Entrance: No accessible signage. • Restrooms: No accessible signage, door too narrow, lavatories do not comply, urinal does not comply, toilet stalls too narrow, water closet too low, need to replace grab bars, toilet paper dispenser needs to be relocated. • Program Offices (two on the 1st and 3rd floors): No accessible room signage. For 3rd floor office, need built-up ramp for threshold. 	<p>DAGS will address inaccessible elements in its transition plan. Two offices located in facility will continue to provide a level of access to persons with disabilities, which is equal to that provided persons without disabilities.</p>