

# MB-38

FOR INSTITUTIONAL AND INDUSTRIAL USES.  
DO NOT STORE IN OR ABOUT DWELLINGS.

ACTIVE INGREDIENT	12.5%
Sodium Hypochlorite	12.5%
OTHER INGREDIENTS	87.5%
TOTAL	100%

EPA Reg. No. 550-198-71898

See side panel for additional precautionary statements.

KEEP OUT OF REACH OF CHILDREN

DANGER

FIRST AID	
<b>IF INHALED:</b>	- Move person to fresh air. - If person is not breathing, call 911 or an ambulance, then give artificial respiration, preferably by mouth-to-mouth, if possible. - Call a Poison Control Center or doctor for further treatment advice.
<b>IF ON SKIN OR CLOTHING:</b>	- Take off contaminated clothing. - Rinse skin immediately with plenty of water for 15-20 minutes. - Call a Poison Control Center or doctor for treatment advice.
<b>IF IN EYES:</b>	- Hold eye open and rinse slowly and gently with water for 15-20 minutes. - Remove contact lenses, if present, after the first 5 minutes, then continue rinsing eyes. - Call a Poison Control Center or doctor for treatment advice.
<b>IF SWALLOWED:</b>	- Call a Poison Control Center or doctor immediately for treatment advice. - Have person sip a glass of water if able to swallow. - Do not induce vomiting unless told to do so by the Poison Control Center or a doctor. - Do not give anything by mouth to an unconscious person.
Have the product container or label with you when calling a Poison Control Center or doctor, or going for treatment. <b>NOTE TO PHYSICIAN:</b> Probable mucosal damage may contraindicate the use of gastric lavage.	

NET CONTENTS: \_\_\_\_\_



Department of Agriculture  
STATE OF HAWAII

LICENSED

PERIOD 2011-2013 LIC. NO.



Department of Agriculture  
STATE OF HAWAII

LICENSED

PERIOD 2014-2016 LIC. NO.

8083.11



**DIRECTIONS FOR USE:** It is a violation of federal law to use this product in a manner inconsistent with its labeling.

**NOTE:** This product degrades with age. Use within one month of receipt. Use a chlorine test kit and increase dosage, as necessary, to obtain the required level of available chlorine.

#### SANITIZATION OF NONPOROUS NON-FOOD CONTACT SURFACES

**RINSE METHOD:** Prepare a sanitizing solution by thoroughly mixing 2 fl. oz. of this product with 10 gallons of water to provide approximately 200 ppm available chlorine by weight. Clean equipment surfaces in the normal manner. Prior to use, rinse all surfaces thoroughly with the sanitizing solution, maintaining contact with the sanitizer for at least 2 minutes. Do not rinse equipment with water after treatment and do not soak equipment overnight.

**IMMERSION METHOD:** Prepare a sanitizing solution by thoroughly mixing, in an immersion tank, 2 fl. oz. of this product with 10 gallons of water to provide approximately 200 ppm available chlorine by weight. Clean equipment in the normal manner. Prior to use, immerse equipment in the sanitizing solution for at least 2 minutes and allow the sanitizer to drain. Do not rinse equipment with water after treatment.

**SPRAY/FOG METHOD:** Pre-clean all surfaces after use. Prepare a 200 ppm available chlorine sanitizing solution of sufficient size by thoroughly mixing this product in a ratio of 2 fl. oz. per 10 gallons of water. Use spray or fogging equipment which can resist hypochlorite solutions. Prior to using equipment, thoroughly spray or fog all surfaces until wet, allowing excess sanitizer to drain. Vacate area for at least 2 hours.

#### DISINFECTION OF NONPOROUS NON-FOOD CONTACT SURFACES

**RINSE METHOD:** Prepare a disinfection solution by thoroughly mixing 6 fl. oz. of this product with 10 gallons of water to provide approximately 600 ppm available chlorine by weight. Clean equipment surfaces in the normal manner. Prior to use, rinse all surfaces thoroughly with the disinfecting solution, maintaining contact with the solution for at least 10 minutes. Do not rinse equipment with water after treatment and do not soak equipment overnight.

**IMMERSION METHOD:** Prepare a disinfecting solution by thoroughly mixing, in an immersion tank, 6 fl. oz. of this product with 10 gallons of water to provide approximately 600 ppm available chlorine by weight. Clean equipment in normal manner. Prior to use, immerse equipment in the disinfecting solution for at least 10 minutes and allow the sanitizer to drain. Do not rinse equipment with water after treatment.

#### SEWAGE & WASTEWATER EFFLUENT TREATMENT

The disinfection of sewage must be evaluated by determining that the total number of coliform bacterial and/or fecal coliform bacteria, as determined by the Most Probable Number (MPN) procedure, of the chlorinated effluent has been reduced to or below the maximum permitted by the controlling regulatory jurisdiction. On the average, satisfactory disinfection of secondary wastewater effluent can be obtained when the chlorine residual is 0.5 ppm after 15 minutes contact. Although the chlorine residual is the critical factor in disinfection, the importance of correlating chlorine residual with bacterial kill must be emphasized. The MPN of the effluent, which is directly related to the water quality standards requirements, should be the final and primary standard and the chlorine residual should be considered an operating standard valid only to the extent verified by the coliform quality of the effluent.

The following are critical factors affecting wastewater disinfection.

- Mixing: It is imperative that the product and the wastewater be instantaneously and completely flash mixed to assure reaction with every chemically active soluble and particulate component of the wastewater.
- Contacting: Upon flash mixing, the flow through the system must be maintained.
- Dosage/Residual Control: Successful disinfection is extremely dependent on response to fluctuating chlorine demand to maintain a predetermined, desirable chlorine level. Secondary effluent should contain 0.2 to 1.0 ppm chlorine residual after a 15 to 30 minute contact time. A reasonable average of residual chlorine is about 0.5 ppm after 15 minutes of contact time.

EPA Est. No						
4140 -				550-		
CA-1	IN-1	NJ-1	TX-1	TX-2	TX-4	OH-003

#### DISINFECTION OF DRINKING WATER

(EMERGENCY/PUBLIC/INDIVIDUAL SYSTEMS)

**PUBLIC SYSTEMS:** Mix a ratio of 1 fl. oz. of this product per 100 gallons of water. Begin feeding this solution with a hypochlorinator until a free available chlorine residual of at least 0.2 ppm and no more than 0.6 ppm is attained throughout the distribution system. Check water frequently with a chlorine test kit. Bacteriological sampling must be conducted at a frequency not less than prescribed by the National Interim Primary Drinking Water Regulations. Contact your local Health Department for further details.

**INDIVIDUAL SYSTEMS: DUG WELLS:** Upon completion of the casing (Lining) wash the interior of the casing (lining) with a 100 ppm available chlorine solution using a stiff brush. This solution can be made by thoroughly mixing 1 fl. oz. of this product into 10 gallons of water. After covering the well, pour the sanitizing solution into the well through both the pipesleeve opening and the pipeline. Wash the exterior of the pump cylinder also with the sanitizing solution. Start pump and pump water until strong odor of chlorine in water is noted. Stop pump and wait at least 24 hours. After 24 hours flush well until all traces of chlorine have been removed from the water. Consult your local Health Department for further details.

**INDIVIDUAL WATER SYSTEMS: DRILLED, DRIVEN, & BORED WELLS:** Run pump until water is as free from turbidity as possible. Pour a 100 ppm available chlorine sanitizing solution into the well. This solution can be made by thoroughly mixing 1 fl. oz. of this product into 10 gallons of water. Add 5 to 10 gallons of clean, chlorinated water to the well in order to force the sanitizer into the rock formation. Wash the exterior of pump cylinder with the sanitizer. Drop pipeline into well, start pump and pump water until strong odor of chlorine in water is noted. Stop pump and wait at least 24 hours. After 24 hours flush well until all traces of chlorine have been removed from the water. Deep wells with high water levels may necessitate the use of special methods for introduction of the sanitizer into the well. Consult your local Health Department for further details.

**INDIVIDUAL WATER SYSTEMS: FLOWING ARTESIAN WELLS:** Artesian wells generally do not require disinfection. If analyses indicate persistent contamination, the well should be disinfected. Consult your local Health Department for further details.

**EMERGENCY DISINFECTION:** When boiling of water for 1 minutes is not practical, water can be made potable by using this product. Prior to addition of the sanitizer, remove all suspended material by filtration or by allowing it to settle to the bottom. Decant the clarified, contaminated water to a clean container and add 1 drop of this product to 20 gallons of water. Allow the treated water to stand for 30 minutes. Properly treated water should have a slight chlorine odor, if not, repeat dosage and allow the water to stand an additional 15 minutes. The treated water can then be made palatable by pouring it between clean containers several times.

#### PUBLIC WATER SYSTEMS

**RESERVOIRS: ALGAE CONTROL:** Hypochlorinated streams feeding the reservoir. Suitable feeding points should be selected on each stream at least 50 yards upstream from the points of entry into the reservoir.

**MAINS:** Thoroughly flush section to be sanitized by discharging from hydrants. Permit a water flow of at least 2.5 feet per minute to continue under pressure while injecting this product by means of a hypochlorinator. Stop water flow when chlorine residual test of 50 ppm is obtained at the low pressure end of the new main section after a 24 hour retention time. When chlorination is complete, the system must be flushed free of all heavily chlorinated water.

**NEW TANKS, BASINS, ETC.:** Remove all physical soil from surfaces. Place 20 fl. oz. of this product per each 5 cubic feet of working capacity (500 ppm available chlorine). Fill to working capacity and allow to stand for at least 4 hours. Drain and flush with potable water and return to surface.

**NEW FILTER SAND:** Apply 80 fl. oz. of this product per each 150 to 200 cubic feet of sand. The action of the product dissolving as the water passes through the bed will aid in sanitizing the new sand.

**NEW WELLS:** Flush the casing with a 50 ppm available chlorine solution of water containing 5 fl. oz. of this product for each 100 gallons of water. The solution should be pumped or fed by gravity into the well after thorough mixing with agitation. The well should stand for several hours or overnight under chlorination. It may then be pumped until a representative raw water sample is obtained. Bacterial examination of the water will indicate whether further treatment is necessary.

**EXISTING EQUIPMENT:** Remove equipment from service, thoroughly clean surfaces of all physical soil. Sanitize by placing 21 fl. oz. of this product per each 5 cubic feet capacity (approximately 500 ppm available chlorine). Fill to working capacity and let stand at least 4 hours. Drain and place in service. If the previous treatment is not practical, surfaces may be sprayed with a solution containing 5 fl. oz. of this product for each 5 gallons of water (approximately 1,000 available chlorine). After drying, flush with water and return to service.

#### EMERGENCY DISINFECTION AFTER MAIN BREAKS

**MAINS:** Before assembly of the repaired section, flush out mud and soil. Permit a water flow of at least 2.5 feet per minute to continue under pressure while injecting this product by means of a hypochlorinator. Stop water flow when a chlorine residual test of 50 ppm is obtained at the low pressure end of the new main section after a 24 hour retention time. When chlorination is completed, the system must be flushed free of all heavily chlorinated water.

#### COOLING TOWER/EVAPORATIVE CONDENSER WATER

**SLUG FEED METHOD:** Initial Dose: When system is noticeably fouled, apply 52 to 104 fl. oz. per 10,000 gallons of water in the system to obtain from 5 to 10 ppm available chlorine. Repeat until control is achieved.

**Subsequent Dose:** When microbial control is evident, add 11 fl. oz. of this product per 10,000 gallons of water in the system daily, or as needed to maintain control and keep the chlorine residual at 1 ppm. Badly fouled systems must be cleaned before treatment is begun.

**INTERMITTENT FEED METHOD:** Initial Dose: When system is noticeably fouled, apply 52 to 104 fl. oz. of this product per 10,000 gallons of water in the system to obtain 5 to 10 ppm available chlorine. Apply half (or 1/3, 1/4, or 1/5) of this initial dose when half (or 1/3, 1/4, or 1/5) of the water in the system has been lost by blowdown.

**Subsequent Dose:** When microbial control is evident, add 11 fl. oz. of this product per 10,000 gallons of water in the system daily, or as needed to maintain control and keep the chlorine residual at 1 ppm. Apply half (or 1/3, 1/4, or 1/5) of this initial dose when half (or 1/3, 1/4, or 1/5) of the water in the system had been lost by blowdown. Badly fouled systems must be cleaned before treatment is begun.

**CONTINUOUS FEED METHOD:** Initial Dose: When system is noticeably fouled, apply 52 to 104 fl. oz. of this product per 10,000 gallons of water to obtain 5 to 10 ppm available chlorine.

**Subsequent Dose:** Maintain this treatment level by starting a continuous feed of 1 fl. oz. per 1,000 gallons of water lost by blowdown to maintain a 1 ppm residual. Badly fouled systems must be cleaned before treatment is begun.

#### PULP AND PAPER MILL PROCESS WATER SYSTEMS

**SLUG FEED METHOD:** Initial Dose: When system is noticeably fouled, apply 52 to 104 fl. oz. of this product per 10,000 gallons of water in the system to obtain from 5 to 10 ppm available chlorine. Repeat until control is achieved.

**Subsequent Dose:** When microbial control is evident, add 11 fl. oz. of this product per 10,000 gallons in the system daily, or as needed to maintain control and keep the chlorine residual at 1 ppm. Badly fouled systems must be cleaned before treatment is begun.

**INTERMITTENT FEED METHOD:** Initial Dose: When system is noticeably fouled, apply 52 to 104 fl. oz. of this product per 10,000 gallons of water in the system to obtain 5 to 10 ppm available chlorine. Apply half (or 1/3, 1/4, or 1/5) of this initial dose when half (or 1/3, 1/4, or 1/5) of the water in the system has been lost by blowdown. Badly fouled systems must be cleaned before treatment is begun.

**Subsequent Dose:** When microbial control is evident, add 11 fl. oz. of this product per 10,000 gallons in the system daily, or as needed to maintain control and keep the chlorine residual at 1 ppm. Apply half (or 1/3, 1/4, or 1/5) of the initial dose when half (or 1/3, 1/4, or 1/5) of the water in the system has been lost by blowdown. Badly fouled systems must be cleaned before treatment is begun.

**CONTINUOUS FEED METHOD:** Initial Dose: When system is noticeably fouled, apply 52 to 104 fl. oz. of this product per 10,000 gallons of water in the system to obtain 5 to 10 ppm available chlorine.

**Subsequent Dose:** Maintain this treatment level by starting a continuous feed of 1 fl. oz. of this product per 1,000 gallons of water lost by blowdown to maintain a 1 ppm residual. Badly fouled systems must be cleaned before treatment is begun.

#### STORAGE AND DISPOSAL

Store this product in a cool dry area, away from direct sunlight and heat to avoid deterioration. In case of spill, flood areas with large quantities of water. Product or rinsates that cannot be used should be diluted with water before disposal in a sanitary sewer. Do not reuse container but place in trash collection. Do not contaminate food or feed by storage, disposal or cleaning of equipment.

Nonrefillable container. Do not reuse or refill this container. Offer for recycling if available. Clean container promptly after emptying. Triple rinse as follows: Empty the remaining contents into application equipment or a mix tank and drain for 10 seconds after the flow begins to drip. Fill the container 1/4 full with water and recap. Shake for 10 seconds. Pour rinsate into application equipment or a mix tank or store rinsate for later use or disposal. Drain for 10 seconds after the flow begins to drip. Repeat this procedure two more times.

#### PRECAUTIONARY STATEMENTS

##### HAZARDS TO HUMANS AND DOMESTIC ANIMALS

**DANGER:** Corrosive, may cause severe skin and eye irritation or chemical burns to broken skin. Causes eye damage. Wear safety glasses or goggles and rubber gloves when handling this product. Wash after handling. Avoid breathing vapors. Vacate poorly ventilated areas as soon as possible. Do not return until strong odors have dissipated.

**ENVIRONMENTAL HAZARDS:** This pesticide is toxic to fish and aquatic organisms. Do not discharge effluent containing this product into lakes, streams, ponds, estuaries, oceans or other waters unless in accordance with the requirements of a National Pollutant Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the local sewage treatment plant authority. For guidance contact your State Water Board or Regional Office of the EPA.

##### PHYSICAL OR CHEMICAL HAZARDS

**STRONG OXIDIZING AGENT:** Mix only with water according to label directions. Mixing this product with chemicals (e.g. ammonia, acids, detergents, etc.) or organic matter (e.g. urine, feces, etc.) will release chlorine gas, which is irritating to eyes, lungs and mucous membranes.

##### CONTAINER ADVICE

##### KEEP CONTAINER CLOSED

**Handling:** Always wear protective clothing including goggles, rubber gloves and apron. Wear respiratory protection if local exhaust ventilation is inadequate. Vent container frequently, and more often in hot weather, to relieve pressure. Loosen closure cautiously when opening and replace closure after each withdrawal. Do not use pressure to empty since the container is not a pressure vessel. Wash thoroughly after handling.

**Empty Containers:** The empty container retains product vapor and residue. Never add any chemicals to this empty container because violent and dangerous reactions may occur. FOLLOW ALL LABEL WARNINGS EVEN AFTER THE CONTAINER IS EMPTY.

##### EMERGENCY RESPONSE

For emergency assistance involving chemicals call CHEMTREC® day or night at 1-800-424-9300.

**In case of Fire:** Use water spray, dry chemical, or CO<sub>2</sub>. Do not use a direct water stream. Use water spray to cool nearby containers exposed to fire. Firefighters should wear self-contained breathing apparatus.

**In case of Spill:** Wear protective equipment including rubber boots, rubber gloves, rubber apron, chemical goggles, and respiratory protection. Flush small spills into waste treatment system with lots of water. For large spills, contain, neutralize with dilute sodium bisulfite, flush neutralized material to waste treatment system with lots of water. Avoid contact with acids. Do not use combustible materials, such as saw dust to absorb spills. Comply with all governmental regulations on reporting releases.

KEEP OUT OF REACH OF CHILDREN, IRRESPONSIBLE PERSONS, AND PETS

FOR ADDITIONAL INFORMATION, SEE MATERIAL SAFETY DATA SHEET.

Not for Resale

MADE IN THE U.S.A. • CS17CABA • 1M001A

TO REORDER, Call TOLL-FREE:  
**1-800-527-9921**  
FAX: 1-972-438-0634

Distributed by  
**CHEM-AQUA, INC.**  
P.O. Box 152170  
Irving, Texas 75015  
**www.chemaqua.com**  
©2010 CHEM-AQUA, Inc.



Certified to  
NSF/ANSI 60

Maximum Use Level  
for Potable Water:  
60 mg/L

