

Buckman WSCP 1500

ACTIVE INGREDIENT(S) Poly[oxyethylene(dimethyliminio)ethylene(dimethyliminio)ethylene dichloride].....	15.0%
INERT INGREDIENTS.....	85.0%
TOTAL.....	100.0%

**KEEP OUT OF REACH OF CHILDREN
CAUTION**

FIRST AID	
If in Eyes	- Hold eye open and rinse slowly and gently with water for 15-20 minutes. - Remove contact lenses, if present, after the first 5 minutes, then continue rinsing eye. - Call a poison control center or doctor for further treatment advice.
If on Skin, Clothes	- Take off contaminated clothing. - Rinse skin immediately with plenty of water for 15-20 minutes. - Call a poison control center or doctor for treatment advice.
If Swallowed	- Call poison control center or doctor immediately for treatment advice. - Have person sip a glass of water, if able to swallow. - Do not induce vomiting unless told to do so by the poison control center or doctor. - Do not give anything by mouth to an unconscious person.
If Inhaled	- Move person to fresh air. - If person is not breathing, call 911 or an ambulance, then give artificial respiration, preferably by mouth-to-mouth if possible. - Call a poison control center or doctor for further treatment advice.
HOT LINE NUMBER	
Have the product container or label with you when calling a Poison Control Center or doctor or going for treatment. You may also contact 901-767-2722 for emergency medical treatment information.	
NOTE TO PHYSICIAN	
Not available.	

Precautionary Statements

HAZARDS TO HUMANS AND DOMESTIC ANIMALS

CAUTION: Causes moderate eye irritation. Harmful if swallowed. Avoid breathing vapors. Avoid contact with skin, eyes, or clothing. Wear chemical-resistant eyewear. Wash thoroughly with soap and water after handling and before eating, drinking, chewing gum, using tobacco, or using the toilet. Remove and wash clothing before reuse.

ENVIRONMENTAL HAZARDS: This pesticide is toxic to fish, aquatic organisms and clams. Do not discharge effluent containing this product into lakes, streams, ponds, estuaries, oceans or other waters unless in accordance with the requirements of a National Pollutant Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the local sewage treatment plant authority. For guidance contact your State Water Board or Regional Office of the EPA.


Directions for Use

It is a violation of Federal law to use this product in a manner inconsistent with its labeling. WSCP 1500 is used to control the growth of algae, bacteria, and fungi in recirculating commercial and industrial water cooling towers and recirculating cooling systems.

WATER COOLING TOWERS: Prior to the use of WSCP 1500 in water cooling towers, clean the systems to remove algal growth, microbiological slime, and other deposits. Then make an initial slug addition of 4 to 10 fluid ounces of WSCP 1500 per 1000 gallons of water to provide 32 to 80 ppm WSCP 1500, based on the total weight of water in the system. Repeat initial dosage until control is evident. Make subsequent slug additions of 1.0 to 10.0 fluid ounces of WSCP 1500 per 1000 gallons of water (8 to 80 ppm WSCP 1500) every 2 to 5 days or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Make slug additions into the sump of water cooling towers.

INDUSTRIAL AIR WASHING SYSTEMS: WSCP 1500 is used to control bacteria in industrial air washing systems that maintain effective mist eliminating components. Prior to its use, clean the systems to remove bacterial slime and other deposits. Make an initial slug dose of 14.8 to 24.7 fluid ounces of WSCP 1500 per 1000 gallons of water. Repeat initial dosage until control is evident. Make subsequent slug additions of 10.1 to 24.7 fluid ounces of WSCP 1500 per 1000 gallons of water each 1 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and severity of the bacterial problem. Make slug additions into the sump or into the water collection trays of the airwash system.

DECORATIVE FOUNTAINS: WSCP 1500 is used to control the growth of algae in decorative fountains that do not contain fish. Manually clean heavy growths of algae prior to treatment. Fountains with just visible algae growth require an initial dose of 5 to 8 fluid ounces of WSCP 1500 per 1000 gallons of water. To treat a freshly cleaned and filled fountain, add 3 to 5 fluid ounces of WSCP 1500 per 1000 gallons of water. For maintenance dosages, add 1 to 2 fluid ounces of WSCP 1500 per 1000 gallons of water every 5 to 7 days as needed. Make sure WSCP 1500 is added at a point where it can be uniformly distributed. WSCP 1500 may be used in fountains treated with chlorine chemicals, but do not mix WSCP 1500 with concentrated dry or liquid chlorine products.



STATE OF HAWAII
Department of Agriculture
ACCEPTED
LICENSE NO. 9599.31

Storage and Disposal

Do not contaminate water, food, or feed by storage or disposal. Do not ship with Food, Feed, Drugs, or Clothing.

PESTICIDE STORAGE: Keep container closed when not in use. In case of spills, use sawdust or sand to absorb the spilled pesticide and disposed of in a sanitary landfill.

PESTICIDE DISPOSAL: Wastes resulting from the use of this product may be disposed of on-site or at an approved waste disposal facility.

CONTAINER HANDLING: Nonrefillable container. Do not reuse or refill this container. Triple rinse container (or equivalent) promptly after emptying. Triple rinse as follows: Empty the remaining contents into application equipment or a mix tank and drain for 10 seconds after the flow begins to drip. Fill the container 1/4 full with water and recap. Shake for 10 seconds. Pour rinsate into application equipment or a mix tank or store rinsate for the later use or disposal. Drain for 10 seconds after the flow begins to drip. Repeat this procedure two more times.

Then offer for recycling if available or reconditioning, if appropriate, or by other procedures if approved by state and local authorities.

*** Specimen Label ***

Manufactured by
Buckman Laboratories, Inc.
1256 North McLean Blvd.
Memphis, Tennessee 38108, USA
(901) 278-0330 or 1-800-282-5626

EPA Est. No. 1448-TN-1
EPA Reg. No. 1448-212
Product Weight 8.6 lbs/gal. 1.03 kg/l
Net contents are marked on the container.

HMIS / NPCA Ratings

Health 1 Flammability 1 Reactivity 0

Last Revision 6/22/2012

NonRefillable Less Than Or Equal To 5 Gallons